

Handling of Repairs to Fire Alarm and Extinguishing Systems

- A. The building fire alarm system shall be tested daily by the school custodian prior to the beginning of classes.
- B. Any breakdown, need of repair, or loss of power in the building fire alarm or extinguishing systems shall be reported immediately upon detection to the Maintenance Department at 301-952-6500. These calls will be handled as emergencies by that department, and repair personnel will be dispatched to effect the repair as soon as they become available or can be contacted.
- C. When it is discovered that building fire alarms or extinguishing systems are in need of repair or have been found inoperative, the Prince George's County Fire Department shall be called at 301-499-8400, to notify them that the system is not in working order and that the Maintenance Department has been called. The Prince George's County Fire Department will not dispatch equipment or personnel but will note that the fire protection system is not in operation.
- D. As soon as the fire protection system has been repaired, notify the Prince George's County Fire Department of this fact so that their notation may be cleared.