



Environmental Consultants and Engineers

1818 New York Avenue Suite 217
Washington, DC 20002

www.globalincusa.net

May 29, 2019

Prince Georges County
Environmental Safety Office
13306 Old Marlboro Pike
Upper Marlboro, MD 20772

Attention: Mr. Alex Baylor

RE: Indoor Air Quality Screening

Global Project Number: 19-015
School: Cool Spring Elementary School

Dear Mr. Baylor,

On May 15, 2019, Global Inc.'s (GLOBAL) team of Industrial Hygienists under the supervision of GLOBAL's Certified Industrial Hygienist, Ms. Lauren Kesslak, conducted an Indoor Air Quality Screening at Cool Springs Elementary School located at 8910 Riggs Rd, Adelphi, MD 20783.

Methodology

The IAQ evaluation included a visual assessment, sampling for non-viable mold spores in air, and measurement of comfort parameters (temperature, humidity, carbon dioxide, and carbon monoxide) in randomly selected representative locations within the building. During the visual assessment of representative locations, and when noted, GLOBAL documented those areas with suspected mold growth, water intrusions, and wet conditions that have the potential to lead to mold growth. GLOBAL also noted any unusual odors. At least one microbial air sample was collected for every 10,000 Square Feet (SF) of space in the building and the analytical results for the interior spaces were compared to an outdoor (ambient) sample collected on the same day.

Microbial samples (including a field blank for quality control) were delivered under strict chain-of-custody procedures were to Hayes Microbial Consulting - an AIHA EMPAT-certified laboratory in Midlothian, Virginia for analysis by microscopy. The sample chain-of-custody and laboratory report is attached.

Observations and Results

GLOBAL's inspector conducted a walkthrough with Prince Georges County Public School (PGCPS) personnel present. Rooms were selected in a random manner throughout the building so as to prevent sampling bias.



Environmental Consultants and Engineers

1818 New York Avenue Suite 217
Washington, DC 20002

www.globalincusa.net

Mold-in-Air Samples

There are no definitive regulations or standardized guidelines for addressing airborne mold in an indoor setting. If building systems (ventilation, envelope) are functioning properly, the indoor fungal ecology profile should be consistent with what is encountered outdoors and the spore concentrations should be below the ambient levels. Laboratory analytical results are attached at the end of this report.

Temperature

The American Society of Heating, Refrigerating and Air-Conditioning Engineers (ASHRAE) have published recommendations for year-round acceptable temperatures in Standard 55-2016 (*Thermal Environmental Conditions for Human Occupancy*). The summer comfort range is 73 to 79°F. It is important to note that ASHRAE standards are intended as a suggested guideline as opposed to a regulation.

Relative Humidity (RH)

Relative humidity is a key factor for mold growth. Mold has the potential of growing on suitable surfaces with humidity levels above 60%. ASHRAE standard 62.1-2013 (*Ventilation for Acceptable Indoor Air Quality*) recommends a maximum indoor relative humidity of 65% to preclude the likelihood of condensation on cool surfaces encouraging mold growth. All the indoor relative humidity readings were below the ASHRAE recommended level of 65%.

Carbon Monoxide

Carbon monoxide (CO) is a colorless and odorless gas that is produced by the incomplete combustion of carbon-containing fuels. Oil, gasoline, diesel fuels, wood, coke, and coal are the major sources of CO. All registered CO concentrations were below the EPA National Ambient Air Quality Standard (NAAQS) of 9 ppm.

Carbon Dioxide

Under conditions of maximum occupancy, ASHRAE Standard 62.1-2013, Appendix C, infers that the acceptable carbon dioxide upper limit is the prevailing outdoor carbon dioxide concentration plus 700 parts per million (ppm). On May 15, 2019, the outdoor (ambient) carbon dioxide concentration was approximately 388.5 ppm so indoor concentrations should not exceed approximately 1088.5 ppm (700 + 388.5). All indoor carbon dioxide measurements were within the ASHRAE standards.

Observations are presented in Table 1 and testing results are presented in Table 2.



Environmental Consultants and Engineers

1818 New York Avenue Suite 217
Washington, DC 20002

www.globalincusa.net

Table 1: Observations

Location	Observations
125	No issues
111	No issues
287	No issues
CR12	No issues
CR9	No issues
CR16	No issues
CR5	No issues
Medical Center	No issues
CR25	No issues
CR19	No issues
Multi-Purpose	No issues
CR2	No issues
CR1	No issues

Table 2: Air Quality Results

Sample Location	Temp °F	RH%	CO ppm	CO2 ppm	Normal Fungal Ecology?
Standards	ASHRAE 68 to 75°F	ASHRAE <65%	NAAQS <9	ASHRAE 1088.5	
Ambient	74.4	27.85	0	388.5	N/A
125	75.35	36.75	0	707	Yes
111	75.35	39.4	0	782.5	Yes
287	74.75	35	0	538.5	Yes
CR12	71.6	40	0	502	Yes
CR9	70.4	46.45	0	873	Yes
CR16	70.05	40.55	0	504.5	Yes
CR5	68.75	52.65	0	1074	Yes
Medical Center	69.2	46.1	0	642.5	Yes



Environmental Consultants and Engineers

1818 New York Avenue Suite 217
Washington, DC 20002

www.globalincusa.net

Sample Location	Temp °F	RH%	CO ppm	CO2 ppm	Normal Fungal Ecology?
Standards	ASHRAE 68 to 75°F	ASHRAE <65%	NAAQS <9	ASHRAE 1088.5	
CR25	70.4	45.35	0	491.5	Yes
CR19	70.25	35.55	0	439.5	Yes
Multi-Purpose	68.2	49.15	0	628	Yes
CR2	66.45	57.5	0	784	Yes
CR1	66.25	54.8	0	865.5	Yes



Environmental Consultants and Engineers

1818 New York Avenue Suite 217
Washington, DC 20002

www.globalincusa.net

Conclusions

No indoor air quality issues related to mold were found during the screening performed on May 15, 2019, and all mold samples were found to have a normal ecology for an indoor environment.

It has been our pleasure to conduct these IAQ Screening services for the Prince Georges County Public School system. If you have any questions, please feel free to contact us.

Regards,

A handwritten signature in black ink, appearing to read "Lauren E. Kesslak".

Lauren E. Kesslak, MS, CIH, CSP
Certified Industrial Hygienist

Analysis Report prepared for

Global, Inc.

1818 New York Ave.
Suite 217
Washington, DC, 20002

Phone: (443) 691-0455

19-015
Cool Springs

Collected: May 15, 2019
Received: May 20, 2019
Reported: May 20, 2019

We would like to thank you for trusting Hayes Microbial for your analytical needs!
We received 14 samples by FedEx in good condition for this project on May 20th, 2019.

The results in this analysis pertain only to this job, collected on the stated date, and should not be used in the interpretation of any other job. This report may not be duplicated, except in full, without the written consent of Hayes Microbial Consulting, LLC..

This laboratory bears no responsibility for sample collection activities, analytical method limitations, or your use of the test results. Interpretation and use of test results are your responsibility. Any reference to health effects or interpretation of mold levels is strictly the opinion of Hayes Microbial. In no event, shall Hayes Microbial or any of its employees be liable for lost profits or any special, incidental or consequential damages arising out of the use of these test results.



Steve Hayes, BSMT(ASCP)
Laboratory Director
Hayes Microbial Consulting, LLC.



EPA Laboratory ID: VA01419



Lab ID: #188863



NVLAP Lab Code: 500096-0



DPH License: #PH-0198

Sample Number	1	CSES/51519-01			2	CSES/51519-02			3	CSES/51519-03			4	CSES/51519-04		
Sample Name	CR 125			CR 111			CR 287			CR 12						
Sample Volume	75.00 liter			75.00 liter			75.00 liter			75.00 liter						
Reporting Limit	13 spores/m ³			13 spores/m ³			13 spores/m ³			13 spores/m ³						
Background	2			2			2			2						
Fragments	ND			ND			ND			13/m ³						
Organism	Raw Count	Count / m ³	% of Total	Raw Count	Count / m ³	% of Total	Raw Count	Count / m ³	% of Total	Raw Count	Count / m ³	% of Total				
Alternaria																
Ascospores	4	53	57.1%	1	13	9.1%	2	27	66.7%	2	27	66.7%				
Aspergillus Penicillium	1	13	14.3%													
Basidiospores	1	13	14.3%				1	13	33.3%							
Bipolaris Drechslera																
Chaetomium																
Cladosporium	1	13	14.3%	6	80	54.5%										
Curvularia																
Epicoccum				1	13	9.1%										
Fusarium																
Memnoniella																
Myxomycetes				3	40	27.3%				1	13	33.3%				
Pithomyces																
Stachybotrys																
Stemphylium																
Torula																
Ulocladium																
Total	7	92	100%	11	146	100%	3	40	100%	3	40	100%				

Water Damage Indicator	Common Allergen	Slightly Higher than Baseline	Significantly Higher than Baseline	Ratio Abnormality
------------------------	-----------------	-------------------------------	------------------------------------	-------------------



Collected: **May 15, 2019**

Received: **May 20, 2019**

Reported: **May 20, 2019**

Project Analyst:
 Ramesh Poluri, PhD

P. Ramesh

Date:
05 - 20 - 2019

Reviewed By:
 Steve Hayes, BSMT

Stephen N. Hayes

Date:
05 - 20 - 2019

Sample Number	5	CSES/51519-05			6	CSES/51519-06			7	CSES/51519-07			8	CSES/51519-08		
Sample Name	CR 9			CR 16			CR 5			Media Center						
Sample Volume	75.00 liter			75.00 liter			75.00 liter			75.00 liter						
Reporting Limit	13 spores/m ³			13 spores/m ³			13 spores/m ³			13 spores/m ³						
Background	3			2			4			2						
Fragments	13/m ³			ND			13/m ³			ND						
Organism	Raw Count	Count / m ³	% of Total	Raw Count	Count / m ³	% of Total	Raw Count	Count / m ³	% of Total	Raw Count	Count / m ³	% of Total				
Alternaria																
Ascospores	3	40	60.0%	5	67	83.3%	1	13	33.3%	3	40	75.0%				
Aspergillus Penicillium																
Basidiospores	1	13	20.0%	1	13	16.7%										
Bipolaris Drechslera																
Chaetomium																
Cladosporium	1	13	20.0%				2	27	66.7%	1	13	25.0%				
Curvularia																
Epicoccum																
Fusarium																
Memnoniella																
Myxomycetes																
Pithomyces																
Stachybotrys																
Stemphylium																
Torula																
Ulocladium																
Total	5	66	100%	6	80	100%	3	40	100%	4	53	100%				

Water Damage Indicator	Common Allergen	Slightly Higher than Baseline	Significantly Higher than Baseline	Ratio Abnormality
------------------------	-----------------	-------------------------------	------------------------------------	-------------------



Collected: May 15, 2019

Received: May 20, 2019

Reported: May 20, 2019

Project Analyst:
Ramesh Poluri, PhD

P. Ramesh

Date:
05 - 20 - 2019

Reviewed By:
Steve Hayes, BSMT

Stephen N. Hayes

Date:
05 - 20 - 2019

Sample Number	9	CSES/51519-09			10	CSES/51519-10			11	CSES/51519-11			12	CSES/51519-12		
Sample Name	CR 25			CR 19			Multipurpose			CR 2						
Sample Volume	75.00 liter			75.00 liter			75.00 liter			75.00 liter						
Reporting Limit	13 spores/m ³			13 spores/m ³			13 spores/m ³			13 spores/m ³						
Background	2			2			2			2						
Fragments	ND			ND			ND			ND						
Organism	Raw Count	Count / m ³	% of Total	Raw Count	Count / m ³	% of Total	Raw Count	Count / m ³	% of Total	Raw Count	Count / m ³	% of Total				
Alternaria																
Ascospores	3	40	37.5%	12	160	75.0%	2	27	66.7%	2	27	100.0%				
Aspergillus Penicillium	1	13	12.5%				1	13	33.3%							
Basidiospores	3	40	37.5%	1	13	6.3%										
Bipolaris Drechslera																
Chaetomium																
Cladosporium	1	13	12.5%	3	40	18.8%										
Curvularia																
Epicoccum																
Fusarium																
Memnoniella																
Myxomycetes																
Pithomyces																
Stachybotrys																
Stemphylium																
Torula																
Ulocladium																
Total	8	106	100%	16	213	100%	3	40	100%	2	27	100%				

Water Damage Indicator	Common Allergen	Slightly Higher than Baseline	Significantly Higher than Baseline	Ratio Abnormality
------------------------	-----------------	-------------------------------	------------------------------------	-------------------

Collected: **May 15, 2019**

Received: **May 20, 2019**

Reported: **May 20, 2019**



Project Analyst:
Ramesh Poluri, PhD

P. Ramesh

Date:
05 - 20 - 2019

Reviewed By:
Steve Hayes, BSMT

Stephen A. Hayes

Date:
05 - 20 - 2019

Sample Number	13	CSES/51519-13			14	CSES/51519-14				
Sample Name	CR 1			Ambient						
Sample Volume	75.00 liter			75.00 liter						
Reporting Limit	13 spores/m ³			13 spores/m ³						
Background	2			2						
Fragments	ND			27/m ³						
Organism	Raw Count	Count / m ³	% of Total	Raw Count	Count / m ³	% of Total				
Alternaria										
Ascospores	8	107	72.7%	48	640	72.7%				
Aspergillus Penicillium				3	40	4.5%				
Basidiospores	1	13	9.1%	10	133	15.2%				
Bipolaris Drechslera										
Chaetomium										
Cladosporium	2	27	18.2%	4	53	6.1%				
Curvularia										
Epicoccum				1	13	1.5%				
Fusarium										
Memnoniella										
Myxomycetes										
Pithomyces										
Stachybotrys										
Stemphylium										
Torula										
Ulocladium										
Total	11	147	100%	66	879	100%				

Water Damage Indicator	Common Allergen	Slightly Higher than Baseline	Significantly Higher than Baseline	Ratio Abnormality
------------------------	-----------------	-------------------------------	------------------------------------	-------------------



Collected: **May 15, 2019** Received: **May 20, 2019** Reported: **May 20, 2019**

Project Analyst: Ramesh Poluri, PhD	<i>P. Ramesh</i>	Date: 05 - 20 - 2019	Reviewed By: Steve Hayes, BSMT	<i>Stephen N. Hayes</i>	Date: 05 - 20 - 2019
--	------------------	--------------------------------	-----------------------------------	-------------------------	--------------------------------

Spore Trap Information

Reporting Limit	The Reporting Limit is the lowest number of spores that can be detected based on the total volume of the sample collected and the percentage of the slide that is counted. At Hayes Microbial, 100% of the slide is read so the LOD is based solely on the total volume. Raw spore counts that exceed 500 spores will be estimated.					
Blanks	Results have not been corrected for field or laboratory blanks.					
Background	<p>The Background is the amount of debris that is present in the sample. This debris consists of skin cells, dirt, dust, pollen, drywall dust and other organic and non-organic matter. As the background density increases, the likelihood of spores, especially small spores such as those of Aspergillus and Penicillium may be obscured. The background is rated on a scale of 1 to 5 and each level is determined as follows:</p> <p>NBD: No background detected due to possible pump or cassette malfunction. Recollect sample. (Field Blanks will display NBD)</p> <p>1 : <5% of field occluded. No spores will be uncountable.</p> <p>2 : 5-25% of field occluded.</p> <p>3 : 25-75% of field occluded.</p> <p>4 : 75-90% of field occluded.</p> <p>5 : >90% of field occluded. Suggested recollection of sample.</p>					
Fragments	Fragments are small pieces of fungal mycelium or spores. They are not identifiable as to type and when present in very large numbers, may indicate the presence of mold amplification.					
Control Comparisons	There are no national standards for the numbers of fungal spores that may be present in the indoor environment. As a general rule and guideline that is widely accepted in the indoor air quality field, the numbers and types of spores that are present in the indoor environment should not exceed those that are present outdoors at any given time. There will always be some mold spores present in "normal" indoor environments. The purpose of sampling and counting spores is to help determine whether an abnormal condition exists within the indoor environment and if it does, to help pinpoint the area of contamination. Spore counts should not be used as the sole determining factor of mold contamination. There are many factors that can cause anomalies in the comparison of indoor and outdoor samples due to the dynamic nature of both of those environments.					
<table border="1"> <tr><td>Water Damage Indicator</td></tr> <tr><td>Common Allergen</td></tr> <tr><td>Slightly Higher than Baseline</td></tr> <tr><td>Significantly Higher than Baseline</td></tr> <tr><td>Ratio Abnormality</td></tr> </table>	Water Damage Indicator	Common Allergen	Slightly Higher than Baseline	Significantly Higher than Baseline	Ratio Abnormality	<p>Blue: These molds are commonly seen in conditions of prolonged water intrusion and usually indicate a problem.</p> <p>Green: Although all molds are potential allergens, these are the most common allergens that may be found indoors.</p> <p>Orange: The spore count is slightly higher than the outside count and may or may not indicate a source of contamination.</p> <p>Red: The spore count is significantly higher than the baseline count and probably indicates a source of contamination.</p> <p>Violet: The types of spores found indoors should be similar to the ones that were identified in the baseline sample. Significant increases (more than 25%) in the ratio of a particular spore type may indicate the presence of abnormal levels of mold, even if the total number of spores of that type is lower in the indoor environment than it was outdoors.</p>
Water Damage Indicator						
Common Allergen						
Slightly Higher than Baseline						
Significantly Higher than Baseline						
Ratio Abnormality						
Color Coding	Fungi that are present in indoor samples at levels lower than 200 per cubic meter are not color coded on the report, unless they are one of the water damage indicators.					

Organism Descriptions

Ascospores	Habitat: A large group consisting of more than 3000 species of fungi. Common plant pathogens and outdoor numbers become very high following rain. Most of the genera are indistinguishable by spore trap analysis and are combined on the report.
	Effects: Health affects are poorly studied, but many are likely to be allergenic.

Aspergillus Penicillium	Habitat: The most common fungi isolated from the environment. Very common in soil and on decaying plant material. Are able to grow well indoors on a wide variety of substrates.
	Effects: This group contains common allergens and many can cause hypersensitivity pneumonitis. They may cause extrinsic asthma, and many are opportunistic pathogens. Many species produce mycotoxins which may be associated with disease in humans and other animals. Toxin production is dependent on the species, the food source, competition with other organisms, and other environmental conditions.

Basidiospores	Habitat: A common group of Fungi that includes the mushrooms and bracket fungi. They are saprophytes and plant pathogens. In wet conditions they can cause structural damage to buildings.
	Effects: Common allergens and are also associated with hypersensitivity pneumonitis.

Cladosporium	Habitat: One of the most common genera worldwide. Found in soil and plant debris and on the leaf surfaces of living plants. The outdoor numbers are lower in the winter and often relatively high in the summer, especially in high humidity. The outdoor numbers often spike in the late afternoon and evening. Indoors, it can be found growing on textiles, wood, sheetrock, moist window sills and in HVAC supply ducts.
	Effects: A common allergen, producing more than 10 allergenic antigens and a common cause of hypersensitivity pneumonitis.

Epicoccum	Habitat: It is found in soil and plant litter and is a plant pathogen. It can grow indoors on a variety of substrates, including paper and textiles and is commonly found on wet drywall.
	Effects: It is a common allergen. No cases of infection have been reported in humans.

Myxomycetes	Habitat: Found on decaying plant material and as a plant pathogen.
	Effects: Some allergenic properties reported, but generally pose no health concerns to humans.



Company: Global Inc.
 Address: 1818 New York Ave NE 217
Washington, DC 20002

N

SHIP: FEDEX - PAK 50
 DATE: 05-20-2019



7752 4965 2328



Job Number: 19-015 Job Name: Cool Springs
 Collector: L. Kesslak
 Date Collected: 5-15-19

Mobile: 814-241-9105 Email: Lauren.K@globalincusa.net
 Note:

Analysis Type	Analysis Description	Turnaround	Accepted Media Types
Spore Trap	S	24 Hour	Air Cassettes, Impact Slides
	S+	24 Hour	Air Cassettes, Impact Slides
Direct ID	D	24 Hour	Bio-Tape, Tape, Swab, Bulk, Agar Plate
	D+	24 Hour	Bio-Tape, Tape, Swab, Bulk, Agar Plate
Culture	C1	7 Day	Air Plate, Agar Plate, Swab, Bulk
	C2	4 Day	Air Plate, Agar Plate, Swab, Bulk
	C3	7 Day	Air Plate, Agar Plate, Swab, Bulk
	C5	2 Day	Agar Plate, Swab, Bulk
Particle	TPA	24 Hour	Air Cassettes, Impact Slides, Bio-Tape

#	Number	Sample	Analysis	Volume	Notes
1	CSES/51519-01	CR 125	5	75L	
2	02	CR 111			
3	03	CR 287			
4	04	CR 12			
5	05	CR 9			
6	06	CR 16			
7	07	CR 5			
8	08	Mediq center			
9	09	CR 25			
10	10	CR 19			
11	11	multi purpose			
12	12	CR 2			
13	13	CR 1			
14	14	Ambient			
15					
16					

Released by: [Signature] Date: 5-15-19 Received By: AN 5/20/19 Date: