



June 26, 2019

Prince George's County Public School (PGCPS)
Environmental Safety Office
13306 Old Marlboro Pike
Upper Marlboro, MD 20772

Attention: Alex Baylor
alex.baylor@pgcps.org

Subject: Indoor Air Quality Survey
Cora L. Rice Elementary School
950 Nalley Road
Landover, MD 20785

Mr. Baylor:

On May 29, 2019, a Soil and Land Use Technology, Inc. (SaLUT) Industrial Hygienist conducted an indoor air quality (IAQ) evaluation at Cora L. Rice Elementary School, a property maintained by Prince George's County Public Schools (PGCPS) located at 950 Nalley Road, Landover, MD. The inspection was performed in accordance with PGCPS contract number IFB 022-19.

Methodology

The IAQ evaluation conducted by SaLUT included a visual assessment, IAQ instrumentation screening, and a collection of interior air samples for mold in representative locations throughout the building. Additionally, one building exterior environmental air sample was taken for comparison.

Air-borne fungal spore samples were collected on *Air-O-Cell* cassettes using a Buck BioAire calibrated pump. The air samples were taken between three and five feet from the ground. In tandem with collecting mold samples, real-time readings for carbon dioxide, carbon monoxide, temperature and relative humidity were collected using a Fluke 975 Air Meter in representative areas within the facility. A MiniRAE 3000-photoionization detector (PID) was used to measure total volatile organic compounds (TVOC).

Respirable particulate in air (size classes PM_{2.5} μ and PM₁₀ μ) was measured using the Particles Plus 8306 Handheld Particle Counter which was calibrated prior to sampling. The fungal spore air samples were delivered to EMSL Analytical, Inc. of Beltsville,

Maryland for analysis. Fungal spores and particulates in air samples were analyzed by Optical Microscopy (methods EMSL 05-TP-003 and ASTM D7391). The sample chain-of-custody and laboratory reports are attached.

Observations

The table below summarizes the main observations from the IAQ survey at Cora L. Rice Elementary School, visited on May 29, 2019.

Table 1-Observations

Location	Summary of Observations 5-29-2019
Classroom G-102	2'x4' ceiling tiles and 1'x1' tile floor; No visual signs of microbial growth, and no odor; No visible dust on floor/other furniture surfaces; Central HVAC system.
Classroom G-107	2'x4' ceiling tiles and 1'x1' tile floor; No visual signs of microbial growth, and no odor; No visible dust on floor/other furniture surfaces; Central HVAC system.
Classroom G-111	2'x4' ceiling tiles and 1'x1' tile floor; No visual signs of microbial growth, and no odor; No visible dust on floor/other furniture surfaces; Central HVAC system.
Classroom K-111	2'x4' ceiling tiles and 1'x1' tile floor; No visual signs of microbial growth, and no odor; No visible dust on floor/other furniture surfaces; Central HVAC system.
Classroom L-201	2'x4' ceiling tiles and 1'x1' tile floor; No visual signs of microbial growth, and no odor; No visible dust on floor/other furniture surfaces; Central HVAC system.
Classroom L-205	2'x4' ceiling tiles and 1'x1' tile floor; No visual signs of microbial growth, and no odor; No visible dust on floor/other furniture surfaces; Central HVAC system.

Measurements of Indoor Environmental Quality Parameters

Table 2 depicts a summary of average measurements of comfort parameters and respirable particulates.

Temperature

The American Society of Heating, Refrigerating and Air-Conditioning Engineers (ASHRAE) have published recommendations for year round acceptable temperatures in Standard 55-2010 *Thermal Environmental Conditions for Human Occupancy*. The winter comfort range is 20 to 24°C (68 to 75°F) and 23 to 26°C (73 to 79°F) is the summer comfort

range. The temperature readings were within the ASHRAE recommended ranges in the representative spaces with the exception of some readings which were slightly lower than the ASHRAE comfort level.

Relative Humidity (RH)

RH is a key factor for mold growth. Mold has the potential of growing on suitable surfaces with humidity levels above 60%. ASHRAE Standard 62.1-2010 *Ventilation for Acceptable Indoor Air Quality* recommends a maximum indoor RH of 65% to preclude the likelihood of condensation on cool surfaces encouraging mold growth. The RH readings were within the ASHRAE recommended ranges in the representative areas.

Carbon Dioxide (CO₂)

Under conditions of maximum occupancy, ASHRAE Standard 62.1-2010, Appendix C, infers that the acceptable CO₂ upper limit is the prevailing outdoor CO₂ concentration plus 700 parts per million (ppm). On the day of the space evaluation, the outdoor (building exterior) CO₂ concentration was approximately 405 ppm therefore indoor concentrations should not exceed approximately 1,105 ppm (700 + 405). The maximum average interior CO₂ concentration detected was 1,034 ppm in Classroom L201, a range within the ASHRAE recommendations, per Table 2 below.

Carbon Monoxide (CO)

CO is a colorless and odorless gas that is produced by the incomplete combustion of carbon containing fuels. Oil, gasoline, diesel fuels, wood, coke, and coal are major sources of CO. All registered CO concentrations were below the EPA National Ambient Air Quality Standard (NAAQS) of 9 ppm, per Table 2 below.

Respirable Particulates

Direct reading particulate monitoring did not identify a condition of concern. Particulate concentrations for two mass ranges with EPA ambient air quality guidelines (PM_{2.5} and PM₁₀) were below their respective NAAQS levels. On May 29, 2019, the highest average PM_{2.5} concentration during the monitoring period was 0.003 mg/m³ (3 µg/m³) in Classroom L201. This is compared to the NAAQS primary standard for PM_{2.5} of 12 µg/m³ annual mean. The highest average PM₁₀ concentration during the same period was 0.038 mg/m³ (38 µg/m³) in Classroom L201. This is compared to NAAQS standard for PM₁₀ of 150 µg/m³ 24 hour average.

Total Volatile Organic Chemicals (TVOC)

LEED's standard of 500 µg/m³ for TVOC (ANSI/ASHRAE Standard 62.1-2010) concentrations per the instrument's level of detection for a healthy commercial building were used as the standard for TVOCs for this survey. Concentrations below this value can be considered as "background levels" and, at such low concentrations, they are

extremely unlikely to cause any adverse health conditions to the occupants. Generally, values below 3000 µg/m³ are unlikely to cause more than mild irritation or headaches, but to date no recognized industry standard has been established for TVOCs. Perfumes, colognes, and air fresheners as well as certain cleaning chemicals can all cause temporary increases in TVOC readings. TVOC readings cannot be used to establish OSHA limits on specific VOCs or be attributed to specific compounds.

**Table 2: Cora L. Elementary School Instrumental Screening Levels
May 29, 2019**

Sample Location	Temp °F	RH%	CO ppm	CO ₂ ppm	PM 2.5 mg/m ³	PM 10 mg/m ³	TVOC ppm
Standards	ASHRAE* 73 to 79°F	ASHRAE <65%	NAAQS 9	ASHRAE 1,105	NAAQS 0.012	NAAQS 0.150	1.0
Classroom G-102	76.1	50.8	1	818	0.001	0.021	0
Classroom G-107	73.4	59.2	1	965	0.002	0.031	0.1
Classroom G-111	75.2	64.0	1	835	0.001	0.021	0
Classroom K-111	72.5	58.5	1	901	0.001	0.018	0
Classroom L-201	72.5	61.7	0	1034	0.003	0.038	0.1
Classroom L-205	59.8	65.8	1	796	0.001	0.027	0.1
Outside	87.5	47.8	1	405	0.003	0.049	0.1

PM - Particulate Matter size
°F - Degrees Fahrenheit
CO - Carbon Monoxide
ppm - parts per million

µg/m³ - micrograms per cubic meter
RH% - % Relative Humidity
CO₂ - Carbon Dioxide
* - Summer Comfort Range

Mold-in-Air Samples

There are no definitive regulations or standardized guidelines for addressing airborne mold in an indoor setting. If building systems (ventilation, envelope) are functioning properly, the indoor population profile should mimic what is encountered outdoors and the concentrations should be below the outdoor (building exterior) environmental sample levels.

Tables 3 summarizes airborne mold spore sampling results and locations. On May 29, 2019, total mold counts in representative samples (spore count/m³ of air) in all the areas inspected were lower than the outdoor concentrations. Laboratory analysis follows this report (see attachment).

**Table 3: Cora L. Elementary School - Measurements of Mold-in-Air Samples
May 29, 2019**

Spore Types	Classroom G102	Classroom G107	Classroom G111	Classroom K111
<i>Alternaria (Ulocladium)</i>	-	-	-	-
<i>Ascospores</i>	-	-	40	40
<i>Aspergillus/Penicillium</i>	-	90	-	-
<i>Basidiospores</i>	90	300	300	40
<i>Bipolaris++</i>	-	-	-	-
<i>Chaetomium</i>	-	-	-	-
<i>Cladosporium</i>	-	-	100	-
<i>Curvularia</i>	-	-	-	-
<i>Epicoccum</i>	-	-	-	-
<i>Fusarium</i>	-	-	-	-
<i>Ganoderma</i>	-	-	-	-
<i>Myxomycetes++</i>	-	-	-	-
<i>Pithomyces++</i>	-	-	-	-
<i>Rust</i>	-	-	-	-
<i>Scopulariopsis/Microascus</i>	-	-	-	-
<i>Stachybotrys/Memmoniella</i>	-	-	-	-
<i>Unidentifiable Spores</i>	-	90	-	-
<i>Zygomycetes</i>	-	-	-	-
<i>Polythrincium</i>	-	-	-	-
<i>Hyphal Fragment</i>	-	100	-	40
<i>Insect Fragment</i>	-	-	-	-
<i>Pollen</i>	-	-	-	-
Total Fungi	90	480	440	80

*Spore Counts per cubic meter of air (Counts/m³).

++Includes other spores with similar morphology.

Table 3: Cora L. Elementary School High School - Measurements of Mold-in-Air Samples Continued

May 29, 2019

Spore Types	Classroom L201	Classroom L205	Outside Exterior EV Sample	Field Blank
<i>Alternaria (Ulocladium)</i>	-	-	-	-
<i>Ascospores</i>	-	-	300	-
<i>Aspergillus/Penicillium</i>	90	-	300	-
<i>Basidiospores</i>	40	300	2,400	-
<i>Bipolaris++</i>	-	-	-	-
<i>Chaetomium</i>	-	-	-	-
<i>Cladosporium</i>	-	300	3,000	-
<i>Curvularia</i>	-	-	-	-
<i>Epicoccum</i>	-	-	-	-
<i>Fusarium</i>	-	-	-	-
<i>Ganoderma</i>	-	-	-	-
<i>Myxomycetes++</i>	10*	-	-	-
<i>Pithomyces++</i>	-	10*	-	-
<i>Rust</i>	-	-	-	-
<i>Scopulariopsis/Microascus</i>	-	-	-	-
<i>Stachybotrys/Memnoniella</i>	-	-	-	-
<i>Unidentifiable Spores</i>	40	-	-	-
<i>Zygomycetes</i>	-	-	-	-
<i>Polythrincium</i>	-	-	40	-
<i>Hyphal Fragment</i>	-	40	-	-
<i>Insect Fragment</i>	-	-	-	-
<i>Pollen</i>	-	-	40	-
Total Fungi	180	610	6,040	No Trace

*Spore Counts per cubic meter of air (Counts/m³).

++Includes other spores with similar morphology.

Findings and Conclusions

The comfort parameters (i.e., temperature, RH, CO₂, and CO levels) and respirable particulates in the representative areas conform to ASHRAE and/or NAAQS guidelines with the exception of the some temperature readings which were lower than the ASHRAE comfort level. On May 29, 2019, total mold counts in representative area samples (spore count/m³ of air) in all the areas inspected were lower than the outdoor concentrations, indicating no amplified mold growth.

Recommendations

Based on the observations, mold spore results, and the results of the indoor air quality parameters tested, we have no recommendations at this time.



Page 7 of 7

Thank you for the opportunity to provide industrial hygiene services for PGCPS. If you have any questions, please contact me at 301.595.3783.

Sincerely,

A handwritten signature in black ink, appearing to read 'Jayatilake', written over a horizontal line.

Chaminda Jayatilake, PE, CIH, CSP, CHMM
Certified Industrial Hygienist
Soil and Land Use Technology Inc. (SaLUT)

Attachment

Attachment - Mold Spore Sample Analytical Results and Chain-of-Custody Forms

Attachment

Mold Spore Sample Analytical Results and Chain-of-Custody Forms



EMSL Analytical, Inc.

528 Mineola Avenue Carle Place, NY 11514
Tel/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> / carleplacelab@emsl.com

EMSL Order: 061910890
Customer ID: SALU50
Customer PO:
Project ID:


Attn: Indika Jayatilake
SaLUT
1818 New York Avenue, NE
Suite 218A
Washington, DC 20002
Project: PGCPs IAQ/19-035 Cora Rice ES

Phone: (301) 595-3783
Fax: (301) 595-3787
Collected: 05/29/2019
Received: 05/30/2019
Analyzed: 06/05/2019

Test Report: Air-O-Cell™ Analysis of Fungal Spores & Particulates by Optical Microscopy (Methods MICRO-SOP-201, ASTM D7391)

Lab Sample Number: Client Sample ID: Volume (L): Sample Location	061910890-0001 28458476 75 Classroom L 201	061910890-0002 28458489 75 Classroom G 111	061910890-0003 28458514 75 Classroom K 111						
Spore Types	Raw Count	Count/m³	% of Total	Raw Count	Count/m³	% of Total	Raw Count	Count/m³	% of Total
Alternaria (Ulocladium)	-	-	-	-	-	-	-	-	-
Ascospores	-	-	-	1	40	9.1	1	40	50
Aspergillus/Penicillium	2	90	50	-	-	-	-	-	-
Basidiospores	1	40	22.2	7	300	68.2	1	40	50
Bipolaris++	-	-	-	-	-	-	-	-	-
Chaetomium	-	-	-	-	-	-	-	-	-
Cladosporium	-	-	-	3	100	22.7	-	-	-
Curvularia	-	-	-	-	-	-	-	-	-
Epicoccum	-	-	-	-	-	-	-	-	-
Fusarium	-	-	-	-	-	-	-	-	-
Ganoderma	-	-	-	-	-	-	-	-	-
Myxomycetes++	1*	10*	5.6	-	-	-	-	-	-
Pithomyces++	-	-	-	-	-	-	-	-	-
Rust	-	-	-	-	-	-	-	-	-
Scopulariopsis/Microascus	-	-	-	-	-	-	-	-	-
Stachybotrys/Memnoniella	-	-	-	-	-	-	-	-	-
Unidentifiable Spores	1	40	22.2	-	-	-	-	-	-
Zygomycetes	-	-	-	-	-	-	-	-	-
Polythrincium	-	-	-	-	-	-	-	-	-
Total Fungi	5	180	100	11	440	100	2	80	100
Hyphal Fragment	1	40	-	-	-	-	1	40	-
Insect Fragment	-	-	-	-	-	-	-	-	-
Pollen	-	-	-	-	-	-	-	-	-
Analyt. Sensitivity 600x	-	44	-	-	44	-	-	44	-
Analyt. Sensitivity 300x	-	13*	-	-	13*	-	-	13*	-
Skin Fragments (1-4)	-	2	-	-	1	-	-	1	-
Fibrous Particulate (1-4)	-	1	-	-	1	-	-	1	-
Background (1-5)	-	3	-	-	1	-	-	1	-

++ Includes other spores with similar morphology; see EMSL's fungal glossary for each specific category.


Jeffrey Lau, Microbiology Laboratory Manager
or other approved signatory

High levels of background particulate can obscure spores and other particulates leading to underestimation. Background levels of 5 indicate an overloading of background particulates, prohibiting accurate detection and quantification. Present = Spores detected on overloaded samples. Results are not blank corrected unless otherwise noted. The detection limit is equal to one fungal spore, structure, pollen, fiber particle or insect fragment. *** Denotes particles found at 300X. "-" Denotes not detected. Due to method stopping rules, raw counts in excess of 100 are extrapolated based on the percentage analyzed. EMSL maintains liability limited to cost of analysis. This report relates only to the samples reported above and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. Samples received in good condition unless otherwise noted.

Samples analyzed by EMSL Analytical, Inc. Carle Place, NY AIHA-LAP, LLC--EMLAP Accredited #102344

Initial report from: 06/06/2019 08:15:55

For information on the fungi listed in this report, please visit the Resources section at www.emsl.com



EMSL Analytical, Inc.

528 Mineola Avenue Carle Place, NY 11514
Tel/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> / carleplacelab@emsl.com

EMSL Order: 061910890
Customer ID: SALU50
Customer PO:
Project ID:

Attn: Indika Jayatilake
SaLUT
1818 New York Avenue, NE
Suite 218A
Washington, DC 20002
Project: PGCPs IAQ/19-035 Cora Rice ES

Phone: (301) 595-3783
Fax: (301) 595-3787
Collected: 05/29/2019
Received: 05/30/2019
Analyzed: 06/05/2019

Test Report: Air-O-Cell™ Analysis of Fungal Spores & Particulates by Optical Microscopy (Methods MICRO-SOP-201, ASTM D7391)

Lab Sample Number: Client Sample ID: Volume (L): Sample Location	061910890-0004 28458463 75 Classroom G 107			061910890-0005 28459000 75 Classroom G 102			061910890-0006 28458432 75 Classroom L 205		
Spore Types	Raw Count	Count/m³	% of Total	Raw Count	Count/m³	% of Total	Raw Count	Count/m³	% of Total
Alternaria (Ulocladium)	-	-	-	-	-	-	-	-	-
Ascospores	-	-	-	-	-	-	-	-	-
Aspergillus/Penicillium	2	90	18.8	-	-	-	-	-	-
Basidiospores	6	300	62.5	2	90	100	7	300	49.2
Bipolaris++	-	-	-	-	-	-	-	-	-
Chaetomium	-	-	-	-	-	-	-	-	-
Cladosporium	-	-	-	-	-	-	7	300	49.2
Curvularia	-	-	-	-	-	-	-	-	-
Epicoccum	-	-	-	-	-	-	-	-	-
Fusarium	-	-	-	-	-	-	-	-	-
Ganoderma	-	-	-	-	-	-	-	-	-
Myxomycetes++	-	-	-	-	-	-	-	-	-
Pithomyces++	-	-	-	-	-	-	1*	10*	1.6
Rust	-	-	-	-	-	-	-	-	-
Scopulariopsis/Microascus	-	-	-	-	-	-	-	-	-
Stachybotrys/Memnoniella	-	-	-	-	-	-	-	-	-
Unidentifiable Spores	2	90	18.8	-	-	-	-	-	-
Zygomycetes	-	-	-	-	-	-	-	-	-
Polythrincium	-	-	-	-	-	-	-	-	-
Total Fungi	10	480	100	2	90	100	15	610	100
Hyphal Fragment	3	100	-	-	-	-	1	40	-
Insect Fragment	-	-	-	-	-	-	-	-	-
Pollen	1	40	-	-	-	-	-	-	-
Analyt. Sensitivity 600x	-	44	-	-	44	-	-	44	-
Analyt. Sensitivity 300x	-	13*	-	-	13*	-	-	13*	-
Skin Fragments (1-4)	-	2	-	-	1	-	-	1	-
Fibrous Particulate (1-4)	-	2	-	-	1	-	-	1	-
Background (1-5)	-	3	-	-	1	-	-	1	-

++ Includes other spores with similar morphology; see EMSL's fungal glossary for each specific category.


Jeffrey Lau, Microbiology Laboratory Manager
or other approved signatory

High levels of background particulate can obscure spores and other particulates leading to underestimation. Background levels of 5 indicate an overloading of background particulates, prohibiting accurate detection and quantification. Present = Spores detected on overloaded samples. Results are not blank corrected unless otherwise noted. The detection limit is equal to one fungal spore, structure, pollen, fiber particle or insect fragment. *** Denotes particles found at 300X. "-" Denotes not detected. Due to method stopping rules, raw counts in excess of 100 are extrapolated based on the percentage analyzed. EMSL maintains liability limited to cost of analysis. This report relates only to the samples reported above and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. Samples received in good condition unless otherwise noted.

Samples analyzed by EMSL Analytical, Inc. Carle Place, NY AIHA-LAP, LLC--EMLAP Accredited #102344

Initial report from: 06/06/2019 08:15:55

For information on the fungi listed in this report, please visit the Resources section at www.emsl.com



EMSL Analytical, Inc.

528 Mineola Avenue Carle Place, NY 11514
Tel/Fax: (516) 997-7251 / (516) 997-7528
<http://www.EMSL.com> / carleplacelab@emsl.com

EMSL Order: 061910890
Customer ID: SALU50
Customer PO:
Project ID:

Attn: Indika Jayatilake
SaLUT
1818 New York Avenue, NE
Suite 218A
Washington, DC 20002
Project: PGCPs IAQ/19-035 Cora Rice ES

Phone: (301) 595-3783
Fax: (301) 595-3787
Collected: 05/29/2019
Received: 05/30/2019
Analyzed: 06/05/2019

Test Report: Air-O-Cell™ Analysis of Fungal Spores & Particulates by Optical Microscopy (Methods MICRO-SOP-201, ASTM D7391)

Lab Sample Number:	061910890-0007			061910890-0008		
Client Sample ID:	28458482			28458552		
Volume (L):	75			Field Blank 1		
Sample Location	Outside Exterior EV Sample			Field Blank 1		
Spore Types	Raw Count	Count/m³	% of Total	Raw Count	Count/m³	% of Total
Alternaria (Ulocladium)	-	-	-	-	-	-
Ascospores	7	300	5	-	-	-
Aspergillus/Penicillium	6	300	5	-	-	-
Basidiospores	54	2400	39.7	-	-	-
Bipolaris++	-	-	-	-	-	-
Chaetomium	-	-	-	-	-	-
Cladosporium	69	3000	49.7	-	-	-
Curvularia	-	-	-	-	-	-
Epicoccum	-	-	-	-	-	-
Fusarium	-	-	-	-	-	-
Ganoderma	-	-	-	-	-	-
Myxomycetes++	-	-	-	-	-	-
Pithomyces++	-	-	-	-	-	-
Rust	-	-	-	-	-	-
Scopulariopsis/Microascus	-	-	-	-	-	-
Stachybotrys/Memnoniella	-	-	-	-	-	-
Unidentifiable Spores	-	-	-	-	-	-
Zygomycetes	-	-	-	-	-	-
Polythrincium	1	40	0.7	-	-	-
Total Fungi	137	6040	100	-	No Trace	-
Hypthal Fragment	-	-	-	-	-	-
Insect Fragment	-	-	-	-	-	-
Pollen	1	40	-	-	-	-
Analyt. Sensitivity 600x	-	44	-	-	0	-
Analyt. Sensitivity 300x	-	13*	-	-	0*	-
Skin Fragments (1-4)	-	1	-	-	-	-
Fibrous Particulate (1-4)	-	1	-	-	-	-
Background (1-5)	-	1	-	-	-	-

++ Includes other spores with similar morphology; see EMSL's fungal glossary for each specific category.


Jeffrey Lau, Microbiology Laboratory Manager
or other approved signatory

High levels of background particulate can obscure spores and other particulates leading to underestimation. Background levels of 5 indicate an overloading of background particulates, prohibiting accurate detection and quantification. Present = Spores detected on overloaded samples. Results are not blank corrected unless otherwise noted. The detection limit is equal to one fungal spore, structure, pollen, fiber particle or insect fragment. *** Denotes particles found at 300X. "-" Denotes not detected. Due to method stopping rules, raw counts in excess of 100 are extrapolated based on the percentage analyzed. EMSL maintains liability limited to cost of analysis. This report relates only to the samples reported above and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. Samples received in good condition unless otherwise noted.

Samples analyzed by EMSL Analytical, Inc. Carle Place, NY AIHA-LAP, LLC--EMLAP Accredited #102344

Initial report from: 06/06/2019 08:15:55

For information on the fungi listed in this report, please visit the Resources section at www.emsl.com



EMSL ANALYTICAL, INC.
LABORATORY PRODUCTS • TRADING

Microbiology Chain of Custody

EMSL Order Number (Lab Use Only):

061910890

PHONE:

FAX:

Company Name: SaLUT Inc.		EMSL-Bill to: <input checked="" type="checkbox"/> Same <input type="checkbox"/> Different If Bill to is Different note instructions in Comments**					
Street: 1818 New York Ave NE Suite 231		Third Party Billing requires written authorization from third party					
City: Washington	State/Province: DC	Zip/Postal Code: 20002	Country: USA				
Report To (Name): Indika Jayatilake		Telephone #: 301-595-3783					
Email Address: ijayatilake@salutinc.com		Fax #:	Purchase Order:				
Project Number/Location: PGCPS IAQ/19-035 Cora Rice ES		Please Provide Results: <input type="checkbox"/> Fax <input checked="" type="checkbox"/> Email					
Location Address: 950 Nalley Road, Landover, MD 20785		Connecticut Samples: <input type="checkbox"/> Commercial <input type="checkbox"/> Residential					
*Analysis completed in accordance with EMSL's Terms and Conditions located in the Analytical Price Guide. TATs are subject to methodology requirements							
Sterile, Sodium Thiosulfate Preserved Bottle Used: <input type="checkbox"/> Biocide Used in Source (specify): <input type="checkbox"/>							
Public Water Supply Samples: <input type="checkbox"/> Note: All results may automatically be reported to DOH if required by state.							
Turnaround Time (TAT) Options * - Please Check							
<input type="checkbox"/> 3 Hour	<input type="checkbox"/> 6 Hour	<input type="checkbox"/> 24 Hour	<input type="checkbox"/> 48 Hour <input type="checkbox"/> 72 Hour <input type="checkbox"/> 96 Hour <input checked="" type="checkbox"/> 1 Week <input type="checkbox"/> 2 Week				
Microbiology Test Codes							
M001 Air-O-Cell M030 Micro 5 M041 Fungal Direct Examination M169 Pollen ID & Enumeration M280 Dust Characterization Level-1 M281 Dust Characterization Level-2 M005 Viable Fungi- Air Samples (Genus ID & Count) M006 Viable Fungi- Air Samples (Includes <i>Penicillium</i> , <i>Aspergillus</i> , <i>Cladosporium</i> , <i>Stachybotrys</i> Species ID & Count) M007 Culturable fungi - Surface Samples (Genus ID & Count) M008 Culturable fungi - Surface Samples (Includes <i>Penicillium</i> , <i>Aspergillus</i> , <i>Cladosporium</i> , <i>Stachybotrys</i> Species ID & Count) M009 Bacteria Culture Gram Stain & Count M010 Bacteria Count & ID - 3 Most Prominent M011 Bacteria Count & ID - 5 Most Prominent M012 <i>Pseudomonas aeruginosa</i> (P/A***)	M174 MoldSnap M032 Allergenco-D M024 <i>Pseudomonas aeruginosa</i> (MFT*) M015 Heterotrophic Plate Count M017 Total Coliform & E. coli (Colilert P/A***) M018 Total Coliform & E. coli (MFT*) M114 Total Coliform & E. coli Enumeration (Colilert MPN**) M019 Fecal Coliform (MFT*) M020 Fecal Streptococcus (MFT*) M029 Enterococci (MFT*) M129 Enterococci (Enterolert P/A***) M180 Real Time qPCR-ERMI 36 Panel M025 Sewage Screen -Water (MFT*)	M115 Sewage Screen - Water (P/A***) M116 Sewage Screen - Water (MPN**) M117 Sewage Screen - Swab (P/A***) M013 Sewage Screen - Swab (MFT*) M133 Methicillin-resistant Staph. aureus (MRSA) M031 Rapid-growing non-TB Mycobacteria Detection & Enumeration M014 Endotoxin Analysis M044 Group Allergen (Cat, Dog, Cockroach, Dust Mite) Other See Analytical Price Guide Legionella Analysis Please use EMSL Legionella COC					
Name of Sampler: Jude Fonseca		Signature of Sampler:					
Sample #	Sample Location/Description	Sample Type	Potable/ NonPotable (only for waters)	Test Code	Volume/ Area	Date/Time Collected	Temperature (°C) (Lab Use Only)
28458476	Classroom L 201	Air	<input type="checkbox"/> P <input type="checkbox"/> NP	M001	75L	5/29/2019	
28458489	Classroom G 111	Air	<input type="checkbox"/> P <input type="checkbox"/> NP	M001	75L	5/29/2019	
28458514	Classroom K 111	Air	<input type="checkbox"/> P <input type="checkbox"/> NP	M001	75L	5/29/2019	
28458463	Classroom G 107	Air	<input type="checkbox"/> P <input type="checkbox"/> NP	M001	75L	5/29/2019	
28459000	Classroom G 102	Air	<input type="checkbox"/> P <input type="checkbox"/> NP	M001	75L	5/29/2019	
28458432	Classroom L 205	Air	<input type="checkbox"/> P <input type="checkbox"/> NP	M001	75L	5/29/2019	
Client Sample # (s): -		Total # of Samples: 8		Samples Received Chilled? Yes / No			
Relinquished (Client):		Date:		Time:			
Received (Lab): <i>L. Horvath, walls Jr</i>		Date: <i>5/30/19</i>		Time: <i>9:05am</i>			
Comments/Special Instructions:							

6/5/19

