



4221 Forbes Boulevard · Suite 250  
Lanham, Maryland 20706  
T: 202.558.7487 | <http://atiinc.com/>

June 18, 2019

Prince George's County Public Schools  
13300 Old Marlboro Pike  
Upper Marlboro, Maryland 20772  
Attention: Mr. Alex Baylor

RE: Indoor Air Quality Screening, High Point High School  
IFB: 022-19  
ATI Project Number: ATI19-692  
Revision 1

Dear Mr. Baylor:

Prince George's County Public Schools requested that ATI, Inc., conduct a proactive indoor air quality (IAQ) screening at High Point High School. The IAQ screening was conducted on May 31, 2019. Its key findings are enclosed in the Executive Summary on page three, and the official laboratory report for total fungal spore trap sampling is enclosed in Appendix A.

Thank you for the opportunity to provide Industrial Hygiene services for Prince George's County Public Schools. If you have any questions regarding this report, please contact us at (202) 643-4283.

Sincerely,  
**ATI, INC.**

---

Courtney E. McCall  
Project Manager

---

Sarath Seneviratne  
CIH, CSP, CHMM

# Indoor Air Quality Screening Report



Prince George's County Public Schools  
High Point High School  
3601 Powder Mill Road  
Beltsville, Maryland 20705

Prepared for:

Prince George's County Public Schools  
13300 Old Marlboro Pike  
Upper Marlboro, Maryland 20772

**June 18, 2019**

**Rev. 1**

Submitted by:

The logo for ATI, consisting of the lowercase letters "ati" in a bold, blue, sans-serif font.

ATI Job # 19-692

Intentionally Blank

**Table of Contents**

1. Executive Summary and Key Findings ..... 3

2. Assessment Methods..... 3

3. Visual Observations ..... 4

4. Thermal Environmental Conditions for Human Occupancy ..... 6

    4.1 Temperature..... 6

    4.2 Relative Humidity ..... 7

    4.3 Carbon Dioxide ..... 7

    4.4 Carbon Monoxide..... 8

5. Total Fungal Air Sampling Results..... 9

6. Summary of Findings..... 10

  

Table 1: Visual Observations and Sampling Locations ..... 4

Table 2: Temperature Measurements..... 6

Table 3: Relative Humidity Measurements ..... 7

Table 4: Carbon Dioxide Measurements ..... 8

Table 5: Carbon Monoxide Measurements ..... 8

Appendix A: Laboratory Report and Chain of Custody  
Appendix B: Instrument Calibration Records



### Abbreviations and Acronyms

<b>AHU</b>	Air-Handling Unit
<b>AIHA</b>	American Industrial Hygiene Association
<b>ASHRAE</b>	American Society of Heating, Refrigerating and Air-Conditioning Engineers
<b>ASTM</b>	American Society for Testing and Materials
<b>CO</b>	Carbon Monoxide
<b>CO<sub>2</sub></b>	Carbon Dioxide
<b>EMLAP</b>	Environmental Microbiology Laboratory Accreditation Program
<b>HVAC</b>	Heating, Ventilating, And Air-Conditioning
<b>IAQ</b>	Indoor Air Quality
<b>NIST</b>	National Institute for Standards and Technology
<b>NVLAP</b>	National Voluntary Laboratory Accreditation Program
<b>RH</b>	Relative Humidity
<b>Rev.</b>	Revision

#### Abbreviations involving scientific volume and measurements involving media or water sampling

<b>Counts/m<sup>3</sup></b>	Mold spores per cubic meter of air
<b>LPM</b>	Liters Per Minute
<b>NTE</b>	Not to exceed
<b>°F</b>	degree Fahrenheit
<b>PPM</b>	Parts Per Million

## 1. Executive Summary and Key Findings

---

ATI conducted a proactive Indoor Air Quality (IAQ) screening on May 31, 2019, at High Point High School, located at 3601 Powder Mill Road, Beltsville, MD 20705.

The screening included a visual assessment of randomly selected classrooms and other frequently occupied spaces, such as the cafeteria, the main office, and classrooms, for potential IAQ contributors and pathways. As part of the screening, ATI collected direct reading measurements for comfort parameters, including temperature, relative humidity, carbon dioxide, and carbon monoxide. Also, ATI collected total fungal air samples on spore trap cassettes for microbiological analysis.

The following is a summary of the key findings from this screening:

1. Three locations exceeded the ASHRAE summer temperature guidelines and four fell below the recommended range, which is 73-79°F.
2. Relative humidity measurements were within ASHRAE guidelines, except in one location that exceeded 65%.
3. Three tested locations exceeded the ASHRAE limit for carbon dioxide, which was 1,032 parts per million (PPM).
4. Carbon monoxide was not detected throughout the tested spaces.
5. Total concentrations detected in each tested space did not exceed the spore counts detected outdoors, 46,960 counts/m<sup>3</sup>. In two indoor areas, Cladosporium was found slightly elevated over the outdoor sample but not at a level to pose a concern. Ascospores and Basidiospores detected indoors did not exceed the outside sample, which is favorable. Aspergillus/Penicillium was detected indoors at low concentrations and was not detected outdoors. Although Aspergillus/Penicillium is known to cause allergies, the low concentration detected indoors does not pose a concern.

## 2. Assessment Methods

---

Ms. Mikal Frater of ATI, Inc. conducted a visual assessment and air sampling on May 31, 2019. Sampled rooms were randomly selected and accounted for approximately 10% of classrooms or a minimum of five samples. Visual observations were made at the time the samples were collected. ATI references the American Society of Heating, Refrigerating, and Air-Conditioning Engineers (ASHRAE) *Standard 62.1 – 2016* and *ASHRAE Standard 55 – 2017* when providing IAQ services to clients. ASHRAE is an industry leader on energy efficiency and indoor air quality.

All measurements and air samples were collected between three-six feet from floor elevation, which represents the breathing zone, and away from air-supply and return diffusers. Real-time direct readings for temperature, relative humidity, carbon dioxide (CO<sub>2</sub>), and carbon monoxide (CO), were obtained with a calibrated TSI Q-Trak 7575-X Meter and attached 982 Probe.

Total fungal air samples were collected with a Buck BioAire High-Volume Sampling Pump on Zefon Air-O-Cell spore-trap cassettes at a flow rate of 15 liters per minute for five minutes, for a sample volume of 75 liters. The samples were analyzed by direct microscopic examination (identifies and counts both viable and

non-viable spores, which is then considered “total fungal”), via the American Society for Testing and Materials (ASTM) Standard D7391-09 by EMSL Analytical, Inc., (EMSL) located in Beltsville, MD.

EMSL participates in the National Institute of Standards and Technology’s (NIST’s) National Voluntary Laboratory Accreditation Program (NVLAP) for general laboratory performance and management and the American Industrial Hygiene Association (AIHA) Environmental Microbial Laboratory Accreditation Program (EMLAP, Certificate Number 102891).

Instrument calibration records are included in Appendix B of this report.

**3. Visual Observations**

**Table 1: Visual Observations and Sampling Locations**

Sample Location	Observations
Outside	<ul style="list-style-type: none"> <li>• Moderate traffic on adjacent road.</li> <li>• Parking lot surrounded by trees.</li> <li>• Light winds.</li> <li>• Sunny, clear skies.</li> <li>• Garbage truck drove into parking lot during sampling.</li> </ul>
Main Office	<ul style="list-style-type: none"> <li>• Three occupants.</li> <li>• Light foot traffic.</li> <li>• Five plants scattered around room.</li> <li>• Stacks of boxes in area, no dust accumulation.</li> <li>• Office space splits into additional rooms.</li> <li>• Two air returns, one air diffuser.</li> <li>• Two portions of the school each built around 1958 and 1975.</li> <li>• Space is approximately 790 ft.<sup>2</sup></li> </ul>
Auditorium	<ul style="list-style-type: none"> <li>• Nine air diffusers, nine air returns.</li> <li>• Diffusers have light dirt load.</li> <li>• Large occupied area, approximately 6,240 ft.<sup>2</sup></li> <li>• Fifty occupants scattered around auditorium.</li> <li>• Door to corridor is open.</li> <li>• Light to moderate foot traffic.</li> </ul>
Gymnasium	<ul style="list-style-type: none"> <li>• Two air returns, 12 air diffusers.</li> <li>• 62 occupants scattered around area.</li> <li>• Door to corridor open.</li> <li>• Four fans that let in outside air are OFF.</li> <li>• Children are moving around.</li> <li>• Space is approximately 9,357 ft.<sup>2</sup></li> </ul>
Cafeteria	<ul style="list-style-type: none"> <li>• Four air returns, 24 air diffusers.</li> <li>• Large occupied area.</li> <li>• Two cafeterias “separated” by pillars. Samples taken between both sides.</li> <li>• Four occupants scattered around room.</li> </ul>

Sample Location	Observations
	<ul style="list-style-type: none"> <li>• Five wall units.</li> </ul>
Room 125	<ul style="list-style-type: none"> <li>• Window open.</li> <li>• A/C off – not working.</li> <li>• Wall unit fan ON.</li> <li>• Three occupants in area.</li> <li>• Individual oscillating fan OFF – heavy dirt load.</li> <li>• Light brown stain on ceiling tile near wall unit.</li> <li>• Space is approximately 772 ft.<sup>2</sup></li> </ul>
Room 237	<ul style="list-style-type: none"> <li>• 22 occupants in area.</li> <li>• A/C on and window open.</li> <li>• Stacks of books and boxes in room.</li> <li>• Wall unit in room.</li> <li>• Stacks of paper near wall unit.</li> <li>• Space is approximately 849 ft.<sup>2</sup></li> </ul>
Room 216	<ul style="list-style-type: none"> <li>• 12 occupants in area during sampling.</li> <li>• Concrete ceiling.</li> <li>• Door to corridor open.</li> <li>• Thermostat controlled by teacher.</li> <li>• Daikin ceiling unit x2</li> <li>• Space is approximately 755 ft.<sup>2</sup></li> </ul>
Room 200	<ul style="list-style-type: none"> <li>• A/C unit OFF.</li> <li>• 32 occupants in room during sampling.</li> <li>• Friedrich A/C unit.</li> <li>• Daikan ceiling unit cracked and held together by rope – hazard.</li> <li>• Crowded/cluttered classroom</li> <li>• Printer about 5-6 ft. from sampling area.</li> </ul>
Room 308	<ul style="list-style-type: none"> <li>• Four air returns, eight air diffusers.</li> <li>• Four large windows open.</li> <li>• 22 occupants in area during sampling.</li> <li>• Five large plants in area.</li> <li>• No stained ceiling tiles or growth visible.</li> <li>• Space is approximately 1,104 ft.<sup>2</sup></li> </ul>
Room 324	<ul style="list-style-type: none"> <li>• One wall unit.</li> <li>• Individual oscillating fan ON.</li> <li>• Two windows open during sampling.</li> <li>• A/C ON.</li> <li>• Three occupants in sampling area.</li> <li>• Space is approximately 1,957 ft.<sup>2</sup></li> </ul>
Room 22	<ul style="list-style-type: none"> <li>• Two air returns, one air diffuser.</li> <li>• Missing ceiling tile in one corner of room.</li> <li>• Three fish tanks in room.</li> <li>• One dry, dead plant in corner of room.</li> </ul>



Sample Location	Observations
	<ul style="list-style-type: none"> <li>Brown stain on ceiling tile by window with noticeable growth. Smaller light brown stain in isolated area.</li> <li>Printer about 12 ft. from sampling area.</li> <li>Space is approximately 1,479 ft.<sup>2</sup></li> </ul>

#### 4. Thermal Environmental Conditions for Human Occupancy

ASHRAE Standard 55-2017, *Thermal Environmental Conditions for Human Occupancy*, addresses thermal comfort in an office environment, which means that an employee wearing a normal amount of clothing feels neither too cold nor too warm. This standard discusses thermal comfort within the context of air temperature, humidity, and air movement and provides recommended ranges for temperature and humidity that are intended to satisfy most building occupants. The recommended ASHRAE ranges are referenced below by each comfort parameter.

##### 4.1 Temperature

The ASHRAE standard establishes a winter comfort range of between 68°F and 75°F and a summer range of between 73°F and 79°F. The temperature measurements obtained during the May 31, 2019, screening are summarized in Table 2. As indicated by the data in the table, temperatures in the school averaged between 68.4 – 82.5°F. Of the 11 tested rooms, three exceeded the ASHRAE summer comfort range and four were below the recommended range.

Table 2: Temperature Measurements

Sample Location	May 31, 2019 °F			ASHRAE Standard °F
	Min	Max	Average	
Outside	73.8	74.6	74.2	N/A
<b>Indoors</b>				
Main Office	71.4	71.4	71.4	73 – 79
Auditorium	68.2	68.6	68.4	73 – 79
Gymnasium	76.3	76.5	76.4	73 – 79
Cafeteria	71.4	72.6	72.0	73 – 79
Room 125	78.9	79.9	79.4	73 – 79
Room 237	72.5	74.5	73.5	73 – 79
Room 216	71.4	71.4	71.4	73 – 79
Room 200	73.6	73.6	73.6	73 – 79
Room 308	77.8	79.8	78.8	73 – 79
Room 324	82.0	82.8	82.4	73 – 79
Room 22	82.4	82.6	82.5	73 – 79

## 4.2 Relative Humidity

Relative humidity is a key factor for mold growth. Mold has the potential of growing on suitable surfaces with humidity levels above 65%. ASHRAE *Standard 62.1-2016, Ventilation for Acceptable Indoor Air Quality*, recommends a maximum indoor relative humidity of 65% to prevent condensation of moisture on surfaces. Relative humidity below 30% may result in drying of the mucous membranes and skin. Relative humidity measurements are summarized in Table 3. As indicated by the data in the table, relative humidity measurements averaged between 48.25% and 65.5%, with one location, the cafeteria, exceeding the ASHRAE maximum recommendation of 65% relative humidity.

**Table 3: Relative Humidity Measurements**

Sample Location	May 31, 2019 (%)			ASHRAE Standard (% RH)
	Min	Max	Average	
Outside	52.4	55.6	54.0	N/A
<b>Inside</b>				
Main Office	55.0	55.6	55.3	< 65
Auditorium	50.2	51.0	50.6	< 65
Gymnasium	60.2	60.6	60.4	< 65
Cafeteria	64.6	66.4	65.5	< 65
Room 125	53.2	55.0	54.1	< 65
Room 237	59.2	62.7	60.95	< 65
Room 216	51.8	52.8	52.3	< 65
Room 200	55.2	55.2	55.2	< 65
Room 308	50.1	50.1	50.1	< 65
Room 324	47.5	49.0	48.25	< 65
Room 22	56.3	56.7	56.5	< 65

## 4.3 Carbon Dioxide

Carbon dioxide measurements within an occupied building are a standard method used to gauge the efficiency of ventilation systems. Carbon dioxide is a by-product of human respiration and does not pose an acute health hazard alone. Elevated concentrations may suggest that insufficient fresh air is being supplied to an occupied space and/or that the ventilation system does not provide a sufficient rate of air exchange.

Research has indicated that buildings with adequately operating ventilation systems are able to remove odors generated by activities in an indoor office environment efficiently. ASHRAE *Standard 62.1-2016* states that comfort (odor) criteria with respect to human bioeffluents are likely to be satisfied if the ventilation results indoor carbon dioxide concentrations are less than 700 parts per million (ppm) above the outdoor air concentration.

Carbon dioxide measurements are summarized in Table 4. On the day of the screening, the average outdoor carbon dioxide concentration obtained was 332 ppm, which calculates to a maximum indoor concentration of 1,032 ppm (700 + 332). The carbon dioxide levels inside the school ranged from the average minimum

detected, 308 ppm to 1,601 ppm, the average maximum detected, with three locations, Room 22, Room 200 and Room 216, exceeding the ASHRAE maximum recommended concentration of 1,032 ppm.

**Table 4: Carbon Dioxide Measurements**

Sample Location	May 31, 2019 Concentration (parts per million)			ASHRAE Standard (ppm) NTE
	Min	Max	Average	
Outside	321	343	332	N/A
<b>Inside</b>				
Main Office	640	644	642	1,032
Auditorium	352	368	360	1,032
Gymnasium	413	421	417	1,032
Cafeteria	307	309	308	1,032
Room 125	462	468	465	1,032
Room 237	893	915	904	1,032
Room 216	1,044	1,056	1,050	1,032
Room 200	1,335	1,335	1,335	1,032
Room 308	402	424	413	1,032
Room 324	430	432	431	1,032
Room 22	1,568	1,634	1,601	1,032

**4.4 Carbon Monoxide**

Carbon monoxide is a colorless and odorless gas produced by the incomplete combustion of carbon containing fuels. Oil, gasoline, diesel fuels, wood, coke, and coal are the major sources of carbon monoxide. ASHRAE recommends that carbon monoxide not exceed nine ppm indoors. As indicated by the data in Table 5, carbon monoxide was not detected throughout the school.

**Table 5: Carbon Monoxide Measurements**

Sample Location	May 31, 2019 Concentration (parts per million)			ASHRAE Standard (ppm)
	Min	Max	Average	
Outside	0	0	0	N/A
<b>Inside</b>				
Main Office	0	0	0	< 9
Auditorium	0	0	0	< 9
Gymnasium	0	0	0	< 9
Cafeteria	0	0	0	< 9
Room 125	0	0	0	< 9
Room 237	0	0	0	< 9
Room 216	0	0	0	< 9
Room 200	0	0	0	< 9



Sample Location	May 31, 2019 Concentration (parts per million)			ASHRAE Standard (ppm)
	Min	Max	Average	
Room 308	0	0	0	< 9
Room 324	0	0	0	< 9
Room 22	0	0	0	< 9

## 5. Total Fungal Air Sampling Results

Mold needs a food source, moisture, proper temperature and humidity, and at times, a source of light, to grow in an environment. Air infiltration through building entrances and exits, open windows and loading docks, and foot traffic into buildings, including the HVAC system all serve as primary pathways that can carry fungi indoors. Water leaks and humid conditions inside of buildings provide the moisture that fosters mold growth. The May 31, 2019 mold screening sampled air using spore trap cassettes in randomly selected classrooms and other areas throughout the facility. These cassettes collect both viable spores, those capable of producing more fungal colonies, and non-viable spores, which cannot reproduce. Based upon recognized industry practices, indoor mold concentrations are compared with those detected outdoors, which are also known as ambient or baseline samples.

In normal circumstances, the diversity of spores identified indoors and outdoors should be similar with some exceptions. The high concentration of one or two species of fungal spores identified indoors and the absence of the same species outdoors can indicate a moisture problem with the potential to degrade the air quality. Fungi species present indoors are typically found at levels ranging from approximately 10-50% of their levels in the outdoor air, reflecting the filtering by the building's HVAC system.

The official laboratory report with spore trap samples collected on May 31, 2019, is presented in Appendix A. Total concentrations detected in each tested space did not exceed the spore counts detected outdoors, 46,960 counts/m<sup>3</sup>.

Ascospores, Basidiospores and Cladosporium had the highest concentrations indoors and are spores commonly found indoors. Each are known to cause allergies yet are not associated with water damaged materials in buildings. In two indoor areas, Cladosporium was found slightly elevated over the outdoor sample but not at a level to pose a concern. Ascospores and Basidiospores detected indoors did not exceed the outside sample, which is favorable.

Aspergillus/Penicillium was detected indoors at low concentrations and was not detected outdoors. Although Aspergillus/Penicillium is known to cause allergies, the low concentration detected indoors does not pose a concern.

Low concentrations of other spores, such as Cercospora, were also detected indoors but not outdoors. These low concentrations do not indicate noteworthy indoor amplification and do not pose a concern.

## 6. Summary of Findings

---

Three locations exceeded the ASHRAE summer temperature guidelines and four fell below the recommended range, which is 73-79°F. Relative humidity measurements were within ASHRAE guidelines, except in one location that exceeded 65%. Three tested locations exceeded the ASHRAE limit for carbon dioxide, which was 1,032 parts per million (PPM). Carbon monoxide was not detected throughout the tested spaces.

Total concentrations detected in each tested space did not exceed the spore counts detected outdoors, 46,960 counts/m<sup>3</sup>. In two indoor areas, Cladosporium was found slightly elevated over the outdoor sample but not at a level to pose a concern. Ascospores and Basidiospores detected indoors did not exceed the outside sample, which is favorable. Aspergillus/Penicillium was detected indoors at low concentrations and was not detected outdoors. Although Aspergillus/Penicillium is known to cause allergies, the low concentration detected indoors does not pose a concern.

We appreciate the opportunity to provide these IAQ testing services for you. If you have any questions, please contact us at (202) 643-4283.

Sincerely,  
**ATI, INC.**



---

Courtney E. McCall  
Project Manager



---

Sarath Seneviratne  
CIH, CSP, CHMM

**Appendix A:  
Laboratory Report and Chain of Custody**



# EMSL Analytical, Inc.

10768 Baltimore Avenue Beltsville, MD 20705

Tel/Fax: (301) 937-5700 / (301) 937-5701

<http://www.EMSL.com> / [beltsvillelab@emsl.com](mailto:beltsvillelab@emsl.com)

EMSL Order: 191906344

Customer ID: ATII25A

Customer PO:

Project ID:

**Attn:** Courtney McCall

ATI

4221 Forbes Blvd

Suite 250

Lanham, MD 20706

**Project:** 19-692- PGCPs -HIGH POINT HIGH SCHOOL

**Phone:** (202) 832-1433

**Fax:**

**Collected:** 05/31/2019

**Received:** 06/04/2019

**Analyzed:** 06/05/2019 - 06/08/2019

### Test Report: Air-O-Cell™ Analysis of Fungal Spores & Particulates by Optical Microscopy (Methods MICRO-SOP-201, ASTM D7391)

Lab Sample Number: Client Sample ID: Volume (L): Sample Location	191906344-0001 19-692-01 75 OUTSIDE PARKING LOT			191906344-0002 19-692-02 FIELD BLANK			191906344-0003 19-692-03 75 MAIN OFFICE		
Spore Types	Raw Count	Count/m³	% of Total	Raw Count	Count/m³	% of Total	Raw Count	Count/m³	% of Total
Alternaria (Ulocladium)	-	-	-	-	-	-	-	-	-
Ascospores	259	10600	22.6	-	-	-	33	1400	22
Aspergillus/Penicillium	-	-	-	-	-	-	-	-	-
Basidiospores	870	35700	76	-	-	-	120	4920	77.4
Bipolaris++	-	-	-	-	-	-	-	-	-
Chaetomium	-	-	-	-	-	-	-	-	-
Cladosporium	14	570	1.2	-	-	-	1	40	0.6
Curvularia	-	-	-	-	-	-	-	-	-
Epicoccum	-	-	-	-	-	-	-	-	-
Fusarium	-	-	-	-	-	-	-	-	-
Ganoderma	1	40	0.1	-	-	-	-	-	-
Myxomycetes++	1*	10*	0	-	-	-	-	-	-
Pithomyces++	-	-	-	-	-	-	-	-	-
Rust	-	-	-	-	-	-	-	-	-
Scopulariopsis/Microascus	-	-	-	-	-	-	-	-	-
Stachybotrys/Memnoniella	-	-	-	-	-	-	-	-	-
Unidentifiable Spores	-	-	-	-	-	-	-	-	-
Zygomycetes	-	-	-	-	-	-	-	-	-
Cercospora++	-	-	-	-	-	-	-	-	-
Gonatobotryum	-	-	-	-	-	-	-	-	-
Polythrincium	1	40	0.1	-	-	-	-	-	-
Zygothia/Schizothyrrium	-	-	-	-	-	-	-	-	-
<b>Total Fungi</b>	<b>1146</b>	<b>46960</b>	<b>100</b>	-	<b>No Trace</b>	-	<b>154</b>	<b>6360</b>	<b>100</b>
Hypal Fragment	-	-	-	-	-	-	-	-	-
Insect Fragment	2*	30*	-	-	-	-	-	-	-
Pollen	1*	10*	-	-	-	-	-	-	-
Analyt. Sensitivity 600x	-	41	-	-	0	-	-	41	-
Analyt. Sensitivity 300x	-	13*	-	-	0*	-	-	13*	-
Skin Fragments (1-4)	-	1	-	-	-	-	-	2	-
Fibrous Particulate (1-4)	-	1	-	-	-	-	-	1	-
Background (1-5)	-	1	-	-	-	-	-	1	-

++ Includes other spores with similar morphology; see EMSL's fungal glossary for each specific category.

Stefanie Schneider, Microbiology Laboratory Manager  
or other approved signatory

High levels of background particulate can obscure spores and other particulates leading to underestimation. Background levels of 5 indicate an overloading of background particulates, prohibiting accurate detection and quantification. Present = Spores detected on overloaded samples. Results are not blank corrected unless otherwise noted. The detection limit is equal to one fungal spore, structure, pollen, fiber particle or insect fragment. \*\*\* Denotes particles found at 300X. \* Denotes not detected. Due to method stopping rules, raw counts in excess of 100 are extrapolated based on the percentage analyzed. EMSL maintains liability limited to cost of analysis. This report relates only to the samples reported above and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. Samples received in good condition unless otherwise noted.

Samples analyzed by EMSL Analytical, Inc. Beltsville, MD AIHA-LAP, LLC -EMLAP Accredited #102891

Initial report from: 06/10/2019 13:48:25

For information on the fungi listed in this report, please visit the Resources section at [www.emsl.com](http://www.emsl.com)



# EMSL Analytical, Inc.

10768 Baltimore Avenue Beltsville, MD 20705

Tel/Fax: (301) 937-5700 / (301) 937-5701

<http://www.EMSL.com> / [beltsvillelab@emsl.com](mailto:beltsvillelab@emsl.com)

<b>EMSL Order:</b> 191906344
<b>Customer ID:</b> ATII25A
<b>Customer PO:</b>
<b>Project ID:</b>

<b>Attn:</b> Courtney McCall ATI 4221 Forbes Blvd Suite 250 Lanham, MD 20706	<b>Phone:</b> (202) 832-1433 <b>Fax:</b> <b>Collected:</b> 05/31/2019 <b>Received:</b> 06/04/2019 <b>Analyzed:</b> 06/05/2019 - 06/08/2019
<b>Project:</b> 19-692- PGCPs -HIGH POINT HIGH SCHOOL	

### Test Report: Air-O-Cell™ Analysis of Fungal Spores & Particulates by Optical Microscopy (Methods MICRO-SOP-201, ASTM D7391)

Lab Sample Number: Client Sample ID: Volume (L): Sample Location	191906344-0004 19-692-04 75 AUDITORIUM			191906344-0005 19-692-05 75 GYM			191906344-0006 19-692-06 75 CAFETERIA		
	Raw Count	Count/m³	% of Total	Raw Count	Count/m³	% of Total	Raw Count	Count/m³	% of Total
Spore Types									
Alternaria (Ulocladium)	-	-	-	-	-	-	-	-	-
Ascospores	6	200	36.4	143	5870	18.2	9	400	35.7
Aspergillus/Penicillium	-	-	-	-	-	-	-	-	-
Basidiospores	7	300	54.5	630	25800	79.9	15	620	55.4
Bipolaris++	-	-	-	1	40	0.1	-	-	-
Chaetomium	-	-	-	-	-	-	-	-	-
Cladosporium	-	-	-	9	400	1.2	3	100	8.9
Curvularia	1*	10*	1.8	1	40	0.1	-	-	-
Epicoccum	-	-	-	-	-	-	-	-	-
Fusarium	-	-	-	-	-	-	-	-	-
Ganoderma	-	-	-	1	40	0.1	-	-	-
Myxomycetes++	1	40	7.3	1	40	0.1	-	-	-
Pithomyces++	-	-	-	-	-	-	-	-	-
Rust	-	-	-	-	-	-	-	-	-
Scopulariopsis/Microascus	-	-	-	-	-	-	-	-	-
Stachybotrys/Memnoniella	-	-	-	-	-	-	-	-	-
Unidentifiable Spores	-	-	-	-	-	-	-	-	-
Zygomycetes	-	-	-	-	-	-	-	-	-
Cercospora++	-	-	-	1	40	0.1	-	-	-
Gonatobotryum	-	-	-	1	40	0.1	-	-	-
Polythrincium	-	-	-	-	-	-	-	-	-
Zygothia/Schizothyrium	-	-	-	-	-	-	-	-	-
<b>Total Fungi</b>	<b>15</b>	<b>550</b>	<b>100</b>	<b>788</b>	<b>32310</b>	<b>100</b>	<b>27</b>	<b>1120</b>	<b>100</b>
Hyphal Fragment	3*	40*	-	1	40	-	-	-	-
Insect Fragment	1	40	-	1	40	-	-	-	-
Pollen	1	40	-	4	200	-	-	-	-
Analyt. Sensitivity 600x	-	41	-	-	41	-	-	41	-
Analyt. Sensitivity 300x	-	13*	-	-	13*	-	-	13*	-
Skin Fragments (1-4)	-	3	-	-	3	-	-	1	-
Fibrous Particulate (1-4)	-	1	-	-	1	-	-	1	-
Background (1-5)	-	2	-	-	3	-	-	1	-

++ Includes other spores with similar morphology; see EMSL's fungal glossary for each specific category.

*Stefanie Schneider*  
 Stefanie Schneider, Microbiology Laboratory Manager  
 or other approved signatory

High levels of background particulate can obscure spores and other particulates leading to underestimation. Background levels of 5 indicate an overloading of background particulates, prohibiting accurate detection and quantification. Present = Spores detected on overloaded samples. Results are not blank corrected unless otherwise noted. The detection limit is equal to one fungal spore, structure, pollen, fiber particle or insect fragment. \*\*\* Denotes particles found at 300X. "-" Denotes not detected. Due to method stopping rules, raw counts in excess of 100 are extrapolated based on the percentage analyzed. EMSL maintains liability limited to cost of analysis. This report relates only to the samples reported above and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. Samples received in good condition unless otherwise noted.

Samples analyzed by EMSL Analytical, Inc. Beltsville, MD AIHA-LAP, LLC --EMLAP Accredited #102891

Initial report from: 06/10/2019 13:48:25

For information on the fungi listed in this report, please visit the Resources section at [www.emsl.com](http://www.emsl.com)





# EMSL Analytical, Inc.

10768 Baltimore Avenue Beltsville, MD 20705

Tel/Fax: (301) 937-5700 / (301) 937-5701

<http://www.EMSL.com> / [beltsvillelab@emsl.com](mailto:beltsvillelab@emsl.com)

EMSL Order: 191906344

Customer ID: ATII25A

Customer PO:

Project ID:

**Attn:** Courtney McCall

ATI

4221 Forbes Blvd

Suite 250

Lanham, MD 20706

**Project:** 19-692- PGCPs -HIGH POINT HIGH SCHOOL

**Phone:** (202) 832-1433

**Fax:**

**Collected:** 05/31/2019

**Received:** 06/04/2019

**Analyzed:** 06/05/2019 - 06/08/2019

### Test Report: Air-O-Cell™ Analysis of Fungal Spores & Particulates by Optical Microscopy (Methods MICRO-SOP-201, ASTM D7391)

Lab Sample Number: Client Sample ID: Volume (L): Sample Location	191906344-0007 19-692-07 75 ROOM 125			191906344-0008 19-692-08 75 ROOM 237			191906344-0009 19-692-09 75 ROOM 216			
	Spore Types	Raw Count	Count/m <sup>3</sup>	% of Total	Raw Count	Count/m <sup>3</sup>	% of Total	Raw Count	Count/m <sup>3</sup>	% of Total
Alternaria (Ulocladium)	-	-	-	-	-	-	-	-	-	-
Ascospores	97	4000	23.8	83	3400	29.3	34	1400	25.8	
Aspergillus/Penicillium	-	-	-	1	40	0.3	-	-	-	
Basidiospores	300	12300	73.1	177	7260	62.5	96	3900	72	
Bipolaris++	-	-	-	-	-	-	-	-	-	
Chaetomium	-	-	-	-	-	-	-	-	-	
Cladosporium	12	490	2.9	21	860	7.4	1	40	0.7	
Curvularia	-	-	-	-	-	-	-	-	-	
Epicoccum	-	-	-	-	-	-	-	-	-	
Fusarium	-	-	-	-	-	-	-	-	-	
Ganoderma	-	-	-	-	-	-	-	-	-	
Myxomycetes++	-	-	-	-	-	-	2	80	1.5	
Pithomyces++	-	-	-	1*	10*	0.1	-	-	-	
Rust	-	-	-	1*	10*	0.1	-	-	-	
Scopulariopsis/Microascus	-	-	-	-	-	-	-	-	-	
Stachybotrys/Memnoniella	-	-	-	-	-	-	-	-	-	
Unidentifiable Spores	-	-	-	-	-	-	-	-	-	
Zygomycetes	-	-	-	-	-	-	-	-	-	
Cercospora++	-	-	-	-	-	-	-	-	-	
Gonatobotryum	-	-	-	-	-	-	-	-	-	
Polythrincium	3*	40*	0.2	1	40	0.3	-	-	-	
Zygothia/Schizothyrium	-	-	-	-	-	-	-	-	-	
<b>Total Fungi</b>	<b>412</b>	<b>16830</b>	<b>100</b>	<b>285</b>	<b>11620</b>	<b>100</b>	<b>133</b>	<b>5420</b>	<b>100</b>	
Hyphal Fragment	-	-	-	-	-	-	-	-	-	
Insect Fragment	1	40	-	4	200	-	-	-	-	
Pollen	1	40	-	1*	10*	-	-	-	-	
Analyt. Sensitivity 600x	-	41	-	-	41	-	-	41	-	
Analyt. Sensitivity 300x	-	13*	-	-	13*	-	-	13*	-	
Skin Fragments (1-4)	-	1	-	-	4	-	-	2	-	
Fibrous Particulate (1-4)	-	1	-	-	1	-	-	1	-	
Background (1-5)	-	1	-	-	2	-	-	1	-	

++ Includes other spores with similar morphology; see EMSL's fungal glossary for each specific category.

Stefanie Schneider, Microbiology Laboratory Manager  
or other approved signatory

High levels of background particulate can obscure spores and other particulates leading to underestimation. Background levels of 5 indicate an overloading of background particulates, prohibiting accurate detection and quantification. Present = Spores detected on overloaded samples. Results are not blank corrected unless otherwise noted. The detection limit is equal to one fungal spore, structure, pollen, fiber particle or insect fragment. \*\*\* Denotes particles found at 300X. "-" Denotes not detected. Due to method stopping rules, raw counts in excess of 100 are extrapolated based on the percentage analyzed. EMSL maintains liability limited to cost of analysis. This report relates only to the samples reported above and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. Samples received in good condition unless otherwise noted.

Samples analyzed by EMSL Analytical, Inc. Beltsville, MD AIHA-LAP, LLC --EMLAP Accredited #102891

Initial report from: 06/10/2019 13:48:25

For information on the fungi listed in this report, please visit the Resources section at [www.emsl.com](http://www.emsl.com)



# EMSL Analytical, Inc.

10768 Baltimore Avenue Beltsville, MD 20705

Tel/Fax: (301) 937-5700 / (301) 937-5701

<http://www.EMSL.com> / [beltsvillelab@emsl.com](mailto:beltsvillelab@emsl.com)

EMSL Order: 191906344

Customer ID: ATII25A

Customer PO:

Project ID:

**Attn:** Courtney McCall

ATI

4221 Forbes Blvd

Suite 250

Lanham, MD 20706

**Project:** 19-692- PGCPs -HIGH POINT HIGH SCHOOL

**Phone:** (202) 832-1433

**Fax:**

**Collected:** 05/31/2019

**Received:** 06/04/2019

**Analyzed:** 06/05/2019 - 06/08/2019

### Test Report: Air-O-Cell™ Analysis of Fungal Spores & Particulates by Optical Microscopy (Methods MICRO-SOP-201, ASTM D7391)

Lab Sample Number: Client Sample ID: Volume (L): Sample Location	191906344-0010 19-692-10 75 ROOM 200			191906344-0011 19-692-11 75 ROOM 308			191906344-0012 19-692-12 75 ROOM 324			
	Spore Types	Raw Count	Count/m <sup>3</sup>	% of Total	Raw Count	Count/m <sup>3</sup>	% of Total	Raw Count	Count/m <sup>3</sup>	% of Total
Alternaria (Ulocladium)	-	-	-	-	-	-	-	-	-	-
Ascospores	50	2100	26.2	126	5170	26.9	74	3000	30.4	
Aspergillus/Penicillium	2	80	1	1	40	0.2	1	40	0.4	
Basidiospores	139	5700	71.1	318	13000	67.7	155	6360	64.5	
Bipolaris++	-	-	-	-	-	-	-	-	-	-
Chaetomium	-	-	-	-	-	-	-	-	-	-
Cladosporium	3	100	1.2	21	860	4.5	9	400	4.1	
Curvularia	-	-	-	-	-	-	-	-	-	-
Epicoccum	-	-	-	1	40	0.2	-	-	-	-
Fusarium	-	-	-	-	-	-	-	-	-	-
Ganoderma	1	40	0.5	1	40	0.2	1	40	0.4	
Myxomycetes++	-	-	-	-	-	-	1*	10*	0.1	
Pithomyces++	-	-	-	-	-	-	-	-	-	-
Rust	-	-	-	-	-	-	-	-	-	-
Scopulariopsis/Microascus	-	-	-	-	-	-	-	-	-	-
Stachybotrys/Memnoniella	-	-	-	-	-	-	-	-	-	-
Unidentifiable Spores	-	-	-	-	-	-	-	-	-	-
Zygomycetes	-	-	-	-	-	-	-	-	-	-
Cercospora++	-	-	-	1*	10*	0.1	-	-	-	-
Gonatobotryum	-	-	-	-	-	-	-	-	-	-
Polythrincium	-	-	-	1*	10*	0.1	1*	10*	0.1	
Zygothia/Schizothyrium	-	-	-	1	40	0.2	-	-	-	-
<b>Total Fungi</b>	<b>195</b>	<b>8020</b>	<b>100</b>	<b>471</b>	<b>19210</b>	<b>100</b>	<b>242</b>	<b>9860</b>	<b>100</b>	
Hyphal Fragment	-	-	-	2	80	-	-	-	-	-
Insect Fragment	3	100	-	1	40	-	1*	10*	-	-
Pollen	-	-	-	1*	10*	-	-	-	-	-
Analyt. Sensitivity 600x	-	41	-	-	41	-	-	41	-	-
Analyt. Sensitivity 300x	-	13*	-	-	13*	-	-	13*	-	-
Skin Fragments (1-4)	-	3	-	-	1	-	-	1	-	-
Fibrous Particulate (1-4)	-	1	-	-	1	-	-	1	-	-
Background (1-5)	-	1	-	-	1	-	-	1	-	-

++ Includes other spores with similar morphology; see EMSL's fungal glossary for each specific category.

Stefanie Schneider, Microbiology Laboratory Manager  
or other approved signatory

High levels of background particulate can obscure spores and other particulates leading to underestimation. Background levels of 5 indicate an overloading of background particulates, prohibiting accurate detection and quantification. Present = Spores detected on overloaded samples. Results are not blank corrected unless otherwise noted. The detection limit is equal to one fungal spore, structure, pollen, fiber particle or insect fragment. \*\*\* Denotes particles found at 300X. "-" Denotes not detected. Due to method stopping rules, raw counts in excess of 100 are extrapolated based on the percentage analyzed. EMSL maintains liability limited to cost of analysis. This report relates only to the samples reported above and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. Samples received in good condition unless otherwise noted.

Samples analyzed by EMSL Analytical, Inc. Beltsville, MD AIHA-LAP, LLC -EMLAP Accredited #102891

Initial report from: 06/10/2019 13:48:25

For information on the fungi listed in this report, please visit the Resources section at [www.emsl.com](http://www.emsl.com)



# EMSL Analytical, Inc.

10768 Baltimore Avenue Beltsville, MD 20705

Tel/Fax: (301) 937-5700 / (301) 937-5701

<http://www.EMSL.com> / [beltsvillelab@emsl.com](mailto:beltsvillelab@emsl.com)

<b>EMSL Order:</b> 191906344
<b>Customer ID:</b> ATII25A
<b>Customer PO:</b>
<b>Project ID:</b>

<b>Attn:</b> Courtney McCall ATI 4221 Forbes Blvd Suite 250 Lanham, MD 20706	<b>Phone:</b> (202) 832-1433 <b>Fax:</b> <b>Collected:</b> 05/31/2019 <b>Received:</b> 06/04/2019 <b>Analyzed:</b> 06/05/2019 - 06/08/2019
<b>Project:</b> 19-692- PGCPs -HIGH POINT HIGH SCHOOL	

### Test Report: Air-O-Cell™ Analysis of Fungal Spores & Particulates by Optical Microscopy (Methods MICRO-SOP-201, ASTM D7391)

<b>Lab Sample Number:</b>	191906344-0013		
<b>Client Sample ID:</b>	19-692-13		
<b>Volume (L):</b>	75		
<b>Sample Location</b>	ROOM 22		
<b>Spore Types</b>	<b>Raw Count</b>	<b>Count/m³</b>	<b>% of Total</b>
Alternaria (Ulocladium)	-	-	-
Ascospores	6	200	14.6
Aspergillus/Penicillium	11	450	32.8
Basidiospores	15	620	45.3
Bipolaris++	-	-	-
Chaetomium	-	-	-
Cladosporium	3	100	7.3
Curvularia	-	-	-
Epicoccum	-	-	-
Fusarium	-	-	-
Ganoderma	-	-	-
Myxomycetes++	-	-	-
Pithomyces++	-	-	-
Rust	-	-	-
Scopulariopsis/Microascus	-	-	-
Stachybotrys/Memnoniella	-	-	-
Unidentifiable Spores	-	-	-
Zygomycetes	-	-	-
Cercospora++	-	-	-
Gonatobotryum	-	-	-
Polythrincium	-	-	-
Zygothiala/Schizothyrium	-	-	-
<b>Total Fungi</b>	<b>35</b>	<b>1370</b>	<b>100</b>
Hyphal Fragment	-	-	-
Insect Fragment	1*	10*	-
Pollen	-	-	-
Analyt. Sensitivity 600x	-	41	-
Analyt. Sensitivity 300x	-	13*	-
Skin Fragments (1-4)	-	4	-
Fibrous Particulate (1-4)	-	1	-
Background (1-5)	-	1	-

++ Includes other spores with similar morphology; see EMSL's fungal glossary for each specific category.

**Stefanie Schneider, Microbiology Laboratory Manager**  
or other approved signatory

High levels of background particulate can obscure spores and other particulates leading to underestimation. Background levels of 5 indicate an overloading of background particulates, prohibiting accurate detection and quantification. Present = Spores detected on overloaded samples. Results are not blank corrected unless otherwise noted. The detection limit is equal to one fungal spore, structure, pollen, fiber particle or insect fragment. \*\*\* Denotes particles found at 300X. "-" Denotes not detected. Due to method stopping rules, raw counts in excess of 100 are extrapolated based on the percentage analyzed. EMSL maintains liability limited to cost of analysis. This report relates only to the samples reported above and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. Samples received in good condition unless otherwise noted.

Samples analyzed by EMSL Analytical, Inc. Beltsville, MD AIHA-LAP, LLC --EMLAP Accredited #102891

Initial report from: 06/10/2019 13:48:25

For information on the fungi listed in this report, please visit the Resources section at [www.emsl.com](http://www.emsl.com)



EMSL ANALYTICAL, INC.  
LABORATORY PRODUCTS TRAINING

### Microbiology Chain of Custody

EMSL Order Number (Lab Use Only):

191906344

EMSL ANALYTICAL, INC.  
200 ROUTE 130 NORTH  
CINNAMINSON, NJ 08077  
PHONE: (800) 220-3675  
FAX: (856) 786-0262

Company Name: <b>ATI, Inc</b>			EMSL-Bill to: <input type="checkbox"/> Same <input type="checkbox"/> Different If Bill to is Different note instructions in Comments				
Street: 4221 Rumsey Road, Suite 250			Third Party Billing requires written authorization from third party.				
City: Lanham	State/Province: MD	Zip/Postal Code: 20706	Country:				
Report To (Name): Courtney McCall / Mikal Frater			Telephone #: 202-558-7489				
Email Address: Courtney@atinc.com & Mikal@atinc.com			Fax #:		Purchase Order:		
Project Name/Number: 19-692- PGCPs - High Point HS			Please Provide Results: <input type="checkbox"/> Fax <input checked="" type="checkbox"/> Email				
U.S. State Samples Taken:		Project Zip Code:	Connecticut Samples: <input checked="" type="checkbox"/> Commercial <input type="checkbox"/> Residential				
Sterile, Sodium Thiosulfate Preserved Bottle Used: <input type="checkbox"/> Biocide Used in Source (specify): <input type="checkbox"/>							
Public Water Supply Samples: <input type="checkbox"/> Note: All results may automatically be reported to DOH if required by state.							
Turnaround Time (TAT) Options- Please Check							
<input type="checkbox"/> 3 Hour	<input type="checkbox"/> 6 Hour	<input type="checkbox"/> 24 Hour	<input type="checkbox"/> 48 Hour	<input type="checkbox"/> 72 Hour	<input type="checkbox"/> 96 Hour	<input checked="" type="checkbox"/> 1 Week <input type="checkbox"/> 2 Week	
<b>Microbiology Test Codes</b>							
M001 Air-O-Cell	M174 MoldSnap	M012 <i>Pseudomonas aeruginosa</i> (PIA***)	M115 Sewage Screen - Water (PIA***)		M116 Sewage Screen - Water (MPN**)		
M030 Micro 5	M032 Allergenco-D	M024 <i>Pseudomonas aeruginosa</i> (MFT*)	M117 Sewage Screen - Swab (PIA***)		M117 Sewage Screen - Swab (PIA***)		
M041 Fungal Direct Examination		M015 Heterotrophic Plate Count	M013 Sewage Screen - Swab (MFT*)		M133 Methicillin-resistant <i>Staph. aureus</i> (MRSA)		
M169 Pollen ID & Enumeration		M017 Total Coliform & <i>E. coli</i> (Colilert PIA***)	M031 Rapid-growing non-TB <i>Mycobacteria</i> Detection & Enumeration		M014 Endotoxin Analysis		
M280 Dust Characterization Level-1		M018 Total Coliform & <i>E. coli</i> (MFT*)	M044 Group Allergen (Cat, Dog, Cockroach, Dust Mite)		Other See Analytical Price Guide		
M281 Dust Characterization Level-2		M114 Total Coliform & <i>E. coli</i> Enumeration (Colilert MPN**)	M014 Endotoxin Analysis		Legionella Analysis Please use EMSL Legionella COC		
M005 Viable Fungi- Air Samples (Genus ID & Count)		M019 Fecal Coliform (MFT*)					
M006 Viable Fungi- Air Samples (Includes <i>Penicillium</i> , <i>Aspergillus</i> , <i>Cladosporium</i> , <i>Stachybotrys</i> Species ID & Count)		M020 Fecal <i>Streptococcus</i> (MFT*)					
M007 Culturable fungi - Surface Samples (Genus ID & Count)		M029 <i>Enterococci</i> (MFT*)					
M008 Culturable fungi - Surface Samples (Includes <i>Penicillium</i> , <i>Aspergillus</i> , <i>Cladosporium</i> , <i>Stachybotrys</i> Species ID & Count)		M129 <i>Enterococci</i> (Enterolert PIA***)					
M009 Bacteria Culture Gram Stain & Count		M180 Real Time qPCR-ERMI 36 Panel					
M010 Bacteria Count & ID - 3 Most Prominent		M025 Sewage Screen -Water (MFT*)					
M011 Bacteria Count & ID - 5 Most Prominent							
			*MFT= Membrane Filtration Technique **MPN= Most Probable Number ***PIA= Presence/Absence				
Name of Sampler: Mikal Frater			Signature of Sampler:				
Sample #	Sample Location/Description	Sample Type	Potable/ NonPotable (Only for Waters)	Test Code	Volume/ Area	Date/Time Collected	Temperature (°C) (Lab Use Only)
Example A1	Kitchen Sink/Tap	Water	<input checked="" type="checkbox"/> P <input type="checkbox"/> NP	M017	100 mL	9/1/13 4:00 PM	
19-692-01	Outside Parking Lot	Air	<input type="checkbox"/> P <input type="checkbox"/> NP	M001	75L	05-31-19 8:01	
19-692-02	Field Blank	Air	<input type="checkbox"/> P <input type="checkbox"/> NP	M001	75L	05-31-19 8:17	
19-692-03	Main Office	Air	<input type="checkbox"/> P <input type="checkbox"/> NP	M001	75L	05-31-19 8:28	
19-692-04	Auditorium	Air	<input type="checkbox"/> P <input type="checkbox"/> NP	M001	75L	05-31-19 8:40	
19-692-05	Gymnasium	Air	<input type="checkbox"/> P <input type="checkbox"/> NP	M001	75L		
Client Sample # (s): - 13		Total # of Samples: 13		Samples Received Chilled? Yes / No (Lab Use Only)			
Relinquished (Client): M. FRATER			Date: 5-31-19	Time: 2:45 pm			
Received (Lab):			Date: 5/31/19	Time: 2:45 pm			
Comments/Special Instructions:							

EMSL Analytical, Inc.'s Laboratory Terms and Conditions are incorporated into this chain of custody by reference in their entirety. Submission of samples to EMSL Analytical, Inc. constitutes acceptance and acknowledgment of all terms and conditions by Customer.



EMSL ANALYTICAL, INC.  
LABORATORY PRODUCTS TRAINING

### Microbiology Chain of Custody

EMSL Order Number (Lab Use Only):

EMSL ANALYTICAL, INC.  
200 ROUTE 130 NORTH  
CINNAMINSON, NJ 08077  
PHONE: (800) 220-3675  
FAX: (856) 786-0262

Additional pages of the chain of custody are only necessary if needed for additional sample information.

Sample #	Sample Location/Description	Sample Type	Potable/ NonPotable (Only for Waters)	Test Code	Volume/ Area	Date/Time Collected	Temperature (°C) (Lab Use Only)
19-692-06	Cafeteria	Air	<input type="checkbox"/> P <input type="checkbox"/> NP	M001	75L	05-31-19 8:54	
19-692-07	Room 125	Air	<input type="checkbox"/> P <input type="checkbox"/> NP	M001	75L	05-31-19 9:11	
19-692-08	Room 237	Air	<input type="checkbox"/> P <input type="checkbox"/> NP	M001	75L	05-31-19 9:24	
19-692-09	Room 216	Air	<input type="checkbox"/> P <input type="checkbox"/> NP	M001	75L	05-31-19 9:36	
19-692-10	Room 200	Air	<input type="checkbox"/> P <input type="checkbox"/> NP	M001	75L	05-31-19 9:48	
19-692-11	Room 308	Air	<input type="checkbox"/> P <input type="checkbox"/> NP	M001	75L	05-31-19 10:00	
19-692-12	Room 324	Air	<input type="checkbox"/> P <input type="checkbox"/> NP	M001	75L	05-31-19 10:13	
19-692-13	Room 22	Air	<input type="checkbox"/> P <input type="checkbox"/> NP	M001	75L	05-31-19 10:23	
		Air	<input type="checkbox"/> P <input type="checkbox"/> NP	M001	75L		
		Air	<input type="checkbox"/> P <input type="checkbox"/> NP	M001	75L		
			<input type="checkbox"/> P <input type="checkbox"/> NP				
			<input type="checkbox"/> P <input type="checkbox"/> NP				
			<input type="checkbox"/> P <input type="checkbox"/> NP				
			<input type="checkbox"/> P <input type="checkbox"/> NP				
			<input type="checkbox"/> P <input type="checkbox"/> NP				
			<input type="checkbox"/> P <input type="checkbox"/> NP				
			<input type="checkbox"/> P <input type="checkbox"/> NP				
			<input type="checkbox"/> P <input type="checkbox"/> NP				
			<input type="checkbox"/> P <input type="checkbox"/> NP				
			<input type="checkbox"/> P <input type="checkbox"/> NP				
			<input type="checkbox"/> P <input type="checkbox"/> NP				
			<input type="checkbox"/> P <input type="checkbox"/> NP				
			<input type="checkbox"/> P <input type="checkbox"/> NP				
			<input type="checkbox"/> P <input type="checkbox"/> NP				
Comments/Special Instructions:							

EMSL Analytical, Inc.'s Laboratory Terms and Conditions are incorporated into this chain of custody by reference in their entirety. Submission of samples to EMSL Analytical, Inc. constitutes acceptance and acknowledgment of all terms and conditions by Customer.

**Appendix B:  
Instrument Calibration Records**

# Certificate of Calibration

() Buck™ BioAire Pump Calibration Rotameter

( ) Buck™ BioSlide Pump Calibration Rotameter

Serial number: R14057

Date Calibrated: 1/22/19

Calibration Due Date: 1/22/20

## Flow Calibration

This is to certify that the rotameter listed above has been calibrated using a Buck Primary calibrator listed below which is calibrated according to A.P. Buck, Inc. calibration procedure APB-1, Ver. 6.2 and is traceable to the National Institute of Standards & Technology (N.I.S.T). A.P. Buck guarantees the accuracy of the rotameter to be within  $\pm 5\%$  of the actual flow rate.

AMBIENT CONDITIONS: Temperature  $74 \pm 3^{\circ}$  F Relative Humidity  $50 \pm 10\%$

Description	MFR.	Model	Serial #
Primary Calibrator	A.P. Buck Inc.	M30B	<input type="checkbox"/> A40020 <input checked="" type="checkbox"/> A40021

QA Approval By: 

Information contained in this document should not be reproduced in any form without the written consent of A.P. Buck, Inc. It is for reference only and cannot be used as a form of endorsement by any private or governmental regulatory body.

A.P. BUCK, INC.  
7101 Presidents Drive, Suite 110  
Orlando, FL 32809  
Phone: 407-851-8602  
Fax: 407-851-8910

**BUCK**  
A.P. BUCK, INC.



# INSTRUMENT CALIBRATION REPORT

Pine Environmental Services LLC

798 Cromwell Park Dr.  
Suite R & S  
Glen Burnie, MD 21061

## Pine Environmental Services, Inc.

**Instrument ID** 27136  
**Description** TSI 982 Probe  
**Calibrated** 5/28/2019 12:36:30PM

**Manufacturer** Tsi  
**Model Number** 982  
**Serial Number/ Lot Number** p13220024  
**Location** Maryland  
**Department**  
**State Certified**  
**Status** Pass  
**Temp °C** 22  
**Humidity %** 53

### Calibration Specifications

Group # 1				Range Acc % 0.0000			
Group Name CO				Reading Acc % 3.0000			
Stated Accy Pct of Reading				Plus/Minus 0.0			
<u>Nom In Val / In Val</u>	<u>In Type</u>	<u>Out Val</u>	<u>Out Type</u>	<u>Fnd As</u>	<u>Lft As</u>	<u>Dev%</u>	<u>Pass/Fail</u>
100.0 / 100.0	PPM	100.0	PPM	108.0	100.0	0.00%	Pass
Group # 2				Range Acc % 0.0000			
Group Name CO2				Reading Acc % 3.0000			
Stated Accy Pct of Reading				Plus/Minus 0			
<u>Nom In Val / In Val</u>	<u>In Type</u>	<u>Out Val</u>	<u>Out Type</u>	<u>Fnd As</u>	<u>Lft As</u>	<u>Dev%</u>	<u>Pass/Fail</u>
1000 / 1000	PPM	1000	PPM	982	1,000	0.00%	Pass

### Test Instruments Used During the Calibration

<u>Test Standard ID</u>	<u>Description</u>	<u>Manufacturer</u>	<u>Model Number</u>	<u>Serial Number / Lot Number</u>	<u>(As Of Cal Entry Date)</u>	
					<u>Last Cal Date / Opened Date</u>	<u>Next Cal Date / Expiration Date</u>
MD 2GAS CO 100PPM/CO2 1000PPM	MD 2GAS CO 100PPM/CO2 1000PPM - LBI-375-2	Pine Environmental Services, Inc.	31657	LBI-375-2		11/21/2022
MD ZERO AIR FBI-1-25	MD ZERO AIR	Pine Environmental Services, Inc.	34LS-1	FBI-1-25		

### Notes about this calibration

**Calibration Result** Calibration Successful  
**Who Calibrated** Ryan Armstrong



# INSTRUMENT CALIBRATION REPORT



**Pine Environmental Services LLC**

798 Cromwell Park Dr.  
Suite R & S  
Glen Burnie, MD 21061

## **Pine Environmental Services, Inc.**

---

**Instrument ID** 27136  
**Description** TSI 982 Probe  
**Calibrated** 5/28/2019 12:36:30PM

---

All instruments are calibrated by Pine Environmental Services LLC according to the manufacturer's specifications, but it is the customer's responsibility to calibrate and maintain this unit in accordance with the manufacturer's specifications and/or the customer's own specific needs.

**Notify Pine Environmental Services LLC of any defect within 24 hours of receipt of equipment**  
**Please call 800-301-9663 for Technical Assistance**

# INSTRUMENT CALIBRATION REPORT



Advanced Labs, Inc.

## Pine Environmental Services, Inc

Instrument ID 27136  
 Description TSI 982 Probe  
 Calibrated 12/12/2018

Manufacturer TSI  
 Model Number 982  
 Serial Number P13220024  
 Location New Jersey  
 Temp 71

Classification  
 Status pass  
 Frequency Yearly EOM  
 Department Lab  
 Humidity 22

### Calibration Specifications

Group # 1							
Group Name Carbon Dioxide							
Stated Accy Pct of Reading							
<u>Nom In Val / In Val</u>	<u>In Type</u>	<u>Out Val</u>	<u>Out Type</u>	<u>End As</u>	<u>Lft As</u>	<u>Dev%</u>	<u>Pass/Fail</u>
0.00 / 0.00	ppm	0.00	ppm	0.00	0.00	0.00%	Pass
1000.00 / 1000.00	ppm	1000.00	ppm	1,009.00	1,002.00	0.20%	Pass
				Range Acc %	0.0000		
				Reading Acc %	3.0000		
				Plus/Minus	0.00		
Group # 2							
Group Name Carbon Monoxide							
Stated Accy Pct of Reading							
<u>Nom In Val / In Val</u>	<u>In Type</u>	<u>Out Val</u>	<u>Out Type</u>	<u>End As</u>	<u>Lft As</u>	<u>Dev%</u>	<u>Pass/Fail</u>
0.00 / 0.00	ppm	0.00	ppm	4.60	0.00	0.00%	Pass
100.00 / 100.00	ppm	100.00	ppm	96.00	100.10	0.10%	Pass
				Range Acc %	0.0000		
				Reading Acc %	3.0000		
				Plus/Minus	0.00		
Group # 3							
Group Name Relative Humidity							
Stated Accy Pct of Reading							
<u>Nom In Val / In Val</u>	<u>In Type</u>	<u>Out Val</u>	<u>Out Type</u>	<u>End As</u>	<u>Lft As</u>	<u>Dev%</u>	<u>Pass/Fail</u>
50.00 / 30.80	%	30.80	%	31.00	30.80	0.00%	Pass
				Range Acc %	0.0000		
				Reading Acc %	3.0000		
				Plus/Minus	0.00		
Group # 4							
Group Name Temperature							
Stated Accy Plus / Minus							
<u>Nom In Val / In Val</u>	<u>In Type</u>	<u>Out Val</u>	<u>Out Type</u>	<u>End As</u>	<u>Lft As</u>	<u>Dev%</u>	<u>Pass/Fail</u>
65.00 / 72.30	°F	72.30	°F	69.80	72.30	0.00%	Pass

### Test Instruments Used During the Calibration

<u>Test Instrument ID</u>	<u>Description</u>	<u>Manufacturer</u>	<u>Serial Number</u>	<u>(As Of Cal Entry Date)</u>	
				<u>Last Cal Date</u>	<u>Next Cal Date</u>
CO/CO2_34LS-375	100 ppm CO, 1000 ppm CO2	Calgaz	MAO-375-1		6/9/2019
MICHELL DM-509-TX-01	Relative Humidity Meter	Michell	273296	9/17/2018	9/17/2019
NITROGEN ZERO_AIR_105	Nitrogen 99.999%	Liquid Technology	7727-37-9	6/1/2016	6/1/2019
L-1	Zero Grade Air THC <1.0 PPM	Liquid Technology	KAP-A-10	10/1/2015	10/20/2019

# INSTRUMENT CALIBRATION REPORT



Advanced Labs, Inc.

**Pine Environmental Services, Inc**

---

**Instrument ID** 27136  
**Description** TSI 982 Probe  
**Calibrated** 12/12/2018

---

**Notes about this calibration**

**Calibration Result** Calibration Successful  
**Who Calibrated** Kevin Cole

**Advanced Labs, Inc. hereby certifies that this instrument is calibrated and functions to meet the manufacture's specifications using NIST traceable standards, or is derived from accepted values of physical constants.**

# INSTRUMENT CALIBRATION REPORT



Advanced Labs, Inc.

## Pine Environmental Services, Inc

Instrument ID R20401  
 Description TSI 7575 -X Q-Trak  
 Calibrated 8/22/2018

Manufacturer TSI  
 Model Number 7575-X  
 Serial Number 7575X1130009  
 Location New Jersey  
 Temp 77

Classification  
 Status pass  
 Frequency Yearly EOM  
 Department Lab  
 Humidity 41

### Calibration Specifications

<b>Group # 1</b>				<b>Range Acc % 0.0000</b>			
<b>Group Name Barometric Pressure</b>				<b>Reading Acc % 3.0000</b>			
<b>Stated Accy Pct of Reading</b>				<b>Plus/Minus 0.000</b>			
<u>Nom In Val / In Val</u>	<u>In Type</u>	<u>Out Val</u>	<u>Out Type</u>	<u>End As</u>	<u>Lft As</u>	<u>Dev%</u>	<u>Pass/Fail</u>
30.000 / 29.610	inHg	29.610	inHg	29.620	29.610	0.00%	Pass

### Test Instruments Used During the Calibration

<u>Test Instrument ID</u>	<u>Description</u>	<u>Manufacturer</u>	<u>Serial Number</u>	<u>(As Of Cal Entry Date)</u>	
				<u>Last Cal Date</u>	<u>Next Cal Date</u>
OMEGA HX93AC/DP25- E	Omega HX93AC/DP25-E	Omega Engineering	1010368 035025 035026	9/15/2016	9/15/2018
OMEGA PX02K1-16A5T /DP25-E-A	Omega PX02K1-16A5T/DP25-E-A	Omega Engineering	168377/8375030	9/15/2016	9/15/2018
OMEGA WT4401-D	Omega WT4401-D	Omega Engineering	101105	9/15/2016	9/15/2018

### Notes about this calibration

Calibration Result Calibration Successful  
 Who Calibrated Kevin Cole

**Advanced Labs, Inc. hereby certifies that this instrument is calibrated and functions to meet the manufacture's specifications using NIST traceable standards, or is derived from accepted values of physical constants.**

# INSTRUMENT CALIBRATION REPORT



**Pine Environmental Services LLC**

798 Cromwell Park Dr.  
Suite R & S  
Glen Burnie, MD 21061

## **Pine Environmental Services, Inc.**

**Instrument ID** R20401  
**Description** TSI 7575 Q-Trak  
**Calibrated** 5/28/2019 12:35:31PM

**Manufacturer** Tsi  
**Model Number** 7575  
**Serial Number/ Lot Number** 7575X1130009  
**Location** Maryland  
**Department**

**State Certified**  
**Status** Pass  
**Temp °C** 22  
**Humidity %** 53

### Calibration Specifications

**Group #** 1  
**Group Name** Functional Test  
**Test Performed:** Yes      **As Found Result:** Pass      **As Left Result:** Pass

### Test Instruments Used During the Calibration

<u>Test Standard ID</u>	<u>Description</u>	<u>Manufacturer</u>	<u>Model Number</u>	<u>Serial Number / Lot Number</u>	<u>(As Of Cal Entry Date)</u> <u>Next Cal Date /</u> <u>Last Cal Date/ Expiration Date</u> <u>Opened Date</u>
-------------------------	--------------------	---------------------	---------------------	-----------------------------------	--

### Notes about this calibration

**Calibration Result** Calibration Successful  
**Who Calibrated** Ryan Armstrong

All instruments are calibrated by Pine Environmental Services LLC according to the manufacturer's specifications, but it is the customer's responsibility to calibrate and maintain this unit in accordance with the manufacturer's specifications and/or the customer's own specific needs.

**Notify Pine Environmental Services LLC of any defect within 24 hours of receipt of equipment**  
**Please call 800-301-9663 for Technical Assistance**