



Architecture | Engineering | Construction

9220 Rumsey Road, Suite 100, Columbia, MD 21045  
T: 410.992.3424 | F: 410.992.1837

December 18, 2020

Prince George's County Public Schools  
13300 Old Marlboro Pike  
Upper Marlboro, Maryland 20772  
Attention: Mr. Alex Baylor

RE: Indoor Air Quality Assessment, Hollywood Elementary School  
IFB: 022-19  
ATI Project Number: 20-705

Dear Mr. Baylor:

Prince George's County Public Schools requested that ATI, Inc., conduct a proactive indoor air quality (IAQ) assessment at Hollywood Elementary School on December 9, 2020. Its key findings are enclosed in the Executive Summary on page three, and the official laboratory report for total fungal spore trap sampling is enclosed in Appendix A.

Thank you for the opportunity to provide Industrial Hygiene services for Prince George's County Public Schools. If you have any questions regarding this report, please contact us at (202) 643-4283.

Sincerely,  
**ATI, INC.**

---

Courtney E. McCall  
Project Manager

---

Nate Burgei, CIH, CSP  
Certified Industrial Hygienist

# Indoor Air Quality Assessment Report

Prince George's County Public Schools  
Hollywood Elementary School  
9811 49th Avenue  
College Park, MD 20740

Prepared for:

Prince George's County Public Schools  
13300 Old Marlboro Pike  
Upper Marlboro, Maryland 20772

**December 18, 2020**

Submitted by:



ATI Job # 20-705

## Table of Contents

Table of Contents .....	1
1 Executive Summary .....	1
2 Assessment Methods .....	1
3 Visual Observations .....	2
4 Thermal Environmental Conditions for Human Occupancy .....	3
4.1 Temperature .....	3
4.2 Relative Humidity .....	4
4.3 Carbon Dioxide .....	5
4.4 Carbon Monoxide .....	5
5 Total Fungal Air Sampling Results .....	6
6 Summary of Findings .....	7

## List of Tables

Table 1: Visual Observations and Sampling Locations .....	2
Table 2: Temperature .....	4
Table 3: Relative Humidity .....	4
Table 4: Carbon Dioxide .....	5
Table 5: Carbon Monoxide .....	6

## Appendices

- Appendix A: Laboratory Report and Chain of Custody
- Appendix B: Instrument Calibration Records

## Abbreviations and Acronyms

<b>AHU</b>	Air-Handling Unit
<b>AIHA</b>	American Industrial Hygiene Association
<b>ASHRAE</b>	American Society of Heating, Refrigerating and Air-Conditioning Engineers
<b>ASTM</b>	American Society for Testing and Materials
<b>CO</b>	Carbon Monoxide
<b>CO<sub>2</sub></b>	Carbon Dioxide
<b>EMLAP</b>	Environmental Microbiology Laboratory Accreditation Program
<b>HVAC</b>	Heating, Ventilating, And Air-Conditioning
<b>IAQ</b>	Indoor Air Quality
<b>NIST</b>	National Institute for Standards and Technology
<b>NVLAP</b>	National Voluntary Laboratory Accreditation Program
<b>RH</b>	Relative Humidity
<b>Rev.</b>	Revision

### Abbreviations involving scientific volume and measurements involving media or water sampling

<b>Counts/m<sup>3</sup></b>	Mold spores per cubic meter of air
<b>LPM</b>	Liters Per Minute
<b>NTE</b>	Not to exceed
<b>°F</b>	degree Fahrenheit
<b>PPM</b>	Parts Per Million

## 1 Executive Summary

---

ATI conducted a proactive Indoor Air Quality (IAQ) assessment on December 9, 2020, at Hollywood Elementary School, located at 9811 49th Ave., College Park, MD 20740.

The assessment included a visual assessment of randomly selected classrooms and other frequently occupied spaces, such as the cafeteria, the main office, and classrooms, for potential IAQ contributors and pathways. As part of the assessment, ATI measured common IAQ comfort parameters, including temperature, relative humidity, carbon dioxide, and carbon monoxide. Also, ATI collected total fungal air samples on spore trap cassettes for microbiological analysis.

The following is a summary of the key findings from this assessment:

1. One of the tested spaces had a temperature greater than the ASHRAE recommended winter range of 68-75°F.
2. Relative humidity in all tested spaces was less than the ASHRAE guidelines of <65%, yet was also <30%, which can cause occupant discomfort.
3. Carbon dioxide concentrations in all tested spaces were less than the ASHRAE limit for carbon dioxide, which was 1,126 parts per million (PPM).
4. Carbon monoxide concentrations were less than the IAQ meter's detection limit throughout the tested spaces.
5. The fungal spore trap results do not suggest indoor spore amplification in the assessed spaces and are not considered unusual. There was a wet ceiling tile in the Computer Lab with signs of mold growth. This ceiling tile should be replaced, and the cause of the wet tile should be investigated and fixed if a water problem is found.

## 2 Assessment Methods

---

Sama Wanigasundara of ATI, Inc. conducted a visual assessment and air sampling on December 9, 2020. Sampled rooms were randomly selected and accounted for approximately 10% of classrooms or a minimum of five samples. Mr. Wanigasundara documented visual observations at the time he collected the air samples. ATI references the American Society of Heating, Refrigerating, and Air-Conditioning Engineers (ASHRAE) *Standard 62.1 – 2016* and *ASHRAE Standard 55 – 2017* when providing IAQ services to clients. ASHRAE is an industry leader on energy efficiency and indoor air quality.

All measurements and air samples were collected between three-six feet from floor elevation, which represents a typical adult breathing zone, and away from air-supply and return diffusers. Real-time direct readings for temperature, relative humidity, carbon dioxide (CO<sub>2</sub>), and carbon monoxide (CO), were obtained with a calibrated TSI Q-Trak 7575-X Meter and attached 982 Probe.

Total fungal air samples were collected with a Buck BioAire High-Volume Sampling Pump on Zefon Air-O-Cell spore-trap cassettes at a flow rate of 15 liters per minute for five minutes, for a sample volume of 75 liters. EMSL Analytical, Inc. of Plymouth Meeting, PA, analyzed the samples using direct microscopic examination per ASTM D7391-09, which counts both viable and non-viable mold spores and particulates, which combined yields *total fungal* results. EMSL participates in the National Institute of Standards and Technology's (NIST) National Voluntary Laboratory Accreditation Program (NVLAP) for general laboratory performance and management, and the American Industrial Hygiene Association (AIHA) for Environmental Microbial Laboratory Accreditation Program (EMLAP). The EMSL laboratory reports are included in Appendix A.

### 3 Visual Observations

Table 1 lists the areas, conditions, observations, and other pertinent details related to this IAQ assessment. On the date of the sampling event, few occupants were present in the school because of the COVID-19 global pandemic.

**Table 1: Visual Observations and Sampling Locations**

Sample Location	Observations
Parking Lot – Outdoors	<ul style="list-style-type: none"> <li>• Scattered clouds, mostly clear skies</li> <li>• Light foot and vehicle traffic observed</li> </ul>
Main Office	<ul style="list-style-type: none"> <li>• Four occupants in the area during sampling</li> <li>• No odors, stained ceiling tiles, or visible mold growth observed</li> <li>• Door to corridor OPEN during sampling</li> <li>• Oscillating fan OFF during sampling</li> <li>• Room splits into three adjoining office spaces</li> <li>• Four air return in this space</li> <li>• Four air diffusers in the space</li> <li>• Space is approximately 1200 ft.<sup>2</sup></li> </ul>
Cafeteria	<ul style="list-style-type: none"> <li>• No odors, stained ceiling tiles, or visible mold growth observed</li> <li>• Six occupants in area during sampling</li> <li>• No dust accumulation</li> <li>• Five air returns in this space (dust accumulated)</li> <li>• Six air diffusers in this space (dust accumulated)</li> <li>• Space is approximately 2,700 ft.<sup>2</sup></li> </ul>
Gymnasium	<ul style="list-style-type: none"> <li>• No odors, stained ceiling tiles, or visible mold growth observed</li> <li>• No occupants in the area during sampling</li> <li>• Three air returns in this space (dust accumulated)</li> <li>• Four diffusers in the space (dust accumulated)</li> <li>• No dust accumulation in this space</li> <li>• Space is approximately 4116 ft.<sup>2</sup></li> </ul>
Media Center	<ul style="list-style-type: none"> <li>• No occupants in the area during sampling</li> <li>• Light dust accumulation in this space</li> <li>• One air return in this space</li> <li>• Adjoining room with sink ceiling observed mold growth</li> <li>• Two air diffusers in this space</li> <li>• Space is approximately 2000 ft.<sup>2</sup></li> </ul>
Computer Lab	<ul style="list-style-type: none"> <li>• Observed a ceiling tile with water marks/damage and likely mold growth (dark area on water damage)</li> <li>• Wall unit OFF during sampling</li> <li>• No visible air return in this space</li> <li>• No occupants in area during sampling</li> <li>• Bathroom inside the room</li> </ul>

Sample Location	Observations
	<ul style="list-style-type: none"> <li>• Door to outside closed.</li> <li>• Space is approximately 600 ft.<sup>2</sup></li> </ul>
Room 2	<ul style="list-style-type: none"> <li>• No occupants in area during sampling</li> <li>• Inside room bathroom</li> <li>• No visible dust on flows and furniture</li> <li>• No visible mold growth or odor observed</li> <li>• One air diffuser and retune in this space</li> <li>• Space is approximately 792ft.<sup>2</sup></li> </ul>
Room 18	<ul style="list-style-type: none"> <li>• No occupants in area during sampling</li> <li>• Inside room bathroom</li> <li>• No visible dust on flows and furniture</li> <li>• No visible mold growth or odor observed</li> <li>• One air diffuser and retune in this space</li> <li>• Space is approximately 720ft.<sup>2</sup></li> </ul>
Room 17	<ul style="list-style-type: none"> <li>• No occupants in area during sampling</li> <li>• Inside room bathroom</li> <li>• No visible dust on flows and furniture</li> <li>• No visible mold growth or odor observed</li> <li>• One air diffuser and retune in this space</li> <li>• Space is approximately 784ft.<sup>2</sup></li> </ul>

## 4 Thermal Environmental Conditions for Human Occupancy

ASHRAE *Standard 55-2017, Thermal Environmental Conditions for Human Occupancy*, addresses thermal comfort in an office environment, which means that an employee wearing a normal amount of clothing feels neither too cold nor too warm. This standard discusses thermal comfort within the context of air temperature, humidity, and air movement and provides recommended ranges for temperature and humidity that are intended to satisfy 80% of occupants. The recommended ASHRAE ranges are referenced below by each comfort parameter.

### 4.1 Temperature

The ASHRAE standard establishes a winter comfort range of between 68°F and 75°F and a summer range of between 73°F and 79°F. The temperature measured during the December 9, 2020, assessment is summarized in Table 2. As indicated by the data in the table, temperatures in the school averaged between 70°F and 78°F, with one location having greater and one location less than the ASHRAE recommended winter range.

Table 2: Temperature

Sample Location	12/09/2020 °F			ASHRAE Standard °F
	Min	Max	Average	
Outdoors	55	55	55	N/A
<b>Indoors</b>				
Main Office	73	73	73	68-75°F
Cafeteria	74	74	74	68-75°F
Gymnasium	72	72	72	68-75°F
Media Center	72	72	72	68-75°F
Computer Lab	78	78	78	68-75°F
Room 2	69	70	70	68-75°F
Room 18	72	72	72	68-75°F
Room 17	72	73	73	68-75°F

4.2 Relative Humidity

Relative humidity is a key factor for mold growth. Mold has the potential of growing on suitable surfaces with humidity levels above 65%. ASHRAE *Standard 62.1-2016, Ventilation for Acceptable Indoor Air Quality*, recommends a maximum indoor relative humidity of 65% to prevent condensation of moisture on surfaces. Relative humidity less than 30% may result in drying of occupants’ mucous membranes and skin. Relative humidity is summarized in Table 3. As indicated by the data in the table, relative humidity averaged between 15% and 29% with all tested locations measuring less than the ASHRAE maximum recommendation of 65% relative humidity, yet also less than 30% relative humidity.

Table 3: Relative Humidity

Sample Location	12/09/2020 (% RH)			ASHRAE Standard (% RH)
	Min	Max	Average	
Outdoors	19	19	19	N/A
<b>Indoors</b>				
Main Office	25	25	25	< 65
Cafeteria	15	15	15	< 65
Gymnasium	20	20	20	< 65
Media Center	22	22	22	< 65
Computer Lab	16	16	16	< 65
Room 2	21	21	21	< 65
Room 18	29	29	29	< 65
Room 17	18	18	18	< 65



4.3 Carbon Dioxide

Carbon dioxide concentrations within an occupied building are a standard method used to gauge the efficiency of ventilation systems. Carbon dioxide is a by-product of human respiration and does not pose an acute health hazard alone. Elevated concentrations may suggest that insufficient fresh air is being supplied to an occupied space and/or that the ventilation system does not provide a sufficient rate of air exchange.

Research has indicated that buildings with adequately operating ventilation systems are able to remove odors generated by activities in an indoor office environment efficiently. ASHRAE *Standard 62.1-2016* states that comfort (odor) criteria with respect to human bioeffluents are likely to be satisfied if the ventilation maintains indoor carbon dioxide concentrations to less than 700 parts per million (ppm) greater than the outdoor air concentration. Typically, outdoor carbon dioxide concentrations range from 300-450 ppm, with the higher range typically found in urban areas during peak rush hour.

Carbon dioxide concentrations are summarized in Table 4. On the day of the assessment, the average outdoor carbon dioxide concentration measured was 426 ppm, which calculates to a maximum indoor concentration of 1,126 ppm (700 + 426). All tested locations indoors were less than the recommended maximum for the day of the assessment.

Table 4: Carbon Dioxide

Sample Location	12/09/2020 Concentration (parts per million)			ASHRAE Standard (ppm) NTE
	Min	Max	Average	
Outdoors	425	426	426	N/A
<b>Indoors</b>				
Main Office	867	870	869	1,126
Cafeteria	437	440	439	1,126
Gymnasium	436	439	438	1,126
Media Center	423	427	425	1,126
Computer Lab	460	467	464	1,126
Room 2	423	429	426	1,126
Room 18	508	530	419	1,126
Room 17	429	455	442	1,126

4.4 Carbon Monoxide

Carbon monoxide is a colorless and odorless gas produced by the incomplete combustion of carbon containing fuels. Oil, gasoline, diesel fuels, wood, coke, and coal are the major sources of carbon monoxide. ASHRAE recommends that carbon monoxide not exceed nine ppm indoors over an eight-hour time-weighted average. ATI measured carbon monoxide concentrations using a TSI Q-Trak model number 7575-X with an attached IAQ probe (model number 982). The instrument’s carbon monoxide sensor has an error range of ± 3% of the reading or three (3) ppm, whichever is greater. As indicated by the data in Table 5, carbon monoxide concentrations were less than the Q-Trak’s detection limit throughout the school.

Table 5: Carbon Monoxide

Sample Location	12/09/2020 Concentration (parts per million)			ASHRAE Standard (ppm)
	Min	Max	Average	
Outdoors	<3	<3	<3	N/A
<b>Inside</b>				
Main Office	<3	<3	<3	< 9
Cafeteria	<3	<3	<3	< 9
Gymnasium	<3	<3	<3	< 9
Media Center	<3	<3	<3	< 9
Computer Lab	<3	<3	<3	< 9
Room 2	<3	<3	<3	< 9
Room 18	<3	<3	<3	< 9
Room 17	<3	<3	<3	< 9

## 5 Total Fungal Air Sampling Results

Mold is carried indoors through building entrances, open windows, loading docks, foot traffic into buildings, and the HVAC system. To thrive indoors, mold requires a food source, proper temperature and humidity to foster its growth.

The December 9, 2020 mold assessment sampled air using spore trap cassettes in randomly selected classrooms and other areas throughout the facility. These cassettes collect both viable spores, those capable of producing more fungal colonies, and non-viable spores, which cannot reproduce. Based upon recognized industry practices, indoor mold concentrations are compared with those detected outdoors, which are also known as ambient or baseline samples.

In normal circumstances, the diversity of spores identified indoors and outdoors should be similar with some exceptions. The high concentration of one or two species of fungal spores identified indoors and the absence of the same species outdoors can indicate a moisture problem with the potential to degrade the air quality. Fungi species present indoors are typically found at levels ranging from approximately 10-50% of their levels in the outdoor air, reflecting the filtering by the building’s HVAC system.

The findings indicated that the indoor concentrations were generally favorable compared to the outdoor concentrations. The total ambient spore concentration was 710 counts/m<sup>3</sup>, and most tested rooms had spore concentrations less than the ambient total concentration. Although the gymnasium and main office had total concentrations greater than the total ambient concentration, 930 counts/m<sup>3</sup> and 1,150 counts/m<sup>3</sup>, respectively, the total spore concentrations were less than 1,000 counts/m<sup>3</sup>.

*Aspergillus/Penicillium* was detected in some of the indoor spaces, and the highest amount was 800 counts/m<sup>3</sup> in the main office. *Cladosporium* was also identified in some of the spaces with the gymnasium having the greatest *Cladosporium* concentration of 890 counts/m<sup>3</sup>. Trace amounts of *Myxomycetes* and *Epicoccum* were detected in low concentrations that did not exceed 100 counts/m<sup>3</sup>. The concentrations measured indoors do not suggest significant spore amplification. The measured concentrations are not unusual in occupied spaces, as total spore concentrations in a typical indoor space are at or less than 1,000 counts/m<sup>3</sup>.

There was a wet ceiling tile in the Computer Lab with signs of mold growth. This ceiling tile should be replaced and the cause of the wet tile should be investigated and fixed if a water problem is found.

The official laboratory report with spore trap samples collected on December 9, 2020, is presented in Appendix A.

## 6 Summary of Findings

---

1. One of the tested spaces had a temperature greater than the ASHRAE recommended winter range of 68-75°F.
2. Relative humidity in all tested spaces was less than the ASHRAE guidelines of <65%, yet was also <30%, which can cause occupant discomfort.
3. Carbon dioxide concentrations in all tested spaces were less than the ASHRAE limit for carbon dioxide, which was 1,126 parts per million (PPM).
4. Carbon monoxide concentrations were less than the IAQ meter's detection limit throughout the tested spaces.
5. The fungal spore trap results do not suggest indoor spore amplification in the assessed spaces and are not considered unusual. There was a wet ceiling tile in the Computer Lab with signs of mold growth. This ceiling tile should be replaced, and the cause of the wet tile should be investigated and fixed if a water problem is found.

We appreciate the opportunity to provide these IAQ testing services for you. If you have any questions, please contact us at (202) 643-4283.

Best,  
**ATI, INC.**



---

Courtney E. McCall  
Project Manager



---

Nate Burgei, CIH, CSP  
Certified Industrial Hygienist

Appendix A: Laboratory Report and Chain of Custody



# EMSL Analytical, Inc.

5221 Militia Hill Road Plymouth Meeting, PA 19462  
Tel/Fax: (610) 828-3102 / (610) 828-3122  
<http://www.EMSL.com> / [plymouthmeetinglab@emsl.com](mailto:plymouthmeetinglab@emsl.com)

**EMSL Order:** 182004045  
**Customer ID:** ATII25A  
**Customer PO:**  
**Project ID:**

**Attention:** Courtney McCall  
ATI  
4221 Forbes Blvd  
Suite 250  
Lanham, MD 20706  
**Project:** Hollywood ES 20-705

**Phone:** (202) 832-1433  
**Fax:**  
**Collected Date:** 12/09/2020  
**Received Date:** 12/10/2020 03:57 PM  
**Analyzed Date:** 12/17/2020

### Test Report: Air-O-Cell™ Analysis of Fungal Spores & Particulates by Optical Microscopy (Methods MICRO-SOP-201, ASTM D7391)

Lab Sample Number:	182004045-0001			182004045-0002			182004045-0003		
Client Sample ID:	3106-0589			3106-0574			3106-0590		
Volume (L):	75			75			75		
Sample Location:	Outside Exterior			Gymnassim			Main Office		
Spore Types	Raw Count	Count/M³	% of Total	Raw Count	Count/M³	% of Total	Raw Count	Count/M³	% of Total
Alternaria (Ulocladium)	-	-	-	-	-	-	-	-	-
Ascospores	-	-	-	-	-	-	-	-	-
Aspergillus/Penicillium	2	80	11.3	-	-	-	19	800	69.6
Basidiospores	14	590	83.1	1	40	4.3	-	-	-
Bipolaris++	-	-	-	-	-	-	-	-	-
Chaetomium	-	-	-	-	-	-	-	-	-
Cladosporium	-	-	-	21	890	95.7	7	300	26.1
Curvularia	-	-	-	-	-	-	-	-	-
Epicoccum	-	-	-	-	-	-	-	-	-
Fusarium	-	-	-	-	-	-	-	-	-
Ganoderma	-	-	-	-	-	-	-	-	-
Myxomycetes++	1	40	5.6	-	-	-	1	40	3.5
Pithomyces++	-	-	-	-	-	-	-	-	-
Rust	-	-	-	-	-	-	1*	10*	0.9
Scopulariopsis/Microascus	-	-	-	-	-	-	-	-	-
Stachybotrys/Memnoniella	-	-	-	-	-	-	-	-	-
Unidentifiable Spores	-	-	-	-	-	-	-	-	-
Zygomycetes	-	-	-	-	-	-	-	-	-
<b>Total Fungi</b>	<b>17</b>	<b>710</b>	<b>100</b>	<b>22</b>	<b>930</b>	<b>100</b>	<b>28</b>	<b>1150</b>	<b>100</b>
Hyphal Fragment	-	-	-	2	80	-	-	-	-
Insect Fragment	-	-	-	1	40	-	-	-	-
Pollen	-	-	-	1*	10*	-	-	-	-
Analyt. Sensitivity 600x	-	42	-	-	42	-	-	42	-
Analyt. Sensitivity 300x	-	13*	-	-	13*	-	-	13*	-
Skin Fragments (1-4)	-	1	-	-	1	-	-	3	-
Fibrous Particulate (1-4)	-	1	-	-	1	-	-	1	-
Background (1-5)	-	1	-	-	1	-	-	2	-

++ Includes other spores with similar morphology; see EMSL's fungal glossary for each specific category.

Kevin Ream, Laboratory Manager  
or other Approved Signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted. High levels of background particulate can obscure spores and other particulates, leading to underestimation. Background levels of 5 indicate an overloading of background particulates, prohibiting accurate detection and quantification. Present = Spores detected on overloaded samples. Results are not blank corrected unless otherwise noted. The detection limit is equal to one fungal spore, structure, pollen, fiber particle or insect fragment. "\*" Denotes particles found at 300X. "-" Denotes not detected. Due to method stopping rules, raw counts in excess of 100 are extrapolated based on the percentage analyzed.

Samples analyzed by EMSL Analytical, Inc. Plymouth Meeting, PA AIHA-LAP, LLC-EMLAP Accredited #178659

Initial report from: 12/17/2020 02:06 PM

For information on the fungi listed in this report, please visit the Resources section at [www.emsl.com](http://www.emsl.com)



# EMSL Analytical, Inc.

5221 Militia Hill Road Plymouth Meeting, PA 19462  
Tel/Fax: (610) 828-3102 / (610) 828-3122  
<http://www.EMSL.com> / [plymouthmeetinglab@emsl.com](mailto:plymouthmeetinglab@emsl.com)

**EMSL Order:** 182004045  
**Customer ID:** ATII25A  
**Customer PO:**  
**Project ID:**

**Attention:** Courtney McCall  
ATI  
4221 Forbes Blvd  
Suite 250  
Lanham, MD 20706  
**Project:** Hollywood ES 20-705

**Phone:** (202) 832-1433  
**Fax:**  
**Collected Date:** 12/09/2020  
**Received Date:** 12/10/2020 03:57 PM  
**Analyzed Date:** 12/17/2020

### Test Report: Air-O-Cell™ Analysis of Fungal Spores & Particulates by Optical Microscopy (Methods MICRO-SOP-201, ASTM D7391)

Lab Sample Number: Client Sample ID: Volume (L): Sample Location:	182004045-0004 3106-0615 75 MPR			182004045-0005 3106-0578 75 Media Center			182004045-0006 3106-0588 75 Computer Lab			
	Spore Types	Raw Count	Count/M <sup>3</sup>	% of Total	Raw Count	Count/M <sup>3</sup>	% of Total	Raw Count	Count/M <sup>3</sup>	% of Total
Alternaria (Ullocladium)	-	-	-	-	-	-	-	-	-	-
Ascospores	1	40	8.2	-	-	-	-	-	-	-
Aspergillus/Penicillium	-	-	-	-	-	-	3	100	45.5	
Basidiospores	2	80	16.3	-	-	-	2	80	36.4	
Bipolaris++	-	-	-	-	-	-	-	-	-	-
Chaetomium	-	-	-	-	-	-	-	-	-	-
Cladosporium	8	300	61.2	-	-	-	1	40	18.2	
Curvularia	-	-	-	-	-	-	-	-	-	-
Epicoccum	2*	30*	6.1	-	-	-	-	-	-	-
Fusarium	-	-	-	-	-	-	-	-	-	-
Ganoderma	-	-	-	-	-	-	-	-	-	-
Myxomycetes++	1	40	8.2	1*	10*	100	-	-	-	-
Pithomyces++	-	-	-	-	-	-	-	-	-	-
Rust	-	-	-	-	-	-	-	-	-	-
Scopulariopsis/Microascus	-	-	-	-	-	-	-	-	-	-
Stachybotrys/Memnoniella	-	-	-	-	-	-	-	-	-	-
Unidentifiable Spores	-	-	-	-	-	-	-	-	-	-
Zygomycetes	-	-	-	-	-	-	-	-	-	-
<b>Total Fungi</b>	<b>14</b>	<b>490</b>	<b>100</b>	<b>1</b>	<b>10</b>	<b>100</b>	<b>6</b>	<b>220</b>	<b>100</b>	
Hyphal Fragment	-	-	-	-	-	-	-	-	-	-
Insect Fragment	-	-	-	-	-	-	-	-	-	-
Pollen	-	-	-	-	-	-	-	-	-	-
Analyt. Sensitivity 600x	-	42	-	-	42	-	-	42	-	-
Analyt. Sensitivity 300x	-	13*	-	-	13*	-	-	13*	-	-
Skin Fragments (1-4)	-	2	-	-	1	-	-	1	-	-
Fibrous Particulate (1-4)	-	1	-	-	1	-	-	1	-	-
Background (1-5)	-	1	-	-	1	-	-	1	-	-

++ Includes other spores with similar morphology; see EMSL's fungal glossary for each specific category.

Kevin Ream, Laboratory Manager  
or other Approved Signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted. High levels of background particulate can obscure spores and other particulates, leading to underestimation. Background levels of 5 indicate an overloading of background particulates, prohibiting accurate detection and quantification. Present = Spores detected on overloaded samples. Results are not blank corrected unless otherwise noted. The detection limit is equal to one fungal spore, structure, pollen, fiber particle or insect fragment. "\*" Denotes particles found at 300X. "-" Denotes not detected. Due to method stopping rules, raw counts in excess of 100 are extrapolated based on the percentage analyzed.  
Samples analyzed by EMSL Analytical, Inc. Plymouth Meeting, PA AIHA-LAP, LLC-EMLAP Accredited #178659

Initial report from: 12/17/2020 02:06 PM

For information on the fungi listed in this report, please visit the Resources section at [www.emsl.com](http://www.emsl.com)



# EMSL Analytical, Inc.

5221 Militia Hill Road Plymouth Meeting, PA 19462  
Tel/Fax: (610) 828-3102 / (610) 828-3122  
<http://www.EMSL.com> / [plymouthmeetinglab@emsl.com](mailto:plymouthmeetinglab@emsl.com)

**EMSL Order:** 182004045  
**Customer ID:** ATII25A  
**Customer PO:**  
**Project ID:**

**Attention:** Courtney McCall  
ATI  
4221 Forbes Blvd  
Suite 250  
Lanham, MD 20706  
**Project:** Hollywood ES 20-705

**Phone:** (202) 832-1433  
**Fax:**  
**Collected Date:** 12/09/2020  
**Received Date:** 12/10/2020 03:57 PM  
**Analyzed Date:** 12/17/2020

### Test Report: Air-O-Cell™ Analysis of Fungal Spores & Particulates by Optical Microscopy (Methods MICRO-SOP-201, ASTM D7391)

Lab Sample Number:	182004045-0007			182004045-0008			182004045-0009		
Client Sample ID:	3106-0662			3106-8858			3106-0573		
Volume (L):	75			75			75		
Sample Location:	Room 2			Room 18			Room 17		
Spore Types	Raw Count	Count/M <sup>3</sup>	% of Total	Raw Count	Count/M <sup>3</sup>	% of Total	Raw Count	Count/M <sup>3</sup>	% of Total
Alternaria (Ulocladium)	-	-	-	-	-	-	-	-	-
Ascospores	-	-	-	-	-	-	-	-	-
Aspergillus/Penicillium	-	-	-	1	40	20	-	-	-
Basidiospores	-	-	-	2	80	40	1	40	100
Bipolaris++	-	-	-	-	-	-	-	-	-
Chaetomium	-	-	-	-	-	-	-	-	-
Cladosporium	-	-	-	2	80	40	-	-	-
Curvularia	-	-	-	-	-	-	-	-	-
Epicoccum	-	-	-	-	-	-	-	-	-
Fusarium	-	-	-	-	-	-	-	-	-
Ganoderma	-	-	-	-	-	-	-	-	-
Myxomycetes++	1	40	100	-	-	-	-	-	-
Pithomyces++	-	-	-	-	-	-	-	-	-
Rust	-	-	-	-	-	-	-	-	-
Scopulariopsis/Microascus	-	-	-	-	-	-	-	-	-
Stachybotrys/Memnoniella	-	-	-	-	-	-	-	-	-
Unidentifiable Spores	-	-	-	-	-	-	-	-	-
Zygomycetes	-	-	-	-	-	-	-	-	-
<b>Total Fungi</b>	<b>1</b>	<b>40</b>	<b>100</b>	<b>5</b>	<b>200</b>	<b>100</b>	<b>1</b>	<b>40</b>	<b>100</b>
Hyphal Fragment	-	-	-	-	-	-	-	-	-
Insect Fragment	-	-	-	-	-	-	-	-	-
Pollen	-	-	-	-	-	-	-	-	-
Analyt. Sensitivity 600x	-	42	-	-	42	-	-	42	-
Analyt. Sensitivity 300x	-	13*	-	-	13*	-	-	13*	-
Skin Fragments (1-4)	-	2	-	-	2	-	-	2	-
Fibrous Particulate (1-4)	-	1	-	-	1	-	-	1	-
Background (1-5)	-	1	-	-	1	-	-	1	-

++ Includes other spores with similar morphology; see EMSL's fungal glossary for each specific category.

Kevin Ream, Laboratory Manager  
or other Approved Signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted. High levels of background particulate can obscure spores and other particulates, leading to underestimation. Background levels of 5 indicate an overloading of background particulates, prohibiting accurate detection and quantification. Present = Spores detected on overloaded samples. Results are not blank corrected unless otherwise noted. The detection limit is equal to one fungal spore, structure, pollen, fiber particle or insect fragment. "" Denotes particles found at 300X. "-" Denotes not detected. Due to method stopping rules, raw counts in excess of 100 are extrapolated based on the percentage analyzed.  
Samples analyzed by EMSL Analytical, Inc. Plymouth Meeting, PA AIHA-LAP, LLC-EMLAP Accredited #178659

Initial report from: 12/17/2020 02:06 PM

For information on the fungi listed in this report, please visit the Resources section at [www.emsl.com](http://www.emsl.com)



# EMSL Analytical, Inc.

5221 Militia Hill Road Plymouth Meeting, PA 19462  
Tel/Fax: (610) 828-3102 / (610) 828-3122  
<http://www.EMSL.com> / [plymouthmeetinglab@emsl.com](mailto:plymouthmeetinglab@emsl.com)

**EMSL Order:** 182004045  
**Customer ID:** ATII25A  
**Customer PO:**  
**Project ID:**

**Attention:** Courtney McCall  
ATI  
4221 Forbes Blvd  
Suite 250  
Lanham, MD 20706  
**Project:** Hollywood ES 20-705

**Phone:** (202) 832-1433  
**Fax:**  
**Collected Date:** 12/09/2020  
**Received Date:** 12/10/2020 03:57 PM  
**Analyzed Date:** 12/17/2020

### Test Report: Air-O-Cell™ Analysis of Fungal Spores & Particulates by Optical Microscopy (Methods MICRO-SOP-201, ASTM D7391)

<b>Lab Sample Number:</b>	182004045-0010		
<b>Client Sample ID:</b>	3106-0585		
<b>Volume (L):</b>			
<b>Sample Location:</b>	Field Blank		
<b>Spore Types</b>	<b>Raw Count</b>	<b>Count/M<sup>3</sup></b>	<b>% of Total</b>
Alternaria (Ulocladium)	-	-	-
Ascospores	-	-	-
Aspergillus/Penicillium	-	-	-
Basidiospores	-	-	-
Bipolaris++	-	-	-
Chaetomium	-	-	-
Cladosporium	-	-	-
Curvularia	-	-	-
Epicoccum	-	-	-
Fusarium	-	-	-
Ganoderma	-	-	-
Myxomycetes++	-	-	-
Pithomyces++	-	-	-
Rust	-	-	-
Scopulariopsis/Microascus	-	-	-
Stachybotrys/Memnoniella	-	-	-
Unidentifiable Spores	-	-	-
Zygomycetes	-	-	-
<b>Total Fungi</b>	-	<b>No Trace</b>	-
Hyphal Fragment	-	-	-
Insect Fragment	-	-	-
Pollen	-	-	-
Analyt. Sensitivity 600x	-	0	-
Analyt. Sensitivity 300x	-	0*	-
Skin Fragments (1-4)	-	-	-
Fibrous Particulate (1-4)	-	-	-
Background (1-5)	-	-	-

++ Includes other spores with similar morphology; see EMSL's fungal glossary for each specific category.

Kevin Ream, Laboratory Manager  
or other Approved Signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted. High levels of background particulate can obscure spores and other particulates, leading to underestimation. Background levels of 5 indicate an overloading of background particulates, prohibiting accurate detection and quantification. Present = Spores detected on overloaded samples. Results are not blank corrected unless otherwise noted. The detection limit is equal to one fungal spore, structure, pollen, fiber particle or insect fragment. "\*" Denotes particles found at 300X. "-" Denotes not detected. Due to method stopping rules, raw counts in excess of 100 are extrapolated based on the percentage analyzed.  
Samples analyzed by EMSL Analytical, Inc. Plymouth Meeting, PA AIHA-LAP, LLC-EMLAP Accredited #178659

Initial report from: 12/17/2020 02:06 PM

For information on the fungi listed in this report, please visit the Resources section at [www.emsl.com](http://www.emsl.com)





EMSL ANALYTICAL, INC.  
LABORATORY PRODUCTS TRAINING

# Microbiology Chain of Custody

EMSL Order Number (Lab Use Only)

**182004045**

EMSL ANALYTICAL, INC.  
200 ROUTE 130 NORTH  
CINNAMINSON, NJ 08077

PHONE: (800) 220-3675  
FAX: (856) 786-0262

Company: <b>ATI INC</b>		EMSL-Bill to: <input checked="" type="checkbox"/> Same <input type="checkbox"/> Different <small>If Bill to is Different note instructions in Comments**</small>	
Street: <b>4221 Forbes Blvd Suite 250</b>		<i>Third Party Billing requires written authorization from third party</i>	
City: <b>Lanham</b>	State/Province: <b>MD</b>	Zip/Postal Code: <b>20706</b>	Country: <b>USA</b>
Report To (Name): <b>Courtney McCall</b>		Telephone #: <b>703-399-5423</b>	
Email Address: <b>courtney@atiinc.com, samappriya@atiinc.com</b>		Fax #: <b>202-905-0335</b>	Purchase Order:
Project Name/Number: <b>Hollywood ES 20-705</b>		Please Provide Results: <input type="checkbox"/> Fax <input checked="" type="checkbox"/> Email <input type="checkbox"/> Fax	
U.S. State Samples Taken:		Connecticut Samples: <input type="checkbox"/> Commercial <input type="checkbox"/> Residential	

**Turnaround Time (TAT) Options\* - Please Check**

3 Hour  
  6 Hour  
  24 Hour  
  48 Hour  
  72 Hour  
  96 Hour  
  1 Week  
  2 Week

\*Analysis completed in accordance with EMSL's Terms and Conditions located in the Analytical Price Guide. TATs are subject to methodology requirements

**Non Culturable Air Samples (Spore Traps) - Test Codes**

- |                   |                   |                    |                     |                   |
|-------------------|-------------------|--------------------|---------------------|-------------------|
| • M001 Air-O-Cell | • M173 Allegro M2 | • M004 Allergenco  | • M032 Allergenco-D | • M172 Versa Trap |
| • M049 BioSIS     | • M003 Burkard    | • M043 Cyclex      | • M002 Cyclex-d     |                   |
| • M030 Micro 5    | • M174 MoldSnap   | • M176 Relle Smart | • M130 Via-Cell     |                   |

**Other Microbiology Test Codes**

- |  |   |  |
|--|---|--|
| • M041 Fungal Direct Examination                 | • M014 Endotoxin Analysis                               | • M029 Enterococci                                     |
| • M005 Viable Fungi ID and Count                 | • M015 Heterotrophic Plate Count                        | • M019 Fecal Coliform                                  |
| • M006 Viable Fungi ID and Count (Speciation)    | • M180 Real Time Q-PCR-ERMI 36                          | • M133 MRSA Analysis                                   |
| • M007 Culturable Fungi                          | • Panel   | • M028 <i>Cryptococcus neoformans</i> Detection        |
| • M008 Culturable Fungi (Speciation)             | • M018 Total Coliform (Membrane Filtration)             | • M120 <i>Histoplasma capsulatum</i> Detection         |
| • M009 Gram Stain Culturable Bacteria            | • M020 Fecal <i>Streptococcus</i> (Membrane Filtration) | • M033-39 Allergen Testing                             |
| • M010 Bacterial Count and ID - 3 Most Prominent | • M210-215 <i>Legionella</i> Detection                  | • M044 Group Allergen (Cat, Dog, Cockroach, Dustmites) |
| • M011 Bacterial Count and ID - 5 Most Prominent | • M026 Recreational Water Screen                        | • Other See Analytical Price Guide                     |
| • M013 Sewage Contamination in Buildings         | • M027 Mycotoxin Analysis                               |  |

**Preservation Method (Water):**

**Don Samappriya Wanigasundara**

Name of Sampler:

Signature of Sampler: *[Signature]*

Sample #	Sample Location	Sample Type	Test Code	Volume/Area	Date/Time Collected
Example: A1	Kitchen	Air	M001	75L	1/1/12 4:00 PM
3106-0589	Outside Exterior	Air	M001	75L	12/09/20 11:35AM
3106-0574	Gymnassim	Air	M001	75L	12/09/20 09:50AM
3106-0590	Main Office	Air	M001	75L	12/09/20 11:25AM
3106-0615	MPR	Air	M001	75L	12/09/20 10:05AM
3106-0578	Media Center	Air	M001	75L	12/09/20 10:15AM
3106-0588	Computer Lab	Air	M001	75L	12/09/20 10:55AM
3106-0662	Room 2	Air	M001	75L	12/09/20 10:40AM
3105-8858	Room 18	Air	M001	75L	12/09/20 10:30AM
3106-0573	Room 17	Air	M001	75L	12/08/20 10:05AM

Client Sample # (s):	-	Total # of Samples:	2020 DEC 10 PTO
Relinquished (Client): <i>[Signature]</i>	Date: <b>12/10/20</b>	Time:	RECEIVED EMSL ANALYTICAL, INC. BELTSVILLE, MD
Received (Client): <i>[Signature]</i>	Date:	Time:	2020 DEC 10 PTO
Comments:			



EMSL ANALYTICAL, INC.  
LABORATORY • PRODUCTS • TRAINING

# Microbiology Chain of Custody

EMSL Order Number (Lab Use Only):

**182004045**

EMSL ANALYTICAL, INC.  
200 ROUTE 130 NORTH  
CINNAMINSON, NJ 08077

PHONE: (800) 220-3675  
FAX: (856) 786-0262

*Additional Pages of the Chain of Custody are only necessary if needed for additional sample information*

Sample #	Sample Location	Sample Type	Test Code	Volume/Area	Date/Time Collected
3106-0585	Filed Blank	Air	M001	<i>Total Samples 10</i>	12/09/20
<b>**Comments/Special Instructions:</b>					



182004045

**EMSL Analytical, Inc.**  
**Sample Transfer Form**

<b>Receiving Lab:</b>	EMSL- BELTSVILLE	<b>Phone Number:</b>	3019375700
		<b>Fax Number:</b>	3019375701
<b>Relinquished to:</b>	EMSL- <i>Plymouth Mtg.</i>	<b>Phone Number:</b>	8002203675
		<b>Fax Number:</b>	8567860262
<b>Does new lab hold equivalent or additional accreditation? *</b>			<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
<b>EMSL Customer ID # (if known):</b>	ATI125A		
<b>Client Name:</b>	ATI INC		
<b>Client Project:</b>	HOLLYWOOD ES 20-705		
<b>Tests to be Performed:</b>	MOLD		
<b>Date Received:</b>	12/10/20		
<b>Date Relinquished:</b>	12/14/20		
<b>Date Due:</b>	1 WEEK - DUE 12/17		
<b>Special Instructions:</b> (e.g. Work Order # , required qualifications, project specific procedures/modifications)			
<b>Relinquished by (Signature):</b> <i>[Signature]</i>	<b>Date:</b> 12/14/20	<b>Received by (Signature):</b> <i>[Signature]</i>	<b>Date:</b> 12-15-20
<b>Relinquished by (Signature):</b>	<b>Date:</b>	<b>Received by (Signature):</b>	<b>Date:</b>
<b>Customer Agreement-</b> Please sign form and send to the receiving laboratory. By signing below, you agree to permit the above named receiving lab to transfer samples to a separate EMSL lab with equivalent qualifications* for analysis. The final report will be issued from the analyzing laboratory. Ensure any requirements are listed in special instructions.			
<b>Name (please print):</b>	<b>Signature:</b>	<b>Agent of:</b>	<b>Date:</b>
<i>If this is a recurring project or sample type that may require samples to be relinquished on a regular basis, a Standing Agreement form must be completed.</i>			

\* Receiving and analyzing labs shall be aware of required qualifications of project prior to transfer of samples.  
Note: If customer has been notified and approved this transfer verbally or by e-mail, the receiving lab must sign for the customer above. EMSL employee filling out form on behalf of customer shall print name of person to whom they spoke, date agreement was received, and then sign under Signature.

**Appendix B: Instrument Calibration Records**

# Certificate of Calibration

- (✓) Buck™ BioAire Pump Calibration Rotameter  
( ) Buck™ BioSlide Pump Calibration Rotameter

Serial number: R14535

Date Calibrated: 12/27/19

Calibration Due Date: 12/27/20

## Flow Calibration

This is to certify that the rotameter listed above has been calibrated using a Buck Primary calibrator listed below which is calibrated according to A.P. Buck, Inc. calibration procedure APB-1, Ver. 6.2 and is traceable to the National Institute of Standards & Technology (N.I.S.T). A.P. Buck guarantees the accuracy of the rotameter to be within  $\pm 5\%$  of the actual flow rate.

AMBIENT CONDITIONS: Temperature  $74\pm 3^{\circ}$  F Relative Humidity  $50\pm 10\%$

Description	MFR.	Model	Serial #
Primary Calibrator	A.P. Buck Inc.	M30B	<input type="checkbox"/> A40020 <input checked="" type="checkbox"/> A40021

QA Approval By: Moroni Went

Information contained in this document should not be reproduced in any form without the written consent of A.P. Buck, Inc. It is for reference only and cannot be used as a form of endorsement by any private or governmental regulatory body.

A.P. BUCK, INC.  
7101 Presidents Drive, Suite 110  
Orlando, FL 32809  
Phone: 407-851-8602  
Fax: 407-851-8910

**BUCK**  
A.P. BUCK, INC.



# CERTIFICATE OF CALIBRATION AND TESTING

TSI Incorporated, 500 Cardigan Road, Shoreview, MN 55126 USA  
Tel: 1-800-874-2811 1-651-490-2811 Fax: 1-651-490-3824 http://www.tsi.com

ENVIRONMENT CONDITIONS			MODEL	982
TEMPERATURE	75.8 (24.3)	°F (°C)	SERIAL NUMBER	P17100006
RELATIVE HUMIDITY	48	%RH		
BAROMETRIC PRESSURE	28.72 (972.6)	inHg (hPa)		

<input type="checkbox"/> AS LEFT	<input type="checkbox"/> IN TOLERANCE
<input checked="" type="checkbox"/> AS FOUND	<input checked="" type="checkbox"/> OUT OF TOLERANCE

## - CALIBRATION VERIFICATION RESULTS -

GAS CO <sub>2</sub> AS FOUND				SYSTEM G-101				Unit: ppm
#	STANDARD	MEASURED	ALLOWABLE RANGE	#	STANDARD	MEASURED	ALLOWABLE RANGE	
1	0	0	0~50	4	3020.5	* 2874.5	2929.9~3111.1	
2	504	460	454~554	5	5037	* 4771.8	4885.9~5188.1	
3	1008	964	958~1058					

GAS CO AS FOUND				SYSTEM G-101				Unit: ppm
#	STANDARD	MEASURED	ALLOWABLE RANGE	#	STANDARD	MEASURED	ALLOWABLE RANGE	
1	35.3	* 30.8	32.3~38.3	2	100.7	* 87.7	97.7~103.7	

TEMPERATURE AS FOUND				SYSTEM T-101				Unit: °F (°C)
#	STANDARD	MEASURED	ALLOWABLE RANGE	#	STANDARD	MEASURED	ALLOWABLE RANGE	
1	32.0 (0.0)	32.6 (0.3)	31.0~33.0 (-0.5~0.6)	2	139.8 (59.9)	140.6 (60.3)	138.8~140.8 (59.4~60.5)	

HUMIDITY AS FOUND				SYSTEM H-102				Unit: %RH
#	STANDARD	MEASURED	ALLOWABLE RANGE	#	STANDARD	MEASURED	ALLOWABLE RANGE	
1	10.0	10.5	7.0~13.0	4	70.0	69.6	67.0~73.0	
2	30.0	30.4	27.0~33.0	5	90.0	88.9	87.0~93.0	
3	50.0	50.4	47.0~53.0					

\*Indicates Out-of-Tolerance Condition

TSI does hereby certify that the above described instrument conforms to the original manufacturer's specification (not applicable to As Found data) and has been calibrated using standards whose accuracies are traceable to the United States National Institute of Standards and Technology (NIST) or has been verified with respect to instrumentation whose accuracy is traceable to NIST, or is derived from accepted values of physical constants. TSI's calibration system is registered to ISO-9001:2015.

Measurement Variable	System ID	Last Cal.	Cal. Due	Measurement Variable	System ID	Last Cal.	Cal. Due
5000 CO <sub>2</sub>	T-0660	07-15-20	07-15-28	200 CO	149848	03-24-20	03-24-28
N <sub>2</sub>	CT308798	06-28-20	06-28-28	Air	T608955	06-17-20	06-17-28
Flow	E003341	09-03-19	09-30-20	Flow	F003980	04-22-20	04-30-21
Flow	E003525	01-06-20	01-31-21	Flow	E003342	09-03-19	09-30-20
2000 C <sub>4</sub> H <sub>8</sub>	EB0054467	08-13-19	08-12-22	100 C <sub>4</sub> H <sub>8</sub>	CC507339	03-24-20	03-24-28
Temperature	E010657	02-14-20	02-28-21	Temperature	E010658	02-14-20	02-28-21
Temperture	E010655	01-21-20	01-31-21	Humidity	E003539	08-21-20	02-28-21

*ChaoVang*  
VERIFIED

August 31, 2020

DATE

Doc ID CERT\_GEN\_WCC



# CERTIFICATE OF CALIBRATION AND TESTING

TSI Incorporated, 500 Cardigan Road, Shoreview, MN 55126 USA  
Tel: 1-800-874-2811 1-651-490-2811 Fax: 1-651-490-3824 http://www.tsi.com

ENVIRONMENT CONDITIONS			MODEL	982
TEMPERATURE	71.33 (21.9)	°F (°C)	SERIAL NUMBER	P17100006
RELATIVE HUMIDITY	53.9	%RH		
BAROMETRIC PRESSURE	28.81 (975.6)	inHg (hPa)		

<input checked="" type="checkbox"/> AS LEFT	<input checked="" type="checkbox"/> IN TOLERANCE
<input type="checkbox"/> AS FOUND	<input type="checkbox"/> OUT OF TOLERANCE

## - CALIBRATION VERIFICATION RESULTS -

TEMPERATURE VERIFICATION				SYSTEM T-101			Unit: °F (°C)
#	STANDARD	MEASURED	ALLOWABLE RANGE	#	STANDARD	MEASURED	ALLOWABLE RANGE
1	32.0 (0.0)	32.6 (0.3)	31.0-33.0 (-0.5-0.6)	2	139.8 (59.9)	140.6 (60.3)	138.8-140.8 (59.4-60.5)

HUMIDITY VERIFICATION				SYSTEM H-102			Unit: %RH
#	STANDARD	MEASURED	ALLOWABLE RANGE	#	STANDARD	MEASURED	ALLOWABLE RANGE
1	10.0	10.5	7.0-13.0	4	70.0	69.6	67.0-73.0
2	30.0	30.4	27.0-33.0	5	90.0	88.9	87.0-93.0
3	50.0	50.4	47.0-53.0				

CO2 GAS VERIFICATION				SYSTEM G-101			Unit: ppm
#	STANDARD	MEASURED	ALLOWABLE RANGE	#	STANDARD	MEASURED	ALLOWABLE RANGE
1	0	0	0-50	4	3020	3025	2929-3110
2	504	501	454-554	5	5037	5026	4886-5188
3	1008	1027	958-1058				

CO GAS VERIFICATION				SYSTEM G-101			Unit: ppm
#	STANDARD	MEASURED	ALLOWABLE RANGE	#	STANDARD	MEASURED	ALLOWABLE RANGE
1	35	36	32-38	2	101	100	98-104

TSI does hereby certify that the above described instrument conforms to the original manufacturer's specification (not applicable to As Found data) and has been calibrated using standards whose accuracies are traceable to the United States National Institute of Standards and Technology (NIST) or has been verified with respect to instrumentation whose accuracy is traceable to NIST, or is derived from accepted values of physical constants. TSI's calibration system is registered to ISO-9001:2015.

Measurement Variable	System ID	Last Cal.	Cal. Due	Measurement Variable	System ID	Last Cal.	Cal. Due
Temperature	E010657	02-14-20	02-28-21	Temperature	E010658	02-14-20	02-28-21
Temperature	E010655	01-21-20	01-31-21	Humidity	E003539	08-21-20	02-28-21
5000 CO2	T-0660	07-15-20	07-15-28	200 CO	149848	03-24-20	03-24-28
N2	CT308798	06-28-20	06-28-28	Air	T608955	06-17-20	06-17-28
Flow	E003341	09-03-19	09-30-20	Flow	E003980	04-22-20	04-30-21
Flow	E003525	01-06-20	01-31-21	Flow	E003342	09-03-19	09-30-20
2000 C4H8	EB0054467	08-13-19	08-12-22	100 C4H8	CC507339	03-24-20	03-24-28

*Baw yary*

CALIBRATED

August 31, 2020

DATE

Doc. ID. CERT\_GEN\_WCC



# CERTIFICATE OF CALIBRATION AND TESTING

TSI Incorporated, 500 Cardigan Road, Shoreview, MN 55126 USA  
 Tel: 1-800-874-2811 1-651-490-2811 Fax: 1-651-490-3824 http://www.tsi.com

ENVIRONMENT CONDITIONS			MODEL		<b>7575-X</b>
TEMPERATURE	71.33 (21.9)	°F (°C)	SERIAL NUMBER		<b>7575X1711004</b>
RELATIVE HUMIDITY	53.9	%RH			
BAROMETRIC PRESSURE	28.81 (975.6)	inHg (hPa)			

AS LEFT     IN TOLERANCE  
 AS FOUND     OUT OF TOLERANCE

## - CALIBRATION VERIFICATION RESULTS -

THERMO COUPLE				SYSTEM PRESSURE01-02				Unit: °F (°C)
#	STANDARD	MEASURED	ALLOWABLE RANGE	#	STANDARD	MEASURED	ALLOWABLE RANGE	
1	70.9 (21.6)	71.1 (21.7)	68.9-72.9 (20.5-22.7)					

BAROMETRIC PRESSURE				SYSTEM PRESSURE01-02				Unit: inHg ( hPa )
#	STANDARD	MEASURED	ALLOWABLE RANGE	#	STANDARD	MEASURED	ALLOWABLE RANGE	
1	28.82 (976.0)	28.82 (976.0)	28.24-29.40 (956.3-995.6)					

*TSI does hereby certify that the above described instrument conforms to the original manufacturer's specification (not applicable to As Found data) and has been calibrated using standards whose accuracies are traceable to the United States National Institute of Standards and Technology (NIST) or has been verified with respect to instrumentation whose accuracy is traceable to NIST, or is derived from accepted values of physical constants. TSI's calibration system is registered to ISO-9001:2015.*

<u>Measurement Variable</u>	<u>System ID</u>	<u>Last Cal.</u>	<u>Cal. Due</u>		<u>Measurement Variable</u>	<u>System ID</u>	<u>Last Cal.</u>	<u>Cal. Due</u>
Temperature	E004626	02-14-20	02-28-21		Pressure	E005254	10-10-19	10-31-20
Pressure	E003982	07-21-20	01-31-21		DC Voltage	E003493	06-17-20	06-30-21

K. Ouef

\_\_\_\_\_  
CALIBRATED

August 31, 2020  
\_\_\_\_\_  
DATE

Doc. ID: CERT\_GEN\_WCC





# CERTIFICATE OF CALIBRATION AND TESTING

TSI Incorporated, 500 Cardigan Road, Shoreview, MN 55126 USA  
Tel: 1-800-874-2811 1-651-490-2811 Fax: 1-651-490-3824 http://www.tsi.com

ENVIRONMENT CONDITIONS			MODEL	<b>7575-X</b>
TEMPERATURE	71.24 (21.8)	°F (°C)	SERIAL NUMBER	<b>7575X1711004</b>
RELATIVE HUMIDITY	54.8	%RH		
BAROMETRIC PRESSURE	28.74 (973.2)	inHg (hPa)		

<input type="checkbox"/> AS LEFT	<input checked="" type="checkbox"/> IN TOLERANCE
<input checked="" type="checkbox"/> AS FOUND	<input type="checkbox"/> OUT OF TOLERANCE

### - CALIBRATION VERIFICATION RESULTS -

THERMO COUPLE			SYSTEM PRESSURE01-02			Unit: °F (°C)	
#	STANDARD	MEASURED	ALLOWABLE RANGE	#	STANDARD	MEASURED	ALLOWABLE RANGE
1	70.8 (21.6)	70.5 (21.4)	68.8-72.8 (20.4-22.7)				

BAROMETRIC PRESSURE			SYSTEM PRESSURE01-02			Unit: inHg (hPa)	
#	STANDARD	MEASURED	ALLOWABLE RANGE	#	STANDARD	MEASURED	ALLOWABLE RANGE
1	28.75 (973.6)	28.84 (976.6)	28.17-29.33 (953.9-993.2)				

TSI does hereby certify that the above described instrument conforms to the original manufacturer's specification (not applicable to As Found data) and has been calibrated using standards whose accuracies are traceable to the United States National Institute of Standards and Technology (NIST) or has been verified with respect to instrumentation whose accuracy is traceable to NIST, or is derived from accepted values of physical constants. TSI's calibration system is registered to ISO-9001:2015.

Measurement Variable	System ID	Last Cal.	Cal. Due	Measurement Variable	System ID	Last Cal.	Cal. Due
Temperature	E004626	02-14-20	02-28-21	Pressure	E005254	10-10-19	10-31-20
Pressure	E003982	07-21-20	01-31-21	DC Voltage	E003493	06-17-20	06-30-21

*Va Cuef*  
VERIFIED

August 31, 2020

DATE

Doc. ID: CERT\_GEN\_WCC