



January 13, 2021

Mr. Alex Baylor  
Environmental Specialist  
Environmental Safety Office  
Prince George's County Public Schools  
Division of Supporting Services / Building Services  
13306 Old Marlboro Pike  
Upper Marlboro, MD 20772

via email: [alex.baylor@pgcps.org](mailto:alex.baylor@pgcps.org)

**RE: Indoor Air Quality (IAQ) and Mold Assessment Services  
Prince George's County Public Schools (PGCPS) – Kenmoor Elementary School  
3211 82<sup>nd</sup> Avenue, Landover, Maryland 20785  
Contract No.: IFB 022-19: Indoor Air Quality Services at Various Locations  
Tidewater Project No.: 5419-031**

Dear Mr. Baylor:

Tidewater, Inc. (Tidewater) is pleased to present this report regarding the results of the preliminary Indoor Air Quality (IAQ) and Mold Assessment Services conducted by Tidewater at Kenmoor Elementary School located at 3211 82<sup>nd</sup> Avenue in Landover, Maryland. These services were conducted on November 30, 2020, by Tidewater's Project Manager and Certified Industrial Hygienist, Mr. Skanda Abeysekere MS, CIH, CSP, CHMM.

The scope of work for the IAQ assessment and mold survey included:

- Inspecting, taking direct read measurements and conducting air sampling at the following select areas of the school: Multipurpose Room, Main Office, Media Center, Classroom 10, Classroom 5, Classroom 2, Classroom 15, Classroom 16, Classroom 17 and Classroom 22. These areas were inspected for evidence of potential indoor air quality problems (including suspect microbial growth, water damage, chemical use/ storage, drain traps, sources of allergens/ contaminants, etc.) that may contribute to indoor air quality problems;
- Taking direct read air measurements for comfort parameters including temperature (T), relative humidity (RH), carbon dioxide (CO<sub>2</sub>), and carbon monoxide (CO) for comparison with standards established by the American Society of Heating, Refrigerating and Air-Conditioning Engineers (ASHRAE) Standard 62.1–2019, *Ventilation for Acceptable Indoor Air Quality*, and The United States Environmental Protection Agency (US EPA) National Ambient Air Quality Standards (NAAQS);
- Taking direct read measurements for Particulate Matter less than 10 microns (PM<sub>10</sub>) for comparison with standards established by the US EPA NAAQS Final Action (December 7, 2020); and
- Conducting air sampling for microbial spores for total airborne fungal spore analysis.

## **Visual Observation**

Due to the on-going COVID-19 pandemic, the school building was occupied by a limited number of staff and no students were present at the time of the survey. The majority of the classrooms and other common areas inspected were vacant. The results of Tidewater's visual inspection are presented below.:

### **Multipurpose Room**

Six (6) ceiling-mounted air diffusers were operating and were emitting warm air at the time of the inspection. Furthermore, the multipurpose room was equipped with four (4) window-mounted air conditioning units which were not in operation. No signs of ongoing water-intrusion problems were observed and no notable odors were detected. Boxes and bags of student supplies were stored in the multi-purpose room at various locations.

### **Main Office**

The Main Office appeared to be clean and well maintained. Housekeeping appeared to be satisfactory. No signs of ongoing water-intrusion problems were observed and no odors were detected. Wall-mounted fan coil units were in operation and were emitting warm air at the time of the inspection. Two (2) occupants were present in the main office at the time of the inspection.

### **Media Center**

Two (2) wall-mounted fan coil units and two (2) window-mounted air conditioning units were observed in the Media Center. None of these units were in operation at the time of the inspection. A return air grill and a supply grill were also located on the walls of the media center. The grills appeared clean with no accumulated dust. Furthermore, no mold growth nor notable odors were detected in the Media Center. Housekeeping appeared to be satisfactory.

### **Classroom 10**

No signs of ongoing water-intrusion problems were observed in the classroom and no odors were detected. The return air and supply grills located on the walls of the classroom appeared clean. The supply grills of the window-mounted air conditioning unit appeared to have dust accumulations. The wall-mounted fan coil unit was not in operation at the time of the inspection.

### **Classroom 5**

No signs of past or ongoing water-intrusion problems were observed in Classroom 5. Furthermore, no mold growth nor notable odors were detected. The wall-mounted fan coil units were operating at the time of the inspection and was emitting warm air. The return air and supply grills located on the walls of the classroom appeared to be clean.

### **Classroom 2**

No signs of ongoing water-intrusion problems were observed in the classroom and no odors were detected. However, a missing ceiling tile and a water-stained ceiling tile were observed in the hallway in front of Classroom 2. One (1) window-mounted air conditioning unit and two (2) wall-mounted fan coil unit were also observed in the classroom. The fan coil units were in operation and were emitting warm air at the time of the inspection. The classroom appeared to be clean and well maintained. Housekeeping appeared to be satisfactory.

**Classroom 15**

No signs of past or ongoing water-intrusion problems were observed in Classroom 15. Furthermore, no mold growth nor notable odors were detected. Numerous wall-mounted fan coil units and a window mounted air conditioning unit were observed in the classroom. The supply grill located on the walls of the classroom appeared to be clean. The classroom appeared to be clean and well maintained. Housekeeping appeared to be satisfactory.

**Computer room 16**

No signs of ongoing water-intrusion problems were observed in Classroom 16 and no notable odors were detected. The wall-mounted fan coil units were in operation at the time of the inspection. A window mounted air conditioning unit was also observed in the classroom. The supply grill located on the walls of the classroom appeared to be clean.

**Classroom 22**

No signs of ongoing water-intrusion problems were observed in the classroom and no notable odors were detected. Numerous wall-mounted fan coil units were in operation and were emitting warm air at the time of the inspection. A window mounted air conditioning unit was observed in the classroom. Two (2) wall-mounted supply and return air grills were also observed on the walls. The perimeter of these supply and return air grills appeared to have dust accumulations.

**Classroom 17**

The classroom appeared to be clean and well maintained. No signs of ongoing water-intrusion problems were observed in the classroom and no notable odors were detected. Multiple wall-mounted fan coil units were in operation and were emitting warm air at the time of the inspection. The supply grills of the window-mounted air conditioning unit and the perimeter of the wall-mounted supply grills appeared to have dust accumulations.

**Comfort Parameter Air Testing**

During the IAQ assessment, Tidewater obtained temperature (T), relative humidity (RH), carbon dioxide (CO<sub>2</sub>), and carbon monoxide (CO) measurements within select locations using a TSI VelociCalc Indoor Air Quality instrument (Model Number 9565-X, Serial Number 9565X 1945 002, Calibration Date: November 8, 2019.) Measurements were taken after allowing the instrument to become acclimated to the ambient temperature and relative humidity for approximately five (5) minutes. Measurements were taken over a 5-minute time period at each designated location, and the average concentration was recorded. The results were compared to the standards established by the American Society for Heating Refrigeration and Air Conditioning (ASHRAE) Standard 62.1 – 2019, *Ventilation for Acceptable Indoor Air Quality*. Tidewater also obtained “outdoor background” measurement at the front of the main entrance of the school building for comparison to the interior readings. The results of the IAQ comfort parameter monitoring are provided in Table 1, in **Attachment A**.

According to the American Society for Heating, Refrigerating and Air Conditioning Engineers (ASHRAE) Standard 62.1 – 2019, *Ventilation for Acceptable Indoor Air Quality*, the temperature range in summer months should be maintained between 73.0°F and 79.0°F for maximum occupant comfort. The ASHRAE standard for temperature for winter months is between 68.0°F and 74.5°F. The indoor temperature levels within the assessed areas on November 30, 2020 ranged between 71.7°F and 75.0°F. The background temperature outside the building was



69.0°F. The temperature levels recorded within most areas monitored were within the temperature levels typically observed during the fall-winter transitional period. The temperature levels in the main office was marginally above the upper temperature levels of 74.5°F recommended by ASHRAE for winter months. The main office had 2 occupants present at the time of the inspection. Most areas inspected were vacant at the time of the inspection. Indoor temperature levels fluctuate with the number of occupants present within the work area.

Per the same ASHRAE standard, a maximum relative humidity level of 65.0% or below is recommended to reduce the likelihood of condensation on cold surfaces. Relative humidity levels within the assessed areas on November 30, 2020 ranged between 43.7% and 60.3%. The background relative humidity level outside the building was 70.4%. The relative humidity levels in all areas assessed were below the ASHRAE recommended maximum relative humidity standard of 65.0%.

ASHRAE Standard 62.1 – 2019 recommends that indoor CO<sub>2</sub> levels not exceed 700 ppm above the outdoor background CO<sub>2</sub> level. The CO<sub>2</sub> levels in the assessed areas on November 30, 2020 ranged between 438 ppm to 618 ppm. The background CO<sub>2</sub> level outside the building was 416 ppm. The CO<sub>2</sub> levels within all interior locations assessed did not exceed 700 ppm above the outdoor background CO<sub>2</sub> level of 416 ppm.

The CO levels in all areas assessed on November 30, 2020 were below the maximum standard of 9.0 ppm recommended by the Indoor Air Quality Association (IAQA) for CO in occupied indoor environments.

### **Particulate Matter Less Than 10 microns (PM10)**

During the assessment, Tidewater obtained particulate matter less than 10 microns (PM10) dust particulate measurements at select locations using a TSI® DUST TRAK II™ Aerosol Monitor (Model 8534, Serial Number 8534170101.) Measurements were taken after allowing the device to become acclimated to the ambient temperature and relative humidity for five (5) minutes. Measurements were taken over a 5-minute time period at each sampling location and the average concentration was recorded for comparison with standards established by the US EPA NAAQS Final Action (December 7, 2020.)

Tidewater also obtained an outdoors background sample in front of the main entrance of the school building for comparison to the interior readings.

The results of the particulate matter sampling are provided in Table 2, in **Attachment A**.

Based on the EPA NAAQS for Particulate Matter, Final Action (December 7, 2020), the 24-hour primary and secondary exposure standard for particulate matter less than 10 microns (PM10) is 150.0 micrograms per cubic meter of air ( $\mu\text{g}/\text{m}^3$ ) or 0.150 milligrams per cubic meter of air ( $\text{mg}/\text{m}^3$ .) The results of the PM10 analysis indicate that the average PM10 dust concentrations in all assessed areas ranged between 0.069  $\text{mg}/\text{m}^3$  and 0.082  $\text{mg}/\text{m}^3$ . The average PM10 dust concentration in the background sample obtained in front of the main entrance was 0.072  $\text{mg}/\text{m}^3$ . The PM10 concentrations in all areas assessed were below the EPA 24-hour primary and secondary NAAQS of 0.150  $\text{mg}/\text{m}^3$ .



### **Spore Trap Bioaerosol Sampling**

Tidewater collected spore trap air samples from the same locations where the comfort parameters were recorded. Tidewater obtained the spore trap samples using Allergenco-D cassettes affixed to a Buck BioAire™ Bioaerosol Sampling Pump (Pump Model Number B520 and Serial Number B153043) calibrated to a flow rate of 15.0 Liters per minute. Each sample was run for a period of five (5) minutes to collect a total sample volume of 75.0 liters of air. Tidewater also obtained an outdoor background sample in front of the main entrance of the school building for comparison to the interior readings.

Once collected, the samples were transported to EMSL Analytical Laboratory (EMSL) located in Beltsville, Maryland for analysis via a standard turn-around time. The samples were transported following rigorous chain-of-custody guidelines to ensure proper handling and delivery of the samples. EMSL is accredited in the American Industrial Hygiene Association (AIHA) Environmental Microbiology Laboratory Accreditation Program (EMLAP) and is a successful participant in AIHA's Environmental Microbiology Proficiency Analytical Testing (EMPAT) program (Laboratory Number 102891.) The samples were analyzed via light microscopy at the standardized magnification of 600X. This technique does not allow for the differentiation between *Aspergillus* and *Penicillium* spores because they are morphologically identical. Additionally, the technique does not allow for cultivation, or the identification of spores to the species level, except in a few cases.

There are no universally accepted federal or State of Maryland standards for acceptable airborne concentrations of bioaerosols in an indoor occupational environment. In general, indoor airborne concentrations should be less than that found in the outdoor air, with similar species composition. Indoor spore counts significantly greater than those outdoors, or the presence of large numbers of different types of spores indoors that are not found outdoors, may indicate contamination and potential indoor air quality problems.

The total mold spore counts in all assessed areas of the school ranged between 1,350 spores/m<sup>3</sup> and 31,400 spores/m<sup>3</sup>. The total mold spore concentrations in the background sample obtained outdoors was 47,410 spores/m<sup>3</sup>. The total mold spore concentrations in all indoor samples were below the background sample concentration of 47,410 spores/m<sup>3</sup> (sample # KES-BG.) Additionally, the fungal species observed in the interior samples were consistent with those observed in the background sample, and no significant concentrations of an individual fungal species were identified in the interior samples. These results do not indicate elevated levels of airborne total fungal spores in the interior locations sampled, nor suggest the presence of potential significant sources of indoor fungi in the interior locations sampled.

The summary of the results for the spore trap sampling are provided in Table 3 in **Attachment A**. The laboratory analytical results, including speciation and chain of custody forms for the spore trap samples are included in **Attachment B**.



## **CONCLUSIONS**

- The follow issues were identified during the visual inspections:
  - Classroom 10 and Classroom 17: The supply grills of the window-mounted air conditioning units appeared to have dust accumulations.
  - Classroom 2: A missing ceiling tile and a water-stained ceiling tile were observed in the hallway in front of Classroom.
  - Classroom 22 and Classroom 17: The perimeter of the supply and return air grills located on the walls of these classrooms appeared to have dust accumulations.
- Temperature levels recorded within majority of the interior locations assessed, were within ASHRAE Standard 62.1 – 2019 of 68.0°F and 74.5°F recommended for winter months. The temperature levels in the main office marginally exceeded the upper temperature levels of 74.5°F recommended by ASHRAE for winter months.
- The Relative humidity, CO<sub>2</sub>, CO readings and particulate matter less than 10 microns (PM10) recorded within the assessed areas were within industry standards and guidelines;
- The total mold spore concentrations in all interior locations sampled were below the background sample concentration and were also consistent with those observed in the background sample. The results do not indicate elevated levels of airborne total fungal spores in the interior locations sampled.

## **RECOMMENDATIONS**

Based on the results of our visual inspection, Tidewater proposes the following:

- Clean the supply grills of the window-mounted air conditioning units in Classroom 10 and Classroom 17 with a commercially available (EPA approved) disinfectant on a routine basis to remove dust deposits.
- Investigate the drop ceiling above the water-stained ceiling tile in the hallway outside Classroom 2 for any ongoing water leaks. If any ongoing water leaks are detected, take immediate action to repair them. Remove the water-stained ceiling tile and replace with new ceiling tile. Also replace all other missing ceiling tiles in this area.
- Ensure the Heating Ventilation and Air Conditioning (HVAC) System supplying air to all common areas and classrooms is properly balanced per design requirements and are turned on and are operating at all times to ensure adequate ventilation throughout the classrooms and common areas before the school re-opens.
- Maintain good housekeeping practices in all common areas and classrooms. All common area and classrooms floors should be broom cleaned at the end of each day once the school re-opens for students. Furthermore, all horizontal surfaces including desktops, furniture, window sills, and light fixtures should be cleaned on a routine basis to prevent the accumulation of dust;



**Qualifications**

Tidewater conducted an air quality and mold assessment of Kenmoor Elementary School located at 3211 82<sup>nd</sup> Avenue in Landover Maryland. Our conclusions and recommendations are based on observations made on the day of our assessment, laboratory data from the time of the assessment, and information provided by both our Client and the area occupants. Actual conditions vary from day to day throughout the year.

Tidewater appreciates the opportunity to provide Industrial Hygiene consulting services for Prince Georges County Public Schools. Please contact us should any questions arise concerning this report or if we may be of further assistance.

Sincerely,

*Tidewater, Inc.*

Skanda Abeyesekere, MS, CIH, CSP, CHMM  
Project Manager

Jonathan N. Schatz, MS, CES, CEI  
Manager, IH Services

SA/JNS

- Attachments: **Attachment A – Summary of Comfort Parameters, PM10 Particulate Dust, and Microbial Results**  
**Attachment B – Laboratory Reports and Chain of Custody Forms**  
**Attachment C – Instrument Calibration Certificates**  
**Attachment D – Relevant Certifications**  
**Attachment E – Floor Plan with Sampling Locations**



**APPENDIX A**

**COMFORT PARAMETERS, PM10 PARTICULATE DUST, AND  
MICROBIAL RESULTS**





<b>Table 1: Indoor Air Quality Comfort Parameters Kenmoor Elementary School</b>				
<b>Location</b>	<b>Temperature (°F)</b>	<b>Carbon Dioxide (ppm)</b>	<b>Relative Humidity (%)</b>	<b>Carbon Monoxide (ppm)</b>
<b>November 30, 2020</b>				
Multi-purpose Room	71.8	60.3	438	0.0
Main Office	<b>75.0</b>	55.3	618	0.1
Media Center	73.6	54.2	449	0.0
Classroom 10	74.5	53.6	447	0.0
Classroom 5	73.7	55.2	452	0.0
Classroom 2	73.6	56.2	446	0.0
Classroom 15	71.7	59.5	466	0.0
Classroom 16	73.7	55.1	444	0.0
Classroom 22	72.8	43.9	447	0.0
Classroom 17	73.7	43.7	447	0.0
Background (Outdoors)	69.0	70.4	416	0.0

\*Highlighted Areas indicate locations in which temperature levels were above the American Society for Heating Refrigeration and Air Conditioning (ASHRAE) Standard 62.1 – 2019 recommended standards for winter months.



<b>Table 2: Particulate Matter Less than 10 Microns (PM10) Kenmoor Elementary School</b>	
<b>Location</b>	<b>Particulate Matter (PM10)</b>
	<b>Concentration (mg/m<sup>3</sup>)</b>
<b>November 30, 2020</b>	
Multi-purpose Room	0.069
Main Office	0.072
Media Center	0.071
Classroom 10	0.076
Classroom 5	0.074
Classroom 2	0.077
Classroom 15	0.082
Classroom 16	0.077
Classroom 22	0.074
Classroom 17	0.070
Background (Outdoors)	0.072



<b>Table 3: Spore Trap Sampling Results Kenmoor Elementary School</b>				
<b>November 30, 2020</b>				
<b>Sample Number</b>	<b>Sample Location</b>	<b>Sample Volume (L)</b>	<b><i>Aspergillus Penicillium</i> Concentration (Counts/m<sup>3</sup>)</b>	<b>Total Fungi Concentration (Counts/m<sup>3</sup>)</b>
KES-1	Multi-purpose Room	75.0	200	31,400
KES-2	Main Office	75.0	300	28,340
KES-3	Media Center	75.0	ND	19,120
KES-4	Classroom 10	75.0	200	30,260
KES-5	Classroom 5	75.0	100	30,180
KES-6	Classroom 2	75.0	NA*	NA*
KES-7	Classroom 15	75.0	550	28,940
KES-8	Classroom 16	75.0	80	14,020
KES-9	Classroom 22	75.0	ND	1,350
KES-10	Classroom 17	75.0	200	8,220
KES-BG	Background	75.0	200	47,410

NA\* - Slide for Cassette KES-6 was missing due to manufacturing error.



**APPENDIX B**

**LABORATORY REPORTS AND CHAIN OF CUSTODY FORMS**



# EMSL Analytical, Inc.

10768 Baltimore Avenue Beltsville, MD 20705

Tel/Fax: (301) 937-5700 / (301) 937-5701

http://www.EMSL.com / beltsvillelab@emsl.com

EMSL Order: 192011891

Customer ID: TIDE50

Customer PO:

Project ID:

**Attention:** Skanda Abeyeskere  
Tidewater, Inc.  
6625 Selnick Drive  
Suite A  
Elkridge, MD 21075

**Phone:** (410) 540-8700

**Fax:** (410) 997-8713

**Collected Date:** 11/30/2020

**Received Date:** 12/02/2020

**Analyzed Date:** 12/14/2020

**Project:** Kenmoor ES

### Test Report: Allergenco-D™ Analysis of Fungal Spores & Particulates by Optical Microscopy (Methods MICRO-SOP-201, ASTM D7391)

Lab Sample Number:	192011891-0001			192011891-0002			192011891-0003		
Client Sample ID:	KES-1			KES-2			KES-3		
Volume (L):	75			75			75		
Sample Location:	Multipurpose room			Main office			Media center		
Spore Types	Raw Count	Count/m <sup>3</sup>	% of Total	Raw Count	Count/m <sup>3</sup>	% of Total	Raw Count	Count/m <sup>3</sup>	% of Total
Alternaria (Ulocladium)	-	-	-	1*	10*	0	3	100	0.5
Ascospores	9	400	1.3	4	200	0.7	4	200	1
Aspergillus/Penicillium	5	200	0.6	6	300	1.1	-	-	-
Basidiospores	722	30500	97.1	650	27400	96.7	433	18300	95.7
Bipolaris++	-	-	-	-	-	-	-	-	-
Chaetomium	-	-	-	-	-	-	-	-	-
Cladosporium	6	300	1	10	420	1.5	7	300	1.6
Curvularia	-	-	-	-	-	-	3	100	0.5
Epicoccum	-	-	-	-	-	-	1	40	0.2
Fusarium	-	-	-	-	-	-	-	-	-
Ganoderma	-	-	-	-	-	-	-	-	-
Myxomycetes++	-	-	-	1*	10*	0	2	80	0.4
Pithomyces++	-	-	-	-	-	-	-	-	-
Rust	-	-	-	-	-	-	-	-	-
Scopulariopsis/Microascus	-	-	-	-	-	-	-	-	-
Stachybotrys/Memnoniella	-	-	-	-	-	-	-	-	-
Unidentifiable Spores	-	-	-	-	-	-	-	-	-
Zygomycetes	-	-	-	-	-	-	-	-	-
<b>Total Fungi</b>	<b>742</b>	<b>31400</b>	<b>100</b>	<b>672</b>	<b>28340</b>	<b>100</b>	<b>453</b>	<b>19120</b>	<b>100</b>
Hyphal Fragment	-	-	-	2	80	-	1	40	-
Insect Fragment	-	-	-	-	-	-	-	-	-
Pollen	-	-	-	1*	10*	-	-	-	-
Analyt. Sensitivity 600x	-	42	-	-	42	-	-	42	-
Analyt. Sensitivity 300x	-	13*	-	-	13*	-	-	13*	-
Skin Fragments (1-4)	-	1	-	-	2	-	-	1	-
Fibrous Particulate (1-4)	-	1	-	-	1	-	-	1	-
Background (1-5)	-	1	-	-	1	-	-	1	-

**Report Comment:** Slide for KES-6 cassette missing due to manufacturing error

++ Includes other spores with similar morphology; see EMSL's fungal glossary for each specific category.

Abubakar Barry, Microbiology Lab Manager  
or other Approved Signatory

No discernable field blank was submitted with this group of samples.

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted. High levels of background particulate can obscure spores and other particulates, leading to underestimation. Background levels of 5 indicate an overloading of background particulates, prohibiting accurate detection and quantification. Present = Spores detected on overloaded samples. Results are not blank corrected unless otherwise noted. The detection limit is equal to one fungal spore, structure, pollen, fiber particle or insect fragment. "\*" Denotes particles found at 300X. "-" Denotes not detected. Due to method stopping rules, raw counts in excess of 100 are extrapolated based on the percentage analyzed.

Samples analyzed by EMSL Analytical, Inc. Beltsville, MD AIHA-LAP, LLC-EMLAP Accredited #102891

Initial report from: 12/15/2020 10:53 AM

For information on the fungi listed in this report, please visit the Resources section at [www.emsl.com](http://www.emsl.com)



# EMSL Analytical, Inc.

10768 Baltimore Avenue Beltsville, MD 20705

Tel/Fax: (301) 937-5700 / (301) 937-5701

http://www.EMSL.com / beltsvillelab@emsl.com

EMSL Order: 192011891

Customer ID: TIDE50

Customer PO:

Project ID:

**Attention:** Skanda Abeyeskere  
Tidewater, Inc.  
6625 Selnick Drive  
Suite A  
Elkridge, MD 21075

**Project:** Kenmoor ES

**Phone:** (410) 540-8700

**Fax:** (410) 997-8713

**Collected Date:** 11/30/2020

**Received Date:** 12/02/2020

**Analyzed Date:** 12/14/2020

### Test Report: Allergenco-D(™) Analysis of Fungal Spores & Particulates by Optical Microscopy (Methods MICRO-SOP-201, ASTM D7391)

Lab Sample Number:	192011891-0004			192011891-0005			192011891-0007		
Client Sample ID:	KES-4			KES-5			KES-7		
Volume (L):	75			75			75		
Sample Location:	Classroom 10			Classroom 5			Classroom 15		
Spore Types	Raw Count	Count/m <sup>3</sup>	% of Total	Raw Count	Count/m <sup>3</sup>	% of Total	Raw Count	Count/m <sup>3</sup>	% of Total
Alternaria (Ulocladium)	-	-	-	1	40	0.1	-	-	-
Ascospores	11	460	1.5	13	550	1.8	9	400	1.4
Aspergillus/Penicillium	5	200	0.7	3	100	0.3	13	550	1.9
Basidiospores	696	29400	97.2	650	27400	90.8	650	27400	94.7
Bipolaris++	-	-	-	1	40	0.1	-	-	-
Chaetomium	-	-	-	-	-	-	-	-	-
Cladosporium	5	200	0.7	39	1600	5.3	13	550	1.9
Curvularia	-	-	-	1	40	0.1	-	-	-
Epicoccum	-	-	-	4*	50*	0.2	-	-	-
Fusarium	-	-	-	-	-	-	-	-	-
Ganoderma	-	-	-	1	40	0.1	-	-	-
Myxomycetes++	-	-	-	4	200	0.7	3*	40*	0.1
Pithomyces++	-	-	-	1	40	0.1	-	-	-
Rust	-	-	-	2	80	0.3	-	-	-
Scopulariopsis/Microascus	-	-	-	-	-	-	-	-	-
Stachybotrys/Memnoniella	-	-	-	-	-	-	-	-	-
Unidentifiable Spores	-	-	-	-	-	-	-	-	-
Zygomycetes	-	-	-	-	-	-	-	-	-
<b>Total Fungi</b>	<b>717</b>	<b>30260</b>	<b>100</b>	<b>720</b>	<b>30180</b>	<b>100</b>	<b>688</b>	<b>28940</b>	<b>100</b>
Hyphal Fragment	1	40	-	10	420	-	-	-	-
Insect Fragment	1	40	-	-	-	-	-	-	-
Pollen	-	-	-	3*	40*	-	2*	30*	-
Analyt. Sensitivity 600x	-	42	-	-	42	-	-	42	-
Analyt. Sensitivity 300x	-	13*	-	-	13*	-	-	13*	-
Skin Fragments (1-4)	-	1	-	-	2	-	-	2	-
Fibrous Particulate (1-4)	-	1	-	-	1	-	-	1	-
Background (1-5)	-	1	-	-	1	-	-	1	-

**Report Comment:** Slide for KES-6 cassette missing due to manufacturing error

++ Includes other spores with similar morphology; see EMSL's fungal glossary for each specific category.

Abubakar Barry, Microbiology Lab Manager  
or other Approved Signatory

No discernable field blank was submitted with this group of samples.

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted. High levels of background particulate can obscure spores and other particulates, leading to underestimation. Background levels of 5 indicate an overloading of background particulates, prohibiting accurate detection and quantification. Present = Spores detected on overloaded samples. Results are not blank corrected unless otherwise noted. The detection limit is equal to one fungal spore, structure, pollen, fiber particle or insect fragment. "\*" Denotes particles found at 300X. "-" Denotes not detected. Due to method stopping rules, raw counts in excess of 100 are extrapolated based on the percentage analyzed.

Samples analyzed by EMSL Analytical, Inc. Beltsville, MD AIHA-LAP, LLC-EMLAP Accredited #102891

Initial report from: 12/15/2020 10:53 AM

For information on the fungi listed in this report, please visit the Resources section at [www.emsl.com](http://www.emsl.com)



# EMSL Analytical, Inc.

10768 Baltimore Avenue Beltsville, MD 20705

Tel/Fax: (301) 937-5700 / (301) 937-5701

http://www.EMSL.com / beltsvillelab@emsl.com

EMSL Order: 192011891

Customer ID: TIDE50

Customer PO:

Project ID:

**Attention:** Skanda Abeyeskere  
Tidewater, Inc.  
6625 Selnick Drive  
Suite A  
Elkridge, MD 21075

**Project:** Kenmoor ES

**Phone:** (410) 540-8700

**Fax:** (410) 997-8713

**Collected Date:** 11/30/2020

**Received Date:** 12/02/2020

**Analyzed Date:** 12/14/2020

## Test Report: Allergenco-D(™) Analysis of Fungal Spores & Particulates by Optical Microscopy (Methods MICRO-SOP-201, ASTM D7391)

Lab Sample Number:	192011891-0008			192011891-0009			192011891-0010		
Client Sample ID:	KES-8			KES-9			KES-10		
Volume (L):	75			75			75		
Sample Location:	Classroom 16			Classroom 22			Classroom 17		
Spore Types	Raw Count	Count/m <sup>3</sup>	% of Total	Raw Count	Count/m <sup>3</sup>	% of Total	Raw Count	Count/m <sup>3</sup>	% of Total
Alternaria (Ulocladium)	-	-	-	-	-	-	-	-	-
Ascospores	3	100	0.7	3	100	7.4	26	1100	13.4
Aspergillus/Penicillium	2	80	0.6	-	-	-	5	200	2.4
Basidiospores	325	13700	97.7	28	1200	88.9	163	6880	83.7
Bipolaris++	-	-	-	-	-	-	-	-	-
Chaetomium	-	-	-	-	-	-	-	-	-
Cladosporium	3	100	0.7	-	-	-	1	40	0.5
Curvularia	-	-	-	1*	10*	0.7	-	-	-
Epicoccum	-	-	-	-	-	-	-	-	-
Fusarium	-	-	-	-	-	-	-	-	-
Ganoderma	-	-	-	-	-	-	-	-	-
Myxomycetes++	1	40	0.3	1	40	3	-	-	-
Pithomyces++	-	-	-	-	-	-	-	-	-
Rust	-	-	-	-	-	-	-	-	-
Scopulariopsis/Microascus	-	-	-	-	-	-	-	-	-
Stachybotrys/Memnoniella	-	-	-	-	-	-	-	-	-
Unidentifiable Spores	-	-	-	-	-	-	-	-	-
Zygomycetes	-	-	-	-	-	-	-	-	-
<b>Total Fungi</b>	<b>334</b>	<b>14020</b>	<b>100</b>	<b>33</b>	<b>1350</b>	<b>100</b>	<b>195</b>	<b>8220</b>	<b>100</b>
Hyphal Fragment	2	80	-	1*	10*	-	-	-	-
Insect Fragment	-	-	-	-	-	-	-	-	-
Pollen	2*	30*	-	1	40	-	1	40	-
Analyt. Sensitivity 600x	-	42	-	-	42	-	-	42	-
Analyt. Sensitivity 300x	-	13*	-	-	13*	-	-	13*	-
Skin Fragments (1-4)	-	2	-	-	1	-	-	1	-
Fibrous Particulate (1-4)	-	1	-	-	1	-	-	1	-
Background (1-5)	-	1	-	-	1	-	-	1	-

**Report Comment:** Slide for KES-6 cassette missing due to manufacturing error

++ Includes other spores with similar morphology; see EMSL's fungal glossary for each specific category.

Abubakar Barry, Microbiology Lab Manager  
or other Approved Signatory

No discernable field blank was submitted with this group of samples.

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted. High levels of background particulate can obscure spores and other particulates, leading to underestimation. Background levels of 5 indicate an overloading of background particulates, prohibiting accurate detection and quantification. Present = Spores detected on overloaded samples. Results are not blank corrected unless otherwise noted. The detection limit is equal to one fungal spore, structure, pollen, fiber particle or insect fragment. "\*" Denotes particles found at 300X. "-" Denotes not detected. Due to method stopping rules, raw counts in excess of 100 are extrapolated based on the percentage analyzed.

Samples analyzed by EMSL Analytical, Inc. Beltsville, MD AIHA-LAP, LLC-EMLAP Accredited #102891

Initial report from: 12/15/2020 10:53 AM

For information on the fungi listed in this report, please visit the Resources section at [www.emsl.com](http://www.emsl.com)



# EMSL Analytical, Inc.

10768 Baltimore Avenue Beltsville, MD 20705

Tel/Fax: (301) 937-5700 / (301) 937-5701

http://www.EMSL.com / beltsvillelab@emsl.com

EMSL Order: 192011891

Customer ID: TIDE50

Customer PO:

Project ID:

**Attention:** Skanda Abeyeskere  
Tidewater, Inc.  
6625 Selnick Drive  
Suite A  
Elkridge, MD 21075

**Project:** Kenmoor ES

**Phone:** (410) 540-8700

**Fax:** (410) 997-8713

**Collected Date:** 11/30/2020

**Received Date:** 12/02/2020

**Analyzed Date:** 12/14/2020

## Test Report: Allergenco-D(™) Analysis of Fungal Spores & Particulates by Optical Microscopy (Methods MICRO-SOP-201, ASTM D7391)

Lab Sample Number:	192011891-0011						
Client Sample ID:	KES-BG						
Volume (L):	75						
Sample Location:	Background						
Spore Types	Raw Count	Count/m <sup>3</sup>	% of Total				
Alternaria (Ulocladium)	4	200	0.4	-	-	-	-
Ascospores	283	11900	25.1	-	-	-	-
Aspergillus/Penicillium	4	200	0.4	-	-	-	-
Basidiospores	826	34900	73.6	-	-	-	-
Bipolaris++	-	-	-	-	-	-	-
Chaetomium	-	-	-	-	-	-	-
Cladosporium	4	200	0.4	-	-	-	-
Curvularia	-	-	-	-	-	-	-
Epicoccum	-	-	-	-	-	-	-
Fusarium	-	-	-	-	-	-	-
Ganoderma	-	-	-	-	-	-	-
Myxomycetes++	1*	10*	0	-	-	-	-
Pithomyces++	-	-	-	-	-	-	-
Rust	-	-	-	-	-	-	-
Scopulariopsis/Microascus	-	-	-	-	-	-	-
Stachybotrys/Memnoniella	-	-	-	-	-	-	-
Unidentifiable Spores	-	-	-	-	-	-	-
Zygomycetes	-	-	-	-	-	-	-
<b>Total Fungi</b>	<b>1122</b>	<b>47410</b>	<b>100</b>	-	-	-	-
Hyphal Fragment	-	-	-	-	-	-	-
Insect Fragment	-	-	-	-	-	-	-
Pollen	-	-	-	-	-	-	-
Analyt. Sensitivity 600x	-	42	-	-	-	-	-
Analyt. Sensitivity 300x	-	13*	-	-	-	-	-
Skin Fragments (1-4)	-	1	-	-	-	-	-
Fibrous Particulate (1-4)	-	1	-	-	-	-	-
Background (1-5)	-	1	-	-	-	-	-

**Report Comment:** Slide for KES-6 cassette missing due to manufacturing error

++ Includes other spores with similar morphology; see EMSL's fungal glossary for each specific category.

Abubakar Barry, Microbiology Lab Manager  
or other Approved Signatory

No discernable field blank was submitted with this group of samples.

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted. High levels of background particulate can obscure spores and other particulates, leading to underestimation. Background levels of 5 indicate an overloading of background particulates, prohibiting accurate detection and quantification. Present = Spores detected on overloaded samples. Results are not blank corrected unless otherwise noted. The detection limit is equal to one fungal spore, structure, pollen, fiber particle or insect fragment. "\*" Denotes particles found at 300X. "-" Denotes not detected. Due to method stopping rules, raw counts in excess of 100 are extrapolated based on the percentage analyzed.

Samples analyzed by EMSL Analytical, Inc. Beltsville, MD AIHA-LAP, LLC-EMLAP Accredited #102891

Initial report from: 12/15/2020 10:53 AM

For information on the fungi listed in this report, please visit the Resources section at [www.emsl.com](http://www.emsl.com)



# Microbiology Chain of Custody

## EMSL Order Number (Lab Use Only):

192011891

PHONE:  
FAX:

Company: Tidewater Inc		EMSL-Bill to: <input type="checkbox"/> Different <input type="checkbox"/> Same <small>If Bill to is Different note instructions in Comments**</small>	
Street: 6625 Selnick Drive, Suite A		<i>Third Party Billing requires written authorization from third party</i>	
City: Elkridge	State/Province: MD	Zip/Postal Code:	Country:
Report To (Name): Skanda Abeyesekere		Telephone #:	
Email Address: skanda@tideh2o.net		Fax #:	Purchase Order:
Project Name/Number: <i>Ken Moor ES1</i>		Please Provide Results: <input type="checkbox"/> FAX <input checked="" type="checkbox"/> E-mail <input type="checkbox"/> Mail	
U.S. State Samples Taken: Maryland		Connecticut Samples: <input type="checkbox"/> Commercial <input type="checkbox"/> Residential	

**Turnaround Time (TAT) Options\* - Please Check**

3 Hour   
  6 Hour   
  24 Hour   
  48 Hour   
  72 Hour   
  96 Hour   
  1 Week   
  2 Week

\*Analysis completed in accordance with EMSL's Terms and Conditions located in the Analytical Price Guide. TATs are subject to methodology requirements

**Non Culturable Air Samples (Spore Traps) - Test Codes**

- |                   |                   |                    |                     |                   |
|-------------------|-------------------|--------------------|---------------------|-------------------|
| • M001 Air-O-Cell | • M173 Allegro M2 | • M004 Allergenco  | • M032 Allergenco-D | • M172 Versa Trap |
| • M049 BioSIS     | • M003 Burkard    | • M043 Cyclex      | • M002 Cyclex-d     |                   |
| • M030 Micro 5    | • M174 MoldSnap   | • M176 Relle Smart | • M130 Via-Cell     |                   |

**Other Microbiology Test Codes**

- |   |  |  |
|---|--|--|
| <ul style="list-style-type: none"> <li>• M041 Fungal Direct Examination</li> <li>• M005 Viable Fungi ID and Count</li> <li>• M006 Viable Fungi ID and Count (Speciation)</li> <li>• M007 Culturable Fungi</li> <li>• M008 Culturable Fungi (Speciation)</li> <li>• M009 Gram Stain Culturable Bacteria</li> <li>• M010 Bacterial Count and ID - 3 Most Prominent</li> <li>• M011 Bacterial Count and ID - 5 Most Prominent</li> <li>• M013 Sewage Contamination in Buildings</li> </ul> | <ul style="list-style-type: none"> <li>• M014 Endotoxin Analysis</li> <li>• M015 Heterotrophic Plate Count</li> <li>• M180 Real Time Q-PCR-ERMI 36 Panel</li> <li>• M018 Total Coliform (Membrane Filtration)</li> <li>• M020 Fecal Streptococcus (Membrane Filtration)</li> <li>• M210-215 Legionella Detection</li> <li>• M026 Recreational Water Screen</li> <li>• M027 Mycotoxin Analysis</li> </ul> | <ul style="list-style-type: none"> <li>• M029 Enterococci</li> <li>• M019 Fecal Coliform</li> <li>• M133 MRSA Analysis</li> <li>• M028 Cryptococcus neoformans Detection</li> <li>• M120 Histoplasma capsulatum Detection</li> <li>• M033-39 Allergen Testing</li> <li>• M044 Group Allergen (Cat, Dog, Cockroach, Dustmites)</li> <li>• Other See Analytical Price Guide</li> </ul> |
|---|--|--|

**Preservation Method (Water):**

Name of Sampler: Skanda Abeyesekere	Signature of Sampler:
-------------------------------------	-----------------------

Sample #	Sample Location	Sample Type	Test Code	Volume/Area	Date/Time Collected
Example: A1	Kitchen	Air	M001	75L	11/11/2020 4:00 PM
KES-1	Multipurpose room	ANY	M032	75	11/30/2020
KES-2	Main office				
KES-3	Media Center				
KES-4	classroom 10				
KES-5	classroom 5				
KES-6	classroom 6				
KES-7	classroom 15				
KES-8	classroom 16				
KES-9	classroom 22				

Client Sample # (s): <i>11</i>	Total # of Samples: <i>11</i>
--------------------------------	-------------------------------

Relinquished (Client):	Date: <i>11/30</i>	Time: <i>12:00 PM</i>
Received (Client): _____	Date: _____	Time: _____

Comments:

RECEIVED  
 EMSL ANALYTICAL, INC.  
 BELTSVILLE, MD  
 DEC - 2 A 9:15

## Microbiology Chain of Custody

**EMSL Order Number (Lab Use Only):**

192011891

PHONE:  
FAX:

*Additional Pages of the Chain of Custody are only necessary if needed for additional sample information*

Sample #	Sample Location	Sample Type	Test Code	Volume/Area	Date/Time Collected
KES-10	classroom 17	Air	M032	75.0	11/30/2020
<del>KES</del>		↓	↓	↓	↓
KES-BG	Background	↓	↓	↓	↓

**\*\*Comments/Special Instructions:**



**APPENDIX C**  
**INSTRUMENT CALIBRATION CERTIFICATES**



# CERTIFICATE OF CALIBRATION AND TESTING

TSI Incorporated, 500 Cardigan Road, Shoreview, MN 55126 USA  
 Tel: 1-800-874-2811 1-651-490-2811 Fax: 1-651-490-3824 <http://www.tsi.com>

ENVIRONMENT CONDITIONS			<b>MODEL</b>	<b>9565-X</b>
TEMPERATURE	74.1 (23.4)	°F (°C)		
RELATIVE HUMIDITY	26	%RH		
BAROMETRIC PRESSURE	29.26 (990.9)	inHg (hPa)		
			<b>SERIAL NUMBER</b>	<b>9565X1945002</b>

<input checked="" type="checkbox"/> AS LEFT	<input checked="" type="checkbox"/> IN TOLERANCE
<input type="checkbox"/> AS FOUND	<input type="checkbox"/> OUT OF TOLERANCE

-- CALIBRATION VERIFICATION RESULTS --

THERMO COUPLE <sup>^</sup>				SYSTEM PRESSURE01-01				Unit: °F (°C)
#	STANDARD	MEASURED	ALLOWABLE RANGE	#	STANDARD	MEASURED	ALLOWABLE RANGE	
1	71.6 (22.0)	71.6 (22.0)	69.6~73.6 (20.9~23.1)					

BAROMETRIC PRESSURE				SYSTEM PRESSURE01-01				Unit: inHg (hPa)
#	STANDARD	MEASURED	ALLOWABLE RANGE	#	STANDARD	MEASURED	ALLOWABLE RANGE	
1	29.26 (990.9)	29.26 (990.9)	28.67~29.85 (970.9~1010.8)					

<sup>^</sup> Circuit portion of temperature measurement only, not including probe.

*TSI does hereby certify that the above described instrument conforms to the original manufacturer's specification (not applicable to As Found data), and has been calibrated using standards whose accuracies are traceable to the United States National Institute of Standards and Technology (NIST) or has been verified with respect to instrumentation whose accuracy is traceable to NIST, or is derived from accepted values of physical constants. TSI's calibration system is registered to ISO 9001:2015*

<u>Measurement Variable</u>	<u>System ID</u>	<u>Last Cal.</u>	<u>Cal. Due</u>	<u>Measurement Variable</u>	<u>System ID</u>	<u>Last Cal.</u>	<u>Cal. Due</u>
DC Voltage	E003299	06-06-19	12-31-20	DC Voltage	E003500	06-06-19	12-31-20
Temperature	E004626	01-09-19	01-31-20	Pressure	E003302	08-07-19	02-29-20
Pressure	E003303	08-26-19	02-29-20				

Rose Germain

---

CALIBRATED

November 8, 2019

---

DATE




# CERTIFICATE OF CALIBRATION AND TESTING

TSI Incorporated, 500 Cardigan Road, Shoreview, MN 55126 USA  
 Tel: 1-800-874-2811 1-651-490-2811 Fax: 1-651-490-3824 http://www.tsi.com

Environment Conditions			Model	<b>8534</b>
Temperature	75.83 (24.4)	°F (°C)	Serial Number	
Relative Humidity	43.6	%RH		
Barometric Pressure	28.93 (979.7)	inHg (hPa)		
			<b>8534170101</b>	

<input checked="" type="checkbox"/> As Left	<input checked="" type="checkbox"/> In Tolerance	
<input type="checkbox"/> As Found	<input type="checkbox"/> Out of Tolerance	



FLOW AND PRESSURE VERIFICATION				SYSTEM DTH01-01			
Parameter	Standard	Measured	Allowable Range	Parameter	Standard	Measured	Allowable Range
Flow lpm	3.00	3.03	2.88 ~ 3.12	Pressure kPa	97.8	97.8	92.95 ~ 102.73
Full Flow lpm	N/A	4.54	>3.80				

*TSI Incorporated does hereby certify that all materials, components, and workmanship used in the manufacture of this equipment are in strict accordance with the applicable specifications agreed upon by TSI and the customer and with all published specifications. All performance and acceptance tests required under this contract were successfully conducted according to required specifications. There is no NIST standard for optical mass measurements. Calibration of this instrument performed by TSI has been done using emery oil and has been nominally adjusted to respirable mass per standard ISO 12103-1, Ai test dust (Arizona dust). Our calibration ratio is greater than 1.2:1*

Measurement Variable	System ID	Last Cal.	Cal. Due	Measurement Variable	System ID	Last Cal.	Cal. Due
DC Voltage	E003314	01-15-20	01-31-21	Photometer	E005612	08-19-20	02-28-21
Microbalance	M001324	10-03-18	10-31-20	1 um PSL	698880	n/a	n/a
3 um PSL	221853	n/a	n/a	10 um PSL	212455	n/a	n/a
Pressure	E003511	10-04-19	10-31-20	Flowmeter	E005140	01-09-20	01-31-21
DC Voltage	E003315	01-15-20	01-31-21	Photometer	E003433	09-15-20	03-31-21
Flowmeter	E005922	06-29-20	06-30-21	DC Voltage(Keithley)	E002859	06-15-20	06-30-21
Microbalance	M001324	10-03-18	10-31-20	Pressure	E005651	07-06-20	07-31-21
1 um PSL	698880	n/a	n/a	3 um PSL	206030	n/a	n/a
10 um PSL	212455	n/a	n/a				

David Farrell

September 24, 2020

Calibrated

Date

# Certificate of Conformance

Buck BioAire™

Buck BioSlide™

Serial number: B153043 Date Issued: 3-18-20

## Flow Calibration

The instrument listed above is in conformance with factory specifications and the flow is set to nominal using a BUCK Calibrator which is N.I.S.T. traceable to A. P. Buck, Inc. Calibration Procedure APB-1, Ver. 6.2.

**QA APPROVAL BY:** Thomas J. Coomaver

Information contained in this document should not be reproduced in any form without the written consent of A.P. Buck Inc. It is for reference only and cannot be used as a form of endorsement by any private or governmental regulatory body.


A.P. BUCK, INC.  
7101 Presidents Drive, Suite 110  
Orlando, FL 32809  
Phone: 407-851-8602 • Fax: 407-851-8910

**BUCK**  
A.P. BUCK, INC.

COCR-004 REV-01 3/3/2006



**APPENDIX D**  
**RELEVANT CERTIFICATIONS**



**american board of industrial hygiene®**

organized to improve the practice of industrial hygiene  
proclaims that

*Skandakumar Harshanath Abeyesekere*

having met all requirements of  
education, experience and examination, and  
ongoing maintenance,  
is hereby certified in the

**COMPREHENSIVE PRACTICE  
of  
INDUSTRIAL HYGIENE**

and has the right to use the designations

**CERTIFIED INDUSTRIAL HYGIENIST**

**CIH**


Certificate Number	9928 CP
Awarded:	May 11, 2011
Expiration Date:	December 1, 2021



*Susan Ripple*  
\_\_\_\_\_  
Chair, ABIH

*William K. Oliver*  
\_\_\_\_\_  
Chief Executive Officer, ABIH





# BOARD OF CERTIFIED SAFETY PROFESSIONALS

affirms that

## Skandakumar Abeyesekere

Has applied for, met qualifications, and passed required examination(s) and is hereby authorized to use the designation

### Certified Safety Professional® in Comprehensive Practice

So long as this certificate is not suspended or revoked and the certificant renews this authorization annually and meets Continuance of Certification requirements.

Board of Examiners in witness whereof we have here unto set our hands and affixed the Seal of the Board this 7th Day of April, 2008



<i>Paul S Adams</i>	President
<i>Linda Japp</i>	Secretary
20110	CSP No.



THIS CERTIFIES THAT

*Skandakumar Abeyeskere*

HAS SUCCESSFULLY MET ALL THE REQUIREMENTS OF EDUCATION, EXPERIENCE AND EXAMINATION, AND IS HEREBY DESIGNATED A

**CERTIFIED HAZARDOUS MATERIALS MANAGER  
CHMM**



May 13, 2016

DATE OF CERTIFICATION

19053

CREDENTIAL NUMBER

May 31, 2021

CERTIFICATION EXPIRES

*M. Patricia Buley*  
ACTING EXECUTIVE DIRECTOR

VALID SO LONG AS THIS CREDENTIAL IS RENEWED ACCORDING TO SCHEDULE AND IS NOT OTHERWISE REVOKED.



Accredited by the American National Standards Institute and the Council of Engineering and Scientific Specialty Boards






**APPENDIX E**

**FLOOR PLAN WITH SAMPLING LOCATIONS**

All will stand at the fence.



Exit out the door and stand

General Notes

Scale: N/A

▲ = Sample Location

Project #: 5419-031  
Date: November 30, 2020

**Attachment C**  
**Kenmoor Elementary School**  
**Floor Plan with Sampling Locations**

