



# EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (800) 220-3675 / (856) 786-0327  
<http://www.EMSL.com> [cinnaminsonradonlab@emsl.com](mailto:cinnaminsonradonlab@emsl.com)

EMSL Order: 382306871  
 CustomerID: GLBW42  
 CustomerPO:  
 ProjectID:

Attn: **Channa Bambaradeniya**  
**Global Inc.**  
**1818 New York Avenue NE**  
**Suite 222**  
**Washington, DC 20002**

Phone: (202) 832-1433  
 Fax:  
 Received: 11/14/2023 11:39 AM  
 Analysis Date: 11/15/2023  
 Collected: 11/3/2023

Project: **Bladensburg HS / 4200 58th Avenue**

Test Site: **Bladensburg HS**  
**4200 58th Avenue**  
**Bladensburg, MD 20710**

## Test Report: Radon in Air Test Results

### Samples for EMSL Kit 308426

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
550329	TEM- C05-492	0.1	11/3/2023	11/6/2023	70	33	Customer
382306871-0001			9:36:00 AM	7:42:00 AM			

Sample Notes:

### Samples for EMSL Kit 308460

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
550286	TEM -08 - 549	0.1	11/3/2023	11/6/2023	70	33	Customer
382306871-0002			9:38:00 AM	7:43:00 AM			

Sample Notes:

### Samples for EMSL Kit 308420

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
550259	(Back Stage Gym) D1113	0.4	11/3/2023	11/6/2023	70	33	Customer
382306871-0003			9:42:00 AM	7:45:00 AM			

Sample Notes:

### Samples for EMSL Kit 308971

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
550269	D1102	0.1	11/3/2023	11/6/2023	70	33	Customer
382306871-0004			9:46:00 AM	7:47:00 AM			

Sample Notes:

### Samples for EMSL Kit 308422

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
550357	C1199 / C1195 / C1196	0.5	11/3/2023	11/6/2023	70	33	Customer
382306871-0005			9:50:00 AM	7:49:00 AM			

Sample Notes:

549897	C1199 / C1195 / C1196	0.4	11/3/2023	11/6/2023	70	33	Duplicate
382306871-0006			9:50:00 AM	7:49:00 AM			

Sample Notes:

Duplicate RPD = 22.2%



# EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (800) 220-3675 / (856) 786-0327  
<http://www.EMSL.com> [cinnaminsonradonlab@emsl.com](mailto:cinnaminsonradonlab@emsl.com)

EMSL Order: 382306871  
 CustomerID: GLBW42  
 CustomerPO:  
 ProjectID:

Attn: **Channa Bambaradeniya**  
**Global Inc.**  
**1818 New York Avenue NE**  
**Suite 222**  
**Washington, DC 20002**

Phone: (202) 832-1433  
 Fax:  
 Received: 11/14/2023 11:39 AM  
 Analysis Date: 11/15/2023  
 Collected: 11/3/2023

Project: **Bladensburg HS / 4200 58th Avenue**

Test Site: **Bladensburg HS**  
**4200 58th Avenue**  
**Bladensburg, MD 20710**

## Test Report: Radon in Air Test Results

### Samples for EMSL Kit 308427

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
550343	C1192	0.1	11/3/2023	11/6/2023	70	33	Customer
382306871-0007			9:52:00 AM	7:51:00 AM			

Sample Notes:

### Samples for EMSL Kit 308419

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
550223	C1199	0.7	11/3/2023	11/6/2023	70	33	Customer
382306871-0008			9:55:00 AM	7:52:00 AM			

Sample Notes:

### Samples for EMSL Kit 308395

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
550291	C1174A	0	11/3/2023	11/6/2023	70	33	Customer
382306871-0009			9:59:00 AM	8:22:00 AM			

Sample Notes:

550362	C1174A	0.1	11/3/2023	11/6/2023	70	33	Blank
382306871-0010			9:59:00 AM	8:22:00 AM			

Sample Notes:

### Samples for EMSL Kit 308439

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
550328	C1174B	0	11/3/2023	11/6/2023	70	33	Customer
382306871-0011			10:02:00 AM	8:23:00 AM			

Sample Notes:

### Samples for EMSL Kit 308443

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
550359	C1170	0	11/3/2023	11/6/2023	70	33	Customer
382306871-0012			10:06:00 AM	7:55:00 AM			

Sample Notes:



# EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077  
Phone/Fax: (800) 220-3675 / (856) 786-0327  
<http://www.EMSL.com> [cinnaminsonradonlab@emsl.com](mailto:cinnaminsonradonlab@emsl.com)

EMSL Order: 382306871  
CustomerID: GLBW42  
CustomerPO:  
ProjectID:

Attn: **Channa Bambaradeniya**  
**Global Inc.**  
**1818 New York Avenue NE**  
**Suite 222**  
**Washington, DC 20002**

Phone: (202) 832-1433  
Fax:  
Received: 11/14/2023 11:39 AM  
Analysis Date: 11/15/2023  
Collected: 11/3/2023

Project: **Bladensburg HS / 4200 58th Avenue**

Test Site: **Bladensburg HS**  
**4200 58th Avenue**  
**Bladensburg, MD 20710**

## Test Report: Radon in Air Test Results

### Samples for EMSL Kit 308434

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
550222	C1155	0	11/3/2023	11/6/2023	70	33	Customer
382306871-0013			10:08:00 AM	7:56:00 AM			

Sample Notes:

### Samples for EMSL Kit 308431

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
550350	C1162	0	11/3/2023	11/6/2023	70	33	Customer
382306871-0014			10:09:00 AM	7:57:00 AM			

Sample Notes:

### Samples for EMSL Kit 308446

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
550352	B1112	0.1	11/3/2023	11/6/2023	70	33	Customer
382306871-0015			10:16:00 AM	8:10:00 AM			

Sample Notes:

### Samples for EMSL Kit 308459

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
550280	A1131	-0.3	11/3/2023	11/6/2023	70	33	Customer
382306871-0016			10:22:00 AM	8:30:00 AM			

Sample Notes:

### Samples for EMSL Kit 308433

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
550315	Kitchen	0.5	11/3/2023	11/6/2023	70	33	Customer
382306871-0017			10:24:00 AM	8:13:00 AM			

Sample Notes:



# EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077  
Phone/Fax: (800) 220-3675 / (856) 786-0327  
<http://www.EMSL.com> [cinnaminsonradonlab@emsl.com](mailto:cinnaminsonradonlab@emsl.com)

EMSL Order: 382306871  
CustomerID: GLBW42  
CustomerPO:  
ProjectID:

Attn: **Channa Bambaradeniya**  
**Global Inc.**  
**1818 New York Avenue NE**  
**Suite 222**  
**Washington, DC 20002**

Phone: (202) 832-1433  
Fax:  
Received: 11/14/2023 11:39 AM  
Analysis Date: 11/15/2023  
Collected: 11/3/2023

Project: **Bladensburg HS / 4200 58th Avenue**

Test Site: **Bladensburg HS**  
**4200 58th Avenue**  
**Bladensburg, MD 20710**

## Test Report: Radon in Air Test Results

### Samples for EMSL Kit 308417

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
550266	A1111	0.1	11/3/2023	11/6/2023	70	33	Customer
382306871-0018			10:29:00 AM	8:16:00 AM			

Sample Notes:

### Samples for EMSL Kit 308447

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
550332	A1109	-0.3	11/3/2023	11/6/2023	70	33	Customer
382306871-0019			10:31:00 AM	8:17:00 AM			

Sample Notes:

### Samples for EMSL Kit 308440

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
550190	A1102	0.1	11/3/2023	11/6/2023	70	33	Customer
382306871-0020			10:34:00 AM	8:19:00 AM			

Sample Notes:

### Samples for EMSL Kit 308469

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
550301	A1102 - Office	0	11/3/2023	11/6/2023	70	33	Customer
382306871-0021			10:37:00 AM	8:11:00 AM			

Sample Notes:

### Samples for EMSL Kit 308441

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
550306	F1101	-0.1	11/3/2023	11/6/2023	70	33	Customer
382306871-0022			10:40:00 AM	8:12:00 AM			

Sample Notes:



# EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077  
Phone/Fax: (800) 220-3675 / (856) 786-0327  
<http://www.EMSL.com> [cinnaminsonradonlab@emsl.com](mailto:cinnaminsonradonlab@emsl.com)

EMSL Order: 382306871  
CustomerID: GLBW42  
CustomerPO:  
ProjectID:

Attn: **Channa Bambaradeniya**  
**Global Inc.**  
**1818 New York Avenue NE**  
**Suite 222**  
**Washington, DC 20002**

Phone: (202) 832-1433  
Fax:  
Received: 11/14/2023 11:39 AM  
Analysis Date: 11/15/2023  
Collected: 11/3/2023

Project: **Bladensburg HS / 4200 58th Avenue**

Test Site: **Bladensburg HS**  
**4200 58th Avenue**  
**Bladensburg, MD 20710**

## Test Report: Radon in Air Test Results

The radon test was performed using a liquid scintillation radon detector/s and counted on a liquid scintillation counter using approved EPA testing protocols for Radon in Air testing. The EPA recommends fixing your home if the average of two short-term tests taken in the lowest lived-in level of the home show radon levels that are equal to or greater than 4.0pCi/L. The EPA recommends retesting your home every two years.

Please contact EMSL Analytical, Inc. or your State Health Department for further information. All procedures used for generating this report are in complete accordance with the current EPA protocols for the analysis of Radon in Air.

### Report Note

Analyst(s)

Jeanel Zoll (22)

Dominic Gehret, Radiochemistry Laboratory Manager, NJ Radon  
Measurement Specialist MES 13910  
or other approved signatory

In no event shall EMSL be liable for indirect, special, consequential, or incidental damages, including, but not limited to, damages for loss of profit or goodwill regardless of the negligence (either sole or concurrent) of EMSL and whether EMSL has been informed of the possibility of such damages, arising out of or in connection with EMSL's services thereunder or the delivery, use, reliance upon or interpretation of test results by client or any third party. We accept no legal responsibility for the purposes for which the client uses the test results. In no event shall EMSL be liable to a client or any third party, whether based upon theories of tort, contract or any other legal or equitable theory, in excess of the amount paid to EMSL by client thereunder. The test results meets all NELAC requirements unless otherwise specified.

Samples analyzed by EMSL Analytical, Inc. Cinnaminson, NJ FL RB2034/R2687,IL RNL2008202,IN RTL00935,IA RNLAB10005,KS KS-LB-0005/KS-MS-0482,ME SPC202,MN RL-0005,NE 474/RMB-1083,NJ 03036/MEB92525/MES13910,NY 10872,OH RL39,OK D9952,PA 2573/3393/68-00367,RI RMB-108/RI00179,WV RL000220,NRSB-ARL6006,NRPP

Initial report from 11/16/2023 16:36:16

Please visit [www.radontestinglab.com](http://www.radontestinglab.com)