

November 2, 2023

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:
**HIGHLAND PARK ED
MAIN**

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
11292934	B12	2023-10-27 @ 4:00 pm	2023-10-30 @ 3:00 pm	0.6 ± 0.3	2023-11-02
11292942	B12	2023-10-27 @ 4:00 pm	2023-10-30 @ 3:00 pm	< 0.3	2023-11-02
11292926	HEALTH SUITE A08	2023-10-27 @ 3:00 pm	2023-10-30 @ 3:00 pm	0.6 ± 0.3	2023-11-02
11292928	KITCHEN OFFICE A15B	2023-10-27 @ 3:00 pm	2023-10-30 @ 3:00 pm	< 0.3	2023-11-02
11292956	KITCHEN OFFICE A15B	2023-10-27 @ 3:00 pm	2023-10-30 @ 3:00 pm	< 0.3	2023-11-02
11292919	MULTIPURPOSE ROOM NEAR KITCHEN	2023-10-27 @ 3:00 pm	2023-10-30 @ 3:00 pm	< 0.3	2023-11-02
11292931	MULTIPURPOSE ROOM NEAR STAGE	2023-10-27 @ 3:00 pm	2023-10-30 @ 3:00 pm	< 0.3	2023-11-02
11292925	OFFICE A02B	2023-10-27 @ 3:00 pm	2023-10-30 @ 3:00 pm	< 0.3	2023-11-02
11292932	OFFICE A13B	2023-10-27 @ 3:00 pm	2023-10-30 @ 3:00 pm	0.5 ± 0.3	2023-11-02
11292936	OFFICE A13B	2023-10-27 @ 3:00 pm	2023-10-30 @ 3:00 pm	< 0.3	2023-11-02
11292927	OFFICE B02	2023-10-27 @ 4:00 pm	2023-10-30 @ 3:00 pm	0.9 ± 0.3	2023-11-02
11292955	OFFICE B05	2023-10-27 @ 4:00 pm	2023-10-30 @ 3:00 pm	1.4 ± 0.3	2023-11-02
11292923	PRINCIPALS OFFICE A02C	2023-10-27 @ 3:00 pm	2023-10-30 @ 3:00 pm	0.5 ± 0.3	2023-11-02

Air Chek 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498