Radon Test Report

November 28, 2023 Batch #: 112823-2

Customer:

Test Site:

6900 Ames St.

ATI Inc.

Imagine Foundayion @ Morningside

Ste.100

9220 Rumsey Road

Columbia MD 21045

Morningside MD 20746

E-PERM® Electret Ion Chambers were used for radon screening measurements that were conducted at the above referenced test site by: ATI Inc.

The Results are as follows:

Serial	Chamber	Type	Location	Test Start Date	Test End Date	Results
						(pCi/L)
SDD703		SST	Room 104	17-Nov-2023 7:07 AM	20-Nov-2023 7:24 AM	1.1
SDM414		SST	Room 101	17-Nov-2023 7:13 AM	20-Nov-2023 7:27 AM	1.1
SKP313		SST	Conference Rm.	17-Nov-2023 7:11 AM	20-Nov-2023 7:26 AM	1.2
SLZ163		SST	Multi-Purpose	17-Nov-2023 7:16 AM	20-Nov-2023 7:24 AM	1.5
SMD083		SST	Room 107	17-Nov-2023 7:07 AM	20-Nov-2023 7:25 AM	1.5
SMZ505		SST	Room 108	17-Nov-2023 7:08 AM	20-Nov-2023 7:25 AM	1.2

Deployed By: Mikal Frater

Retrieved By:

Analyzed By: Kimberly Cage 20SS034

Reader S/N: E0125 Reader Calibration Due: 8/2/2024

Conditions: Closed-Building Conditions Not Met Vents: Not Applicable / Fan Not Applicable

Radon Health Risk Information

Radon is the second leading cause of lung cancer after smoking. The U.S. Environmental Protection Agency (EPA) and the Surgeon General strongly recommend that further action be taken when a home's radon test results are 4.0 pCi/L or greater. The national average indoor radon level is about 1.3 pCi/L. The higher the home's radon level, the greater the health risk to you and your family. Reducing your radon levels can be done easily, effectively and fairly inexpensively. Even homes with very high radon levels can be reduced below 4.0 pCi/L. Please refer to the EPA website at www.epa.gov/radon for further information to assist you in evaluating your test results or deciding if further action is needed.

Signature:	Kimberly Cage	Date:	28-Nov-2023