

Radon test result report for:

**JAMES E. DUCKWORTH SPECIAL CENTER
MAIN**

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
11291855	CAFETORIUM	2023-11-10 @ 10:00 am	2023-11-13 @ 1:00 pm	0.5 ± 0.5	2023-11-20
11291866	CLASSROOM 10	2023-11-10 @ 11:00 am	2023-11-13 @ 2:00 pm	< 0.3	2023-11-20
11291846	CLASSROOM 12	2023-11-10 @ 11:00 am	2023-11-13 @ 2:00 pm	1.0 ± 0.6	2023-11-20
11291837	CLASSROOM 15	2023-11-10 @ 11:00 am	2023-11-13 @ 2:00 pm	1.4 ± 0.6	2023-11-20
11291853	CLASSROOM 15	2023-11-10 @ 11:00 am	2023-11-13 @ 2:00 pm	< 0.3	2023-11-20
11291821	CLASSROOM 16	2023-11-10 @ 11:00 am	2023-11-13 @ 2:00 pm	2.4 ± 0.6	2023-11-20
11291841	CLASSROOM 2	2023-11-10 @ 10:00 am	2023-11-13 @ 2:00 pm	< 0.3	2023-11-20
11291873	CLASSROOM 2	2023-11-10 @ 10:00 am	2023-11-13 @ 2:00 pm	1.0 ± 0.6	2023-11-20
11291858	CLASSROOM 4	2023-11-10 @ 10:00 am	2023-11-13 @ 2:00 pm	< 0.3	2023-11-20
11291838	CLASSROOM 6	2023-11-10 @ 10:00 am	2023-11-13 @ 2:00 pm	< 0.3	2023-11-20
11291868	CLASSROOM 8	2023-11-10 @ 11:00 am	2023-11-13 @ 2:00 pm	< 0.3	2023-11-20
11291815	GYM	2023-11-10 @ 11:00 am	2023-11-13 @ 1:00 pm	< 0.3	2023-11-20
11291874	GYM	2023-11-10 @ 11:00 am	2023-11-13 @ 1:00 pm	< 0.3	2023-11-20
11291834	STAGE	2023-11-10 @ 10:00 am	2023-11-13 @ 1:00 pm	< 0.3	2023-11-20