

## Findings

### Radon Sampling

The laboratory results of the radon testing canisters collected at Lake Arbor Elementary School had concentrations below the EPA action level of 4 pCi/L. Radon sampling results are summarized in Table 1. The complete laboratory analysis reports can be found in Attachment A.

**Table 1**  
**Radon Sampling Results**  
**Samples Measured from November 3, 2023 to November 6, 2023**

<b>Device Number</b>	<b>Room Number / Location</b>	<b>Result (pCi/L)</b>
7280087	251	1.2
7280086	251 Duplicate	1.0
7280096	249	1.9
7280097	236	0.9
7280099	Office across 251	1.7
7280098	247	1.6
7280100	238	1.1
7280101	240	0.8
7280102	244	1.7
7280103	242	0.8
7280104	Art Room	0.4
7280105	121	0.5
7280154	231	<0.4
7280155	231 Duplicate	<0.4
7280153	213	0.8
7280152	210	0.5
7280151	214	2.0
7280146	208	1.7
7280147	203	0.9
7280149	Speech Room	0.9
7280150	221	0.5
7280031	Field Blank	<0.4

Note: pCi/L - picocuries per liter of air