

Radon Test Report

November 22, 2023

Batch #: 111723-2

Customer:

ATI Inc.
9220 Rumsey Road
Ste.100
Columbia MD 21045

Test Site:

Paint Branch ES
5101 Pierce Ave
College Park MD 20740

E-PERM® Electret Ion Chambers were used for radon screening measurements that were conducted at the above referenced test site by: ATI Inc.

The Results are as follows:

Serial	Chamber	Type	Location	Test Start Date	Test End Date	Results (pCi/L)
SDG734		SST	Room 2	10-Nov-2023 3:29 PM	13-Nov-2023 7:33 AM	1.8
SDM313		SST	Room 23	10-Nov-2023 2:58 PM	13-Nov-2023 7:31 AM	1.0
SDM396		SST	Room 13	10-Nov-2023 2:56 PM	13-Nov-2023 7:31 PM	0.7
SKA381		SST	Room 34	10-Nov-2023 3:08 PM	13-Nov-2023 7:29 AM	0.8
SLK394		SST	Cafeteria	10-Nov-2023 3:16 PM	13-Nov-2023 7:27 AM	0.6
SLN514		SST	Media Center	10-Nov-2023 3:04 PM	13-Nov-2023 7:30 AM	0.8
SLT057		SST	Kitchen	10-Nov-2023 3:16 PM	13-Nov-2023 7:26 AM	1.2
SMA503		SST	Gym Office	10-Nov-2023 3:02 PM	13-Nov-2023 7:35 AM	0.4
SMB003		SST	Room 43	10-Nov-2023 3:11 PM	13-Nov-2023 7:28 AM	0.8
SMG974		SST	Room 33	10-Nov-2023 3:01 PM	13-Nov-2023 7:29 AM	0.4
SMQ626		SST	Pupil Service	10-Nov-2023 3:21 PM	13-Nov-2023 7:25 AM	0.8
SMT307		SST	Storage	10-Nov-2023 3:15 PM	13-Nov-2023 7:27 AM	0.8
SMU690		SST	Room 24	10-Nov-2023 3:00 PM	13-Nov-2023 7:32 AM	0.6
SMZ429		SST	Boiler Rm.	10-Nov-2023 3:13 PM	13-Nov-2023 7:28 AM	0.6
SMZ516		SST	Room 14	10-Nov-2023 2:55 PM	13-Nov-2023 7:31 AM	0.9

Deployed By:

Retrieved By:

Analyzed By: Kimberly Cage 20SS034

Reader S/N: E0125

Reader Calibration Due: 8/2/2024

Radon Health Risk Information

Radon is the second leading cause of lung cancer after smoking. The U.S. Environmental Protection Agency (EPA) and the Surgeon General strongly recommend that further action be taken when a home's radon test results are 4.0 pCi/L or greater. The national average indoor radon level is about 1.3 pCi/L. The higher the home's radon level, the greater the health risk to you and your family. Reducing your radon levels can be done easily, effectively and fairly inexpensively. Even homes with very high radon levels can be reduced below 4.0 pCi/L. Please refer to the EPA website at www.epa.gov/radon for further information to assist you in evaluating your test results or deciding if further action is needed.

Signature: Kimberly Cage

Date: 27-Nov-2023