



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077
Phone/Fax: (800) 220-3675 / (856) 786-0327
<http://www.EMSL.com> cinnaminsonradonlab@emsl.com

EMSL Order: 382306839
CustomerID: GLBW42
CustomerPO:
ProjectID:

Attn: **Channa Bambaradeniya**
Global Inc.
1818 New York Avenue NE
Suite 222
Washington, DC 20002

Phone: (202) 832-1433
Fax:
Received: 11/10/2023 05:00 PM
Analysis Date: 11/11/2023
Collected: 11/3/2023

Project: **William Wirt Middle School / 6200 Tuckerman Street**

Test Site: **William Wirt Middle School**
6200 Tuckerman Street
Riverdale, MD 20737

Test Report: Radon in Air Test Results

Samples for EMSL Kit 308423

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
550283	Health #112	0.7	11/3/2023	11/6/2023	66	40	Customer
382306839-0001			9:45:00 AM	6:41:00 AM			

Sample Notes:

Samples for EMSL Kit 308436

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
550278	Class Room #113	0.6	11/3/2023	11/6/2023	66	40	Customer
382306839-0002			9:50:00 AM	6:39:00 AM			

Sample Notes:

Samples for EMSL Kit 308430

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
550319	Class Room #110	0.8	11/3/2023	11/6/2023	66	40	Customer
382306839-0003			9:59:00 AM	6:50:00 AM			

Sample Notes:

Samples for EMSL Kit 308403

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
550273	Library (Media Center)	0.7	11/3/2023	11/6/2023	66	40	Customer
382306839-0004			10:03:00 AM	6:48:00 AM			

Sample Notes:

Samples for EMSL Kit 308411

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
550265	Multi Purpose Room	0.7	11/3/2023	11/6/2023	66	40	Customer
382306839-0005			10:08:00 AM	6:53:00 AM			

Sample Notes:



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (800) 220-3675 / (856) 786-0327
<http://www.EMSL.com> cinnaminsonradonlab@emsl.com

EMSL Order: 382306839
 CustomerID: GLBW42
 CustomerPO:
 ProjectID:

Attn: **Channa Bambaradeniya**
Global Inc.
1818 New York Avenue NE
Suite 222
Washington, DC 20002

Phone: (202) 832-1433
 Fax:
 Received: 11/10/2023 05:00 PM
 Analysis Date: 11/11/2023
 Collected: 11/3/2023

Project: **William Wirt Middle School / 6200 Tuckerman Street**

Test Site: **William Wirt Middle School**
6200 Tuckerman Street
Riverdale, MD 20737

Test Report: Radon in Air Test Results

Samples for EMSL Kit 308410

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
550290	Kitchen Office Room	0.7	11/3/2023	11/6/2023	66	40	Customer
382306839-0006			10:12:00 AM	6:54:00 AM			

Sample Notes:

Samples for EMSL Kit 308397

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
550267	Room #109A	0.4	11/3/2023	11/6/2023	66	40	Customer
382306839-0007			10:16:00 AM	6:56:00 AM			

Sample Notes:

Samples for EMSL Kit 308396

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
550252	Custodian Office	0.5	11/3/2023	11/6/2023	66	40	Customer
382306839-0008			10:21:00 AM	6:46:00 AM			

Sample Notes:

Samples for EMSL Kit 308388

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
550330	Class Room #101	1.2	11/3/2023	11/6/2023	66	40	Customer
382306839-0009			10:26:00 AM	7:38:00 AM			

Sample Notes:

549318	Class Room #101	1.3	11/3/2023	11/6/2023	66	40	Duplicate
382306839-0010			10:26:00 AM	7:38:00 AM			

Sample Notes:

Duplicate RPD = 8%

Samples for EMSL Kit 308380

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
550316	Class Room #102	0.4	11/3/2023	11/6/2023	66	40	Customer
382306839-0011			10:30:00 AM	7:11:00 AM			

Sample Notes:



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (800) 220-3675 / (856) 786-0327
<http://www.EMSL.com> cinnaminsonradonlab@emsl.com

EMSL Order: 382306839
 CustomerID: GLBW42
 CustomerPO:
 ProjectID:

Attn: **Channa Bambaradeniya**
Global Inc.
1818 New York Avenue NE
Suite 222
Washington, DC 20002

Phone: (202) 832-1433
 Fax:
 Received: 11/10/2023 05:00 PM
 Analysis Date: 11/11/2023
 Collected: 11/3/2023

Project: **William Wirt Middle School / 6200 Tuckerman Street**

Test Site: **William Wirt Middle School**
6200 Tuckerman Street
Riverdale, MD 20737

Test Report: Radon in Air Test Results

Samples for EMSL Kit 308404

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
550318	Class Room #105	0.5	11/3/2023	11/6/2023	66	40	Customer
382306839-0012			10:33:00 AM	7:09:00 AM			

Sample Notes:

Samples for EMSL Kit 308400

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
550351	Boy's Locker Room	0.6	11/3/2023	11/6/2023	66	40	Customer
382306839-0013			10:45:00 AM	7:46:00 AM			

Sample Notes:

Samples for EMSL Kit 308385

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
550355	Girl's Locker Room	1.3	11/3/2023	11/6/2023	66	40	Customer
382306839-0014			10:48:00 AM	7:41:00 AM			

Sample Notes:

550363	Girl's Locker Room	0.3	11/3/2023	11/6/2023	66	40	Blank
382306839-0015			10:48:00 AM	7:41:00 AM			

Sample Notes:

Samples for EMSL Kit 308393

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
550342	Class Room # 111	0.7	11/3/2023	11/6/2023	66	40	Customer
382306839-0016			10:54:00 AM	7:18:00 AM			

Sample Notes:

Samples for EMSL Kit 308429

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
550237	Class Room #104	0.5	11/3/2023	11/6/2023	66	40	Customer
382306839-0017			10:59:00 AM	7:05:00 AM			

Sample Notes:



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077
Phone/Fax: (800) 220-3675 / (856) 786-0327
<http://www.EMSL.com> cinnaminsonradonlab@emsl.com

EMSL Order: 382306839
CustomerID: GLBW42
CustomerPO:
ProjectID:

Attn: **Channa Bambaradeniya**
Global Inc.
1818 New York Avenue NE
Suite 222
Washington, DC 20002

Phone: (202) 832-1433
Fax:
Received: 11/10/2023 05:00 PM
Analysis Date: 11/11/2023
Collected: 11/3/2023

Project: **William Wirt Middle School / 6200 Tuckerman Street**

Test Site: **William Wirt Middle School**
6200 Tuckerman Street
Riverdale, MD 20737

Test Report: Radon in Air Test Results

Samples for EMSL Kit 308437

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
550236	Class Room #103	0.2	11/3/2023	11/6/2023	66	40	Customer
382306839-0018			11:01:00 AM	7:35:00 AM			

Sample Notes:

Samples for EMSL Kit 308409

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
550299	Class Room #100	0.7	11/3/2023	11/6/2023	66	40	Customer
382306839-0019			11:03:00 AM	7:13:00 AM			

Sample Notes:

Samples for EMSL Kit 308421

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
550356	Class Room #109B	0.8	11/3/2023	11/6/2023	66	40	Customer
382306839-0020			11:09:00 AM	6:58:00 AM			

Sample Notes:

Samples for EMSL Kit 308401

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
550274	Class Room #108	0.8	11/3/2023	11/6/2023	66	40	Customer
382306839-0021			11:12:00 AM	7:00:00 AM			

Sample Notes:

Samples for EMSL Kit 308399

Liquid Scintillation ID	Location	Radon Activity pCi/L	Start	Stop	Temperature F	Humidity %	Sample Type
550320	Class Roomn #106	0.7	11/3/2023	11/6/2023	66	40	Customer
382306839-0022			11:15:00 AM	7:02:00 AM			

Sample Notes:



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077
Phone/Fax: (800) 220-3675 / (856) 786-0327
<http://www.EMSL.com> cinnaminsonradonlab@emsl.com

EMSL Order: 382306839
CustomerID: GLBW42
CustomerPO:
ProjectID:

Attn: **Channa Bambaradeniya**
Global Inc.
1818 New York Avenue NE
Suite 222
Washington, DC 20002

Phone: (202) 832-1433
Fax:
Received: 11/10/2023 05:00 PM
Analysis Date: 11/11/2023
Collected: 11/3/2023

Project: **William Wirt Middle School / 6200 Tuckerman Street**

Test Site: **William Wirt Middle School**
6200 Tuckerman Street
Riverdale, MD 20737

Test Report: Radon in Air Test Results

The radon test was performed using a liquid scintillation radon detector/s and counted on a liquid scintillation counter using approved EPA testing protocols for Radon in Air testing. The EPA recommends fixing your home if the average of two short-term tests taken in the lowest lived-in level of the home show radon levels that are equal to or greater than 4.0pCi/L. The EPA recommends retesting your home every two years.

Please contact EMSL Analytical, Inc. or your State Health Department for further information. All procedures used for generating this report are in complete accordance with the current EPA protocols for the analysis of Radon in Air.

Report Note

Analyst(s)

Jeanel Zoll (22)

Dominic Gehret, Radiochemistry Laboratory Manager, NJ Radon
Measurement Specialist MES 13910
or other approved signatory

In no event shall EMSL be liable for indirect, special, consequential, or incidental damages, including, but not limited to, damages for loss of profit or goodwill regardless of the negligence (either sole or concurrent) of EMSL and whether EMSL has been informed of the possibility of such damages, arising out of or in connection with EMSL's services thereunder or the delivery, use, reliance upon or interpretation of test results by client or any third party. We accept no legal responsibility for the purposes for which the client uses the test results. In no event shall EMSL be liable to a client or any third party, whether based upon theories of tort, contract or any other legal or equitable theory, in excess of the amount paid to EMSL by client thereunder. The test results meets all NELAC requirements unless otherwise specified.

Samples analyzed by EMSL Analytical, Inc. Cinnaminson, NJ FL RB2034/R2687,IL RNL2008202,IN RTL00935,IA RNLAB10005,KS KS-LB-0005/KS-MS-0482,ME SPC202,MN RL-0005,NE 474/RMB-1083,NJ 03036/MEB92525/MES13910,NY 10872,OH RL39,OK D9952,PA 2573/3393/68-00367,RI RMB-108/RI00179,WV RL000220,NRSB-ARL6006,NRPP

Initial report from 11/13/2023 16:10:38

Please visit www.radontestinglab.com