



Environmental Consultants and Engineers

1818 New York Avenue Suite 217  
Washington, DC 20002

[www.globalincusa.net](http://www.globalincusa.net)

May 11, 2026

Prince Georges County  
Environmental Safety Office  
13306 Old Marlboro Pike  
Upper Marlboro, MD 20772  
Attention: Mr. Alex Baylor

RE: Post Fire Remediation Indoor Air Quality Inspection Report – Cesar Chavez Elementary School (Global Project Number: 26-026)

Dear Mr. Baylor,

On April 21<sup>st</sup> and April 30<sup>th</sup>, 2026, Global, Inc. (GLOBAL) conducted post fire remediation Indoor Air Quality (IAQ) Inspections at the Cesar Chavez Elementary School located at 6609 Riggs Rd, Chillum, MD 20782.

### Methodology

The IAQ inspection performed on April 21, 2026 included a visual assessment, real-time measurement of Formaldehyde (CH<sub>2</sub>O), Total Volatile Organic Compounds (TVOC), Carbon Dioxide (CO<sub>2</sub>), Carbon Monoxide (CO) and respirable particulate matter (PM<sub>2.5</sub>um and PM<sub>10</sub>um size classes) in Air.

Realtime Measurements of the above IAQ parameters were performed with calibrated field instruments mentioned below:

IAQ Parameter	Instrument
Formaldehyde (CH <sub>2</sub> O)	Extech VFM200 Meter
Total Volatile Organic Compounds (TVOC)	MiniRAE 3000 Photo Ionization Detector
Carbon Monoxide (CO) / Carbon Dioxide (CO <sub>2</sub> )	FLUKE 975 IAQ Meter
Respirable Particulates (PM <sub>2.5</sub> / PM <sub>10</sub> )	TempTop M2000C IAQ Meter

In addition, qualitative sampling and screening of Combustion By-Products (CBPs – Char, Ash and Soot) in air and furniture surfaces in selected classrooms was also performed. The wipe samples for CBPs were collected with Alcohol wipes. The air samples for CBPs were collected on *Air-O-Cell* cassettes using a Buck BioAire® calibrated pump (15 LPM for 10 minutes).

The Air and wipe samples for CBPs were shipped under strict chain-of-custody procedures to EMSL Analytical Services, Inc. in Cinnaminson, New Jersey. The samples were analyzed under Light Microscope (ASTM D6602-13 Mod). Currently, there are no industry standards for

comparison of CBP in air/surface wipe samples. Laboratory analysis of CBPs is a recent and developing technological advance, and GLOBAL, in consultation with PGPCS Environmental Division decided to adopt qualitative sampling and testing of CBPs as a proactive measure to determine if any residual contaminants are prevalent from the fire damage.

A follow-up round of air samples was collected and analyzed for CBPs on April 30<sup>th</sup>, 2026, in order to verify and compare the presence of any indoor CBPs with outdoor CBPs.

### Visual Observations

On April 21<sup>st</sup>, 2026, GLOBAL's industrial hygienist observed that all classrooms affected by fire damage at Cesar Chavez ES had been thoroughly cleaned. Any building material and/or furniture/teaching equipment affected by fire damage have been discarded. There were no unusual odors related to fire damage. Air purifiers with clean MERV 13 filters were in operation in each classroom and the adjacent hallway on April 21<sup>st</sup> as well as April 30<sup>th</sup>, 2026.

### Indoor Air Quality Parameter Measurements

The real-time measurements of IAQ parameters and applicable industry standards are summarized in Table 1 below.

**Table 1: Indoor Air Quality (IAQ) Parameter Readings (April 21, 2026; 3:45 – 4:15 PM)**

IAQ Parameter	CH2O (ppm)	TVOC (ppm)	CO (ppm)	C02 (ppm)	PM2.5 (ug/m3)	PM10.0 (ug/m3)
Industry Standard	OSHA PEL 0.75 EPA 0.3	LEED 0.25	NAAQS <9	ASHRAE <(700+Ambient)	NAAQS 9	NAAQS 150
<b>Location</b>						
Ambient	0	0	1	484	7.9	9.2
Room 13	0.21	0.10	0	890	2.7	3.6
Room 4	0.08	0	1	860	3.0	4.5
Room 14	0.09	0	0	875	2.6	3.0
Room 11	0.02	0	2	706	1.8	3.0
Room 3	0.14	0	1	895	1.4	2.5

The real-time measurement of Formaldehyde, Total Volatile Organic Compounds, Carbon Monoxide, Carbon Dioxide and Respirable Particulate Matter (PM 2.5 and PM 10 Size Classes) in the five classrooms tested were within the applicable industry standards.



Environmental Consultants and Engineers

1818 New York Avenue Suite 217  
Washington, DC 20002

[www.globalincusa.net](http://www.globalincusa.net)

### Analytical Results of Air and Wipe Samples for Combustion By-Products (CBPs)

The results for CBPs are based on qualitative analysis (presence/absence). There are no industry standards for comparison of CBP in air/surface wipe samples.

All indoor air samples collected on April 21, 2026 were positive for CBPs (see laboratory analytical results and chain-of-custody form in **Attachment I**). The wipe samples collected from furniture surfaces in some of the classrooms tested positive for CBPs, but the amount was less than 1%.

Since CBPs were detected in air samples collected from indoors on April 21<sup>st</sup>, 2026, a follow-up round of air sampling was performed for CBPs on April 30<sup>th</sup>, 2026 to include an outdoor sample as well which was considered as the background sample. The analytical results revealed the presence of CBPs in indoor as well as the outdoor air sample, hence confirming that there is no difference of CBPs between indoor and outdoor air samples (see laboratory analytical results and chain-of-custody form in **Attachment II**). As indicated in the lab results, it should be noted that Black carbon (soot) documented in indoor and outdoor air samples is based on **presumptive analysis** only (i.e., not a definitive identification).

### Conclusions and Recommendations

The real-time measurements of key indoor air quality indicators for fire damage obtained on April 21, 2026 including Formaldehyde, Total Volatile Organic Compounds, Carbon Monoxide, Carbon Dioxide and Respirable Particulate Matter (PM 2.5 and PM 10 Size Classes) in the five classrooms were within the applicable industry standards.

The analytical results of wipe samples for CBPs collected on April 21<sup>st</sup>, 2026 from representative furniture surfaces in the five classrooms indicates efficient cleanup.

Based on the analytical results of air samples for CBPs collected on April 30<sup>th</sup>, CBPs were detected in indoor as well as ambient (outdoor) air samples. Therefore, with regards to CBPs, there is no difference between the indoor air and outdoor air (i.e., the normal background condition) at Cesar Chavez ES. The results do not indicate residual contamination from the fire. Soot and char particles are commonly present at low levels in outdoor air due to sources like vehicle exhaust, industrial activity, and even distant fires. So simply detecting CBPs indoors is not unusual. It should be noted that Cesar Chavez ES is located adjacent to a main thoroughfare – the Riggs Road.

Based on the timely adoption of efficient fire damage restoration practices, post-remediation visual observations and real-time measurements of IAQ indicators for fire damage, GLOBAL and PGCPS deemed it safe for the children and teachers to re-occupy the affected classrooms at Cesar Chavez Elementary School. Furthermore, air purifiers with MERV-13 rated filters were placed and operated in each remediated classroom for an extended period as a proactive measure to ensure healthy indoor air quality. We have no further recommendations at this time.



Environmental Consultants and Engineers

1818 New York Avenue Suite 217  
Washington, DC 20002

[www.globalincusa.net](http://www.globalincusa.net)

---

It has been our pleasure to conduct post fire remediation indoor air quality inspection services for the Prince Georges County Public School system. If you have any questions, please feel free to contact us.

Regards,

A handwritten signature in blue ink, appearing to read "Channa Bambaradeniya".

Channa Bambaradeniya, Ph.D., CIH, CSP, CHMM

Certified Industrial Hygienist



Environmental Consultants and Engineers

1818 New York Avenue Suite 217  
Washington, DC 20002

[www.globalincusa.net](http://www.globalincusa.net)

---

## **Attachment I**

Laboratory Analytical Results and Chain-of-Custody Forms for  
Combustion By-Products in Air and Wipe Samples Collected on  
April 21<sup>st</sup>, 2026



**EMSL Analytical, Inc.**  
 200 Route 130 North Cinnaminson, NJ 08077  
 Phone: Toll Free: 800-220-3675 | Fax: 856-786-5971  
[www.emsl.com](http://www.emsl.com) [info@emsl.com](mailto:info@emsl.com)

EMSL Order: **362601468**  
 Customer ID: **GLOC62**  
 Customer PO: **n/a**

Attn: **Channa Bambaradeniya**  
**Global, Inc.**  
 1818 New York Ave NE, S-217  
 Washington, DC 20002

Phone: **(443) 691-0455**  
 Fax: **-**

Collected: **4/21/2026**  
 Received: **4/24/2026**  
 Analyzed: **4/27/2026**

Project: **Cesar Chavez ES Fire Damage Monitoring ( Job # 26-026)**

**- Laboratory Report -**  
**Combustion By-Products**  
**-Screening-**

<i>EMSL Sample ID</i>	<i>Sample ID</i>	<i>Description</i>	<i>Analyte</i>	<i>Qualifier</i>	<i>Comments (Sample Specific)</i>
362601468-0001	AS-1	Room – 11	Carbonized Material (Char) Carbonized Material (Ash) Black Carbon (Soot)*	Present Not Present Present	The sample is spore trap. Qualitative analysis only.
362601468-0002	AS-2	Room – 3	Carbonized Material (Char) Carbonized Material (Ash) Black Carbon (Soot)*	Not Present Not Present Present	The sample is spore trap. Qualitative analysis only.
362601468-0003	AS-3	Room – 4	Carbonized Material (Char) Carbonized Material (Ash) Black Carbon (Soot)*	Present Not Present Not Present	The sample is spore trap. Qualitative analysis only.
362601468-0004	AS-4	Room – 13	Carbonized Material (Char) Carbonized Material (Ash) Black Carbon (Soot)*	Not Present Not Present Present	The sample is spore trap. Qualitative analysis only.
362601468-0005	AS-5	Room – 14	Carbonized Material (Char) Carbonized Material (Ash) Black Carbon (Soot)*	Not Present Not Present Present	The sample is spore trap. Qualitative analysis only.

\* Black Carbon/Soot analysis is limited to presumptive analysis only. In order to resolve the submicron size and the aciniform morphology of the particles confirmatory analysis by Transmission Electron Microscopy (TEM) is needed.

Methods and instrumentation: Polarized Light Microscopy (PLM), Stereomicroscopy, epi-Reflected Light Microscopy (RLM).





**EMSL Analytical, Inc.**  
 200 Route 130 North Cinnaminson, NJ 08077  
 Phone: Toll Free: 800-220-3675 | Fax: 856-786-5971  
[www.emsl.com](http://www.emsl.com) [info@emsl.com](mailto:info@emsl.com)

EMSL Order: **362601468**  
 Customer ID: **GLOC62**  
 Customer PO: **n/a**

Attn: **Channa Bambaradeniya**  
**Global, Inc.**  
 1818 New York Ave NE, S-217  
 Washington, DC 20002

Phone: **(443) 691-0455**  
 Fax: **-**

Collected: **4/21/2026**  
 Received: **4/24/2026**  
 Analyzed: **4/27/2026**

Project: **Cesar Chavez ES Fire Damage Monitoring ( Job # 26-026)**

**- Laboratory Report -  
 Combustion By-Products  
 -Screening-**

<i>EMSL Sample ID</i>	<i>Sample ID</i>	<i>Description</i>	<i>Analyte</i>	<i>Qualifier</i>	<i>Comments (Sample Specific)</i>
362601468-0006	AS-6	Blank	Carbonized Material (Char) Carbonized Material (Ash) Black Carbon (Soot)*	Not Present Not Present Not Present	The sample is spore trap. Qualitative analysis only.
362601468-0007	WS-1	Room – 11	Carbonized Material (Char) Carbonized Material (Ash) Black Carbon (Soot)*	Present Not Present Present	The amount of char in this sample is <1%. The amount of soot is <1% (presumptive analysis).
362601468-0008	WS-2	Room – 03	Carbonized Material (Char) Carbonized Material (Ash) Black Carbon (Soot)*	Not Present Not Present Present	The amount of soot is <1% (presumptive analysis).
362601468-0009	WS-3	Room – 04	Carbonized Material (Char) Carbonized Material (Ash) Black Carbon (Soot)*	Not Present Not Present Not Present	None.
362601468-0010	WS-4	Room – 13	Carbonized Material (Char) Carbonized Material (Ash) Black Carbon (Soot)*	Not Present Not Present Not Present	None.

\* Black Carbon/Soot analysis is limited to presumptive analysis only. In order to resolve the submicron size and the aciniform morphology of the particles confirmatory analysis by Transmission Electron Microscopy (TEM) is needed.

Methods and instrumentation: Polarized Light Microscopy (PLM), Stereomicroscopy, epi-Reflected Light Microscopy (RLM).



**EMSL Analytical, Inc.**  
 200 Route 130 North Cinnaminson, NJ 08077  
 Phone: Toll Free: 800-220-3675 | Fax: 856-786-5971  
[www.emsl.com](http://www.emsl.com) [info@emsl.com](mailto:info@emsl.com)

EMSL Order: **362601468**  
 Customer ID: **GLOC62**  
 Customer PO: n/a

Attn: **Channa Bambaradeniya**  
**Global, Inc.**  
 1818 New York Ave NE, S-217  
 Washington, DC 20002

Phone: **(443) 691-0455**  
 Fax: -

Collected: **4/21/2026**  
 Received: **4/24/2026**  
 Analyzed: **4/27/2026**

Project: **Cesar Chavez ES Fire Damage Monitoring ( Job # 26-026)**

**- Laboratory Report -**  
**Combustion By-Products**  
**-Screening-**

<i>EMSL Sample ID</i>	<i>Sample ID</i>	<i>Description</i>	<i>Analyte</i>	<i>Qualifier</i>	<i>Comments (Sample Specific)</i>
362601468-0011	WS-5	Room – 14	Carbonized Material (Char) Carbonized Material (Ash) Black Carbon (Soot)*	Not Present Not Present Present	The amount of soot is <1% (presumptive analysis).
362601468-0012	WS-6	Blank	Carbonized Material (Char) Carbonized Material (Ash) Black Carbon (Soot)*	Not Present Not Present Not Present	None.

\* Black Carbon/Soot analysis is limited to presumptive analysis only. In order to resolve the submicron size and the aciniform morphology of the particles confirmatory analysis by Transmission Electron Microscopy (TEM) is needed.

Methods and instrumentation: Polarized Light Microscopy (PLM), Stereomicroscopy, epi-Reflected Light Microscopy (RLM).

Marietta Rowand  
 Laboratory Technician

Eugenia Mirica, Ph.D.  
 Laboratory Director

Sample received in acceptable condition unless otherwise noted. The QC data associated with these sample results included in this report meet the method quality control requirements, unless specifically indicated otherwise. Unless noted, results in this report are not blank corrected. This report relates only to the samples reported above and may not be reproduced, except in full, without written approval by EMSL Analytical, Inc.. EMSL Analytical, Inc. bears no responsibility for sample collection activities. Sample Retention: Samples analyzed by EMSL Analytical, Inc. will be retained for 60 days after analysis date. Storage beyond this period is available for a fee with written request prior to the initial 30 day period. Samples containing hazardous/toxic substances which require special handling may be returned to the client immediately. EMSL Analytical, Inc. reserves the right to charge a sample disposal fee or return samples to the client. Change Orders and Cancellation: All changes in the scope of work or turnaround time requested by the client after sample acceptance must be made in writing and confirmed in writing by EMSL Analytical, Inc.. If requested changes result in a change in cost the client must accept payment responsibility. In the event work is cancelled by a client, EMSL Analytical, Inc. will complete work in progress and invoice for work completed to the point of cancellation notice. EMSL Analytical, Inc. is not responsible for holding times that are exceeded due to such changes. Warranty: EMSL Analytical, Inc. warrants to its clients that all services provided hereunder shall be performed in accordance with established and recognized analytical testing procedures and with reasonable care in accordance with applicable federal, state and local laws. The foregoing express warranty is exclusive and is given in lieu of all other warranties, expressed or implied. EMSL Analytical, Inc. disclaims any other warranties, express or implied, including a warranty of fitness for particular purpose and warranty of merchantability. Limits of Liability: In no event shall EMSL Analytical, Inc. be liable for indirect, special, consequential, or incidental damages, including, but not limited to, damages for loss of profit or goodwill regardless of the negligence (either sole or concurrent) of EMSL Analytical, Inc. and whether EMSL Analytical, Inc. has been informed of the possibility of such damages, arising out of or in connection with EMSL Analytical, Inc.'s services there under or the delivery, use, reliance upon or interpretation of test results by client or any third party. We accept no legal responsibility for the purposes for which the client uses the test results. EMSL Analytical, Inc. will not be held responsible for the improper selection of sampling devices even if we supply the device to the user. The user of the sampling device has the sole responsibility to select the proper sampler and sampling conditions to ensure that a valid sample is taken for analysis. Any resampling performed will be at the sole discretion of EMSL Analytical, Inc., the cost of which shall be limited to the reasonable value of the original sample delivery group (SDG) samples. In no event shall EMSL Analytical, Inc. be liable to a client or any third party, whether based upon theories of tort, contract or any other legal or equitable theory, in excess of the amount paid to EMSL Analytical, Inc. by client there under.

# Industrial Hygiene - Chain of Custody

EMSL Order Number / Lab Use Only

362601468

200 Route 130 North  
Cinnaminson, NJ 08077

PHONE: (800) 220-3675  
EMAIL: c@emsl.com

If Bill-To is the same as Report-To leave this section blank. Third-party billing requires written authorization.

**Customer Information**

Customer ID: GLOC62  
 Company Name: Global, Inc.  
 Contact Name: Channa Bambaradeniya  
 Street Address: 1818 New York Ave NE, S-217  
 City, State, Zip: Washington, DC 20002  
 Phone: 443-691-0455  
 Email(s) for Report: channab@globalincusa.net

**Billing Information**

Billing ID:  
 Company Name: Global, Inc.  
 Billing Contact: Same  
 Street Address: Same  
 City, State, Zip:  
 Phone:  
 Email(s) for Invoice:

RECEIVED  
EMSL  
CINNAMINSON, NJ  
2026 APR 24 A 10:00

Project Name/No: Cesar Chavez ES Fire Damage Monitoring (Job # 26-026)

EMSL LIMS Project ID: (If applicable, EMSL will provide)

Media Type: Air and wipes

Media Manufacturer/Part Number:

Sampled By Signature: *[Signature]*

US State where samples collected: MD

State of Connecticut (CT) must select project location:  
 Commercial (Taxable)  Residential (Non-Taxable)

Media Lot Number:

No. Samples in Shipment:

Turnaround Time (TAT) Options - Please check:  
 (If no selection made, Standard 2 Week (EOD) TAT will apply)

1 Week  2 Week  3 Day  4 Day  1 Day  Other (Call Lab)

Client Sample ID	Location/Description	Analyte/Method	Media	Flow (lpm)	Sample Time		Volume/Area	Sample Type		Sample Date	Comments
					On	Off		Area Personal	Area Personal		
AS-1	Room - 11	S-CBP	Air	15	3:20 pm	3:30 pm	150L	<input checked="" type="checkbox"/>	<input type="checkbox"/>	4/21/2026	Screening - CBP
AS-2	Room - 3		Air		3:32 pm	3:42 pm		<input checked="" type="checkbox"/>	<input type="checkbox"/>		
AS-3	Room - 4		Air		3:45 pm	3:55 pm		<input checked="" type="checkbox"/>	<input type="checkbox"/>		
AS-4	Room - 13		Air		3:56 pm	4:06 pm		<input checked="" type="checkbox"/>	<input type="checkbox"/>		
AS-5	Room - 14		Air		4:08 pm	4:18 pm		<input checked="" type="checkbox"/>	<input type="checkbox"/>		
AS-6	Blank							<input type="checkbox"/>	<input type="checkbox"/>		

Special Instructions and/or Regulatory Requirements (Sample Specifications, Processing Methods, Limits of Detection, etc.)

Method of Shipment:

Relinquished by: Sajith Samarasinghe Date/Time: 4/21/26

Relinquished by: *[Signature]* Date/Time: 4/21/26 10:4M

Sample Condition Upon Receipt:

Received by: *[Signature]* Date/Time: 4/21/26 10:4M

Received by: *[Signature]* Date/Time: 4/21/26 10:4M

Controlled Document - COC-21 Industrial Hygiene R4 05/12/2021

AGREE TO ELECTRONIC SIGNATURE (By checking, I consent to signing this Chain of Custody document by electronic signature.)

EMSL Analytical, Inc.'s Laboratory Terms and Conditions are incorporated into this Chain of Custody by reference in their entirety. Submission of samples to EMSL Analytical, Inc. constitutes acceptance and acknowledgment of all terms and conditions by Customer.

Page 1 of 1





Environmental Consultants and Engineers

1818 New York Avenue Suite 217  
Washington, DC 20002

[www.globalincusa.net](http://www.globalincusa.net)

---

## **Attachment II**

Laboratory Analytical Results and Chain-of-Custody Forms for  
Combustion By-Products in Air Samples Collected on April 30<sup>th</sup>, 2026



**EMSL Analytical, Inc.**  
 200 Route 130 North Cinnaminson, NJ 08077  
 Phone: Toll Free: 800-220-3675 | Fax: 856-786-5971  
[www.emsl.com](http://www.emsl.com) [info@emsl.com](mailto:info@emsl.com)

EMSL Order: **362601582**  
 Customer ID: **GLOC62**  
 Customer PO: n/a

Attn: **Channa Bambaradeniya**  
**Global, Inc.**  
**1818 New York Ave NE, S-217**  
**Washington, DC 20002**

Phone: **(443) 691-0455**  
 Fax: **channab@globalincusa.net**

Project: **Cesar Chavez ES Fire Damage Monitoring (Job # 26-026)**

Collected: **4/30/2026**  
 Received: **5/1/2026**  
 Analyzed: **5/4/2026**

**- Laboratory Report -**  
**Combustion By-Products**  
**-Screening-**

<i>EMSL Sample ID</i>	<i>Sample ID</i>	<i>Description</i>	<i>Analyte</i>	<i>Qualifier</i>	<i>Comments (Sample Specific)</i>
362601582-0001	AS-1	Room – 11	Carbonized Material (Char) Carbonized Material (Ash) Black Carbon (Soot)*	Not Present Not Present Present	The sample is a spore trap. Qualitative analysis only.
362601582-0002	AS-2	Room – 3	Carbonized Material (Char) Carbonized Material (Ash) Black Carbon (Soot)*	Not Present Not Present Present	The sample is a spore trap. Qualitative analysis only.
362601582-0003	AS-3	Room – 4	Carbonized Material (Char) Carbonized Material (Ash) Black Carbon (Soot)*	Present Not Present Present	The sample is a spore trap. Qualitative analysis only.
362601582-0004	AS-4	Room – 13	Carbonized Material (Char) Carbonized Material (Ash) Black Carbon (Soot)*	Present Not Present Present	The sample is a spore trap. Qualitative analysis only.
362601582-0005	AS-5	Room – 14	Carbonized Material (Char) Carbonized Material (Ash) Black Carbon (Soot)*	Not Present Not Present Present	The sample is a spore trap. Qualitative analysis only.

\* Black Carbon/Soot analysis is limited to presumptive analysis only. In order to resolve the submicron size and the aciniform morphology of the particles confirmatory analysis by Transmission Electron Microscopy (TEM) is needed.

Methods and instrumentation: Polarized Light Microscopy (PLM), Stereomicroscopy, epi-Reflected Light Microscopy (RLM).





**EMSL Analytical, Inc.**  
 200 Route 130 North Cinnaminson, NJ 08077  
 Phone: Toll Free: 800-220-3675 | Fax: 856-786-5971  
[www.emsl.com](http://www.emsl.com) [info@emsl.com](mailto:info@emsl.com)

EMSL Order: **362601582**  
 Customer ID: **GLOC62**  
 Customer PO: **n/a**

Attn: **Channa Bambaradeniya**  
**Global, Inc.**  
**1818 New York Ave NE, S-217**  
**Washington, DC 20002**

Phone: **(443) 691-0455**  
 Fax: **channab@globalincusa.net**

Collected: **4/30/2026**  
 Received: **5/1/2026**  
 Analyzed: **5/4/2026**

Project: **Cesar Chavez ES Fire Damage Monitoring (Job # 26-026)**

**- Laboratory Report -**  
**Combustion By-Products**  
**-Screening-**

<i>EMSL Sample ID</i>	<i>Sample ID</i>	<i>Description</i>	<i>Analyte</i>	<i>Qualifier</i>	<i>Comments (Sample Specific)</i>
362601582-0006	AS-6	Ambient	Carbonized Material (Char) Carbonized Material (Ash) Black Carbon (Soot)*	Present Not Present Present	The sample is a spore trap. Qualitative analysis only.
362601582-0007	AS-7	Blank	Carbonized Material (Char) Carbonized Material (Ash) Black Carbon (Soot)*	Not Present Not Present Not Present	The sample is a spore trap. Qualitative analysis only.

\* Black Carbon/Soot analysis is limited to presumptive analysis only. In order to resolve the submicron size and the aciniform morphology of the particles confirmatory analysis by Transmission Electron Microscopy (TEM) is needed.

Methods and instrumentation: Polarized Light Microscopy (PLM), Stereomicroscopy, epi-Reflected Light Microscopy (RLM).

Heather Yamka  
 Laboratory Analyst

Eugenia Mirica, Ph.D.  
 Laboratory Director

Sample received in acceptable condition unless otherwise noted. The QC data associated with these sample results included in this report meet the method quality control requirements, unless specifically indicated otherwise. Unless noted, results in this report are not blank corrected. This report relates only to the samples reported above and may not be reproduced, except in full, without written approval by EMSL Analytical, Inc.. EMSL Analytical, Inc. bears no responsibility for sample collection activities. Sample Retention: Samples analyzed by EMSL Analytical, Inc. will be retained for 60 days after analysis date. Storage beyond this period is available for a fee with written request prior to the initial 30 day period. Samples containing hazardous/toxic substances which require special handling may be returned to the client immediately. EMSL Analytical, Inc. reserves the right to charge a sample disposal fee or return samples to the client. Change Orders and Cancellation: All changes in the scope of work or turnaround time requested by the client after sample acceptance must be made in writing and confirmed in writing by EMSL Analytical, Inc.. If requested changes result in a change in cost the client must accept payment responsibility. In the event work is cancelled by a client, EMSL Analytical, Inc. will complete work in progress and invoice for work completed to the point of cancellation notice. EMSL Analytical, Inc. is not responsible for holding times that are exceeded due to such changes. Warranty: EMSL Analytical, Inc. warrants to its clients that all services provided hereunder shall be performed in accordance with established and recognized analytical testing procedures and with reasonable care in accordance with applicable federal, state and local laws. The foregoing express warranty is exclusive and is given in lieu of all other warranties, expressed or implied. EMSL Analytical, Inc. disclaims any other warranties, express or implied, including a warranty of fitness for particular purpose and warranty of merchantability. Limits of Liability: In no event shall EMSL Analytical, Inc. be liable for indirect, special, consequential, or incidental damages, including, but not limited to, damages for loss of profit or goodwill regardless of the negligence (either sole or concurrent) of EMSL Analytical, Inc. and whether EMSL Analytical, Inc. has been informed of the possibility of such damages, arising out of or in connection with EMSL Analytical, Inc.'s services there under or the delivery, use, reliance upon or interpretation of test results by client or any third party. We accept no legal responsibility for the purposes for which the client uses the test results. EMSL Analytical, Inc. will not be held responsible for the improper selection of sampling devices even if we supply the device to the user. The user of the sampling device has the sole responsibility to select the proper sampler and sampling conditions to ensure that a valid sample is taken for analysis. Any resampling performed will be at the sole discretion of EMSL Analytical, Inc., the cost of which shall be limited to the reasonable value of the original sample delivery group (SDG) samples. In no event shall EMSL Analytical, Inc. be liable to a client or any third party, whether based upon theories of tort, contract or any other legal or equitable theory, in excess of the amount paid to EMSL Analytical, Inc. by client there under.

EMSL Analytical, Inc.  
200 Route 130 North  
Cinnaminson, NJ 08077

PHONE: (800) 220-3675  
EMAIL: c@emsl.com

### Industrial Hygiene - Chain of Custody

EMSL Order Number / Lab Use Only

362601582



If Bill-To is the same as Report-To leave this section blank. Third-party billing requires written authorization.

Customer ID: GLOC62		Billing ID:	
Company Name: Global, Inc.		Company Name: Global, Inc.	
Contact Name: Channa Bambaradeniya		Billing Contact: Same	
Street Address: 1818 New York Ave NE, S-217		Street Address: Same	
City, State, Zip: Washington, DC 20002		City, State, Zip: Same	
Phone: 443-691-0455		Phone: Same	
Email(s) for Report: channab@globalincusa.net		Email(s) for Invoice: Same	
Project Name/No: Cesar Chavez ES Fire Damage Monitoring (Job # 26-026)		Purchase Order:	

EMSL LIMS Project ID: (If applicable, EMSL will provide)	US State where samples collected: MD	State of Connecticut (CT) must select project location: <input type="checkbox"/> Commercial (Taxable) <input type="checkbox"/> Residential (Non-Taxable)
Media Type: Air	Media Manufacturer/Part Number:	Media Lot Number:
Sampled By Signature: <i>Sajith</i>	No. Samples in Shipment:	

Client Sample ID	Location/Description	Analyte/Method	Media	Flow (lpm)	Sample Time		Volume/Area	Sample Type	Sample Date	Comments
					On	Off				
AS-1	Room - 11	S-CBP	Air	15	6:25 Am	6:35 Am	150L	<input checked="" type="checkbox"/> Area Personal	4/30/2026	RECEIVED EMSL CINNAMINSON, NJ 2026 MAY -1 A 11:16
AS-2	Room - 3		Air		6:36 Am	6:46 Am		<input checked="" type="checkbox"/> Area Personal		
AS-3	Room - 4		Air		6:47 Am	6:57 Am		<input checked="" type="checkbox"/> Area Personal		
AS-4	Room - 13		Air		6:58 Am	7:08 Am		<input checked="" type="checkbox"/> Area Personal		
AS-5	Room - 14		Air		7:10 Am	7:20 Am		<input checked="" type="checkbox"/> Area Personal		
AS-6	Ambient		Air		7:22 Am	7:32 Am		<input checked="" type="checkbox"/> Area Personal		
AS-7	Blank							<input type="checkbox"/> Area Personal		

Special Instructions and/or Regulatory Requirements (Sample Specifications, Processing Methods, Limits of Detection, etc.)

Method of Shipment:

Relinquished by: *Sajith Samarasinghe* Date/Time: 4/30/26

Relinquished by: *Gileen Palladum* Date/Time: 5/12/26 10AM